



U.S. Department  
Of Transportation  
**Pipeline and  
Hazardous Materials  
Safety Administration**

820 Bear Tavern Road, Suite 103  
West Trenton, NJ 08628  
**609.989.2171**

## **WITHDRAWAL of NOTICE LETTER**

### **OVERNIGHT EXPRESS MAIL**

May 10, 2012

Randy Barnard  
President, Natural Gas Pipelines  
Williams Partners  
2800 Post Oak Blvd  
Houston, TX 77056

**CPF 1-2012-1011M**

Dear Mr. Barnard:

On April 23, 2012, Williams Transco Gas Pipeline (Williams) was issued a Notice of Amendment (Notice) for the case number referenced above. This Notice cited Williams for inadequate procedure because it failed to address actions to take when gas is detected inside a building.

On April 30, 2012, Williams submitted (via email) 3 pages from its WGP Emergency Plan and Preparedness Manual that upon our further review were determined to address actions to take when gas is detected inside a building.

This letter is to inform you that Pipeline and Hazardous Materials Safety Administration (PHMSA) hereby withdraws the Notice and that the case is now closed.

Sincerely,

Byron Coy, PE  
Director, Eastern Region  
Pipeline and Hazardous Materials Safety Administration