



U.S. Department
Of Transportation
**Pipeline and
Hazardous Materials
Safety Administration**

820 Bear Tavern Road, Suite 103
West Trenton, NJ 08628
609.989.2171

**NOTICE OF PROBABLE VIOLATION
and
PROPOSED CIVIL PENALTY**

EXPRESS OVERNIGHT MAIL

April 06, 2012

Mr. Jerry Ashcroft
Buckeye Partners, L.P.
Five TEK Park,
999 Hamilton Blvd
Breinigsville, PA 18031

CPF 1-2012-5009

Dear Mr. Ashcroft:

Between September 20, 2011, and March 12, 2012, inspectors from the New York State Department of Public Service (NYSDPS), acting as agents for the Pipeline and Hazardous Materials Safety Administration (PHMSA) pursuant to Chapter 601 of 49 United States Code conducted an accident investigation regarding the September 20, 2011, incident that occurred at your Auburn Terminal in Auburn, New York. The accident was due to internal corrosion on a 14" diameter tank line (line 318).

As a result of the inspection, it appears that you have committed a probable violation of the Pipeline Safety Regulations, Title 49, Code of Federal Regulations. The items inspected and the probable violation(s) are:

- 1. §195.54 (b) - Accident reports.
(b) Whenever an operator receives any changes in the information reported or additions to the original report on DOT Form 7000-1, it shall file a supplemental report within 30 days.**

Buckeye failed to submit a Supplemental Accident Report within 30 days upon receiving changes or additions to the original report submitted using DOT Form 7000-1.

Buckeye failed to submit a Supplemental Accident Report within 30 days, as required under Section 195.54, upon receiving the Final Metallurgical Report from DET NORSKE VERITAS (DNV), dated December 22, 2011. The DNV Report identified the potential cause

of the leak on the 14-inch diameter Tank Line (Line 318) at Buckeye's Auburn Terminal in Auburn (Cayuga County), New York. The original accident report was filed by Buckeye on October 19, 2011.

Proposed Civil Penalty

Under 49 United States Code, § 60122, you are subject to a civil penalty not to exceed \$100,000 for each violation for each day the violation persists up to a maximum of \$1,000,000 for any related series of violations. The Compliance Officer has reviewed the circumstances and supporting documentation involved in the above probable violation and has recommended that you be preliminarily assessed a civil penalty of \$22,500 as follows:


<u>Item number</u>	<u>PENALTY</u>
1	\$22,500

Response to this Notice

Enclosed as part of this Notice is a document entitled *Response Options for Pipeline Operators in Compliance Proceedings*. Please refer to this document and note the response options. Be advised that all material you submit in response to this enforcement action is subject to being made publicly available. If you believe that any portion of your responsive material qualifies for confidential treatment under 5 U.S.C. 552(b), along with the complete original document you must provide a second copy of the document with the portions you believe qualify for confidential treatment redacted and an explanation of why you believe the redacted information qualifies for confidential treatment under 5 U.S.C. 552(b). If you do not respond within **30** days of receipt of this Notice, this constitutes a waiver of your right to contest the allegations in this Notice and authorizes the Associate Administrator for Pipeline Safety to find facts as alleged in this Notice without further notice to you and to issue a Final Order.

Please submit all correspondence in this matter to Byron Coy, PE, Director, PHMSA Eastern Region, 820 Bear Tavern Road, Suite 103, W. Trenton, NJ 08628. Please refer to **CPF 1-2012-5009** on each document you submit, and please whenever possible provide a signed PDF copy in electronic format. Smaller files may be emailed to Byron.Coy@dot.gov. Larger files should be sent on a CD accompanied by the original paper copy to the Eastern Region Office.

Sincerely,



Byron Coy, PE
Director, Eastern Region
Pipeline and Hazardous Materials Safety Administration

Cc: Mr. Kevin Speicher, NYSDPS

Enclosure: *Response Options for Pipeline Operators in Compliance Proceedings*