

NOTICE OF AMENDMENT

OVERNIGHT EXPRESS DELIVERY

October 29, 2018

Mr. Scott Warnshouse
General Manager Operations
Honeoye Storage Corp.
4511 Egypt Road
Canandaigua, NY 14424

CPF 1-2018-1022M

Dear Mr. Warnshouse:

From June 19 to 21, 2018, representatives of the Pipeline and Hazardous Materials Safety Administration (PHMSA) pursuant to Chapter 601 of 49 United States Code inspected Honeoye Storage Corp. (Honeoye) procedures and records for the Honeoye Underground Natural Gas Storage field in Ontario County, New York.

On the basis of the inspection, PHMSA has identified the apparent inadequacies found within Honeoye's plans or procedures, as described below:

1. § 192.12 Underground natural gas storage facilities.

(e) Operators of underground gas storage facilities must establish and follow written procedures for operations, maintenance, and emergencies implementing the requirements of API RP 1170 and API RP 1171, as required under this section, including the effective dates as applicable, and incorporate such procedures into their written procedures for operations, maintenance, and emergencies established pursuant to §192.605.

Honeoye's procedures for operations, maintenance and emergencies implementing the requirements of API RP 1170 and API RP 1171 were inadequate. Specifically, Honeoye's procedures do not define an annular pressure threshold to determine if additional evaluation is required in accordance with API RP 1171, Section 9.3.2.

2. § 192.12 Underground natural gas storage facilities.

(e) Operators of underground gas storage facilities must establish and follow written procedures for operations, maintenance, and emergencies implementing the requirements of API RP 1170 and API RP 1171, as required under this section, including the effective dates as applicable, and incorporate such procedures into their written procedures for operations, maintenance, and emergencies established pursuant to §192.605.

Honeye's procedures for operations, maintenance and emergencies implementing the requirements of API RP 1170 and API RP 1171 were inadequate. Specifically, Honeye does not have a procedure to verify all applicable staff receive training in the use of the emergency preparedness/response plan in accordance with API RP 1171, Section 10.6.2.

3. § 192.12 Underground natural gas storage facilities.

(e) Operators of underground gas storage facilities must establish and follow written procedures for operations, maintenance, and emergencies implementing the requirements of API RP 1170 and API RP 1171, as required under this section, including the effective dates as applicable, and incorporate such procedures into their written procedures for operations, maintenance, and emergencies established pursuant to §192.605.

Honeye's procedures for operations, maintenance and emergencies implementing the requirements of API RP 1170 and API RP 1171 were inadequate. Specifically, Honeye does not have a procedure to measure the effectiveness of operator familiarity with emergency plans and procedures and periodic testing of the effectiveness of the plan in accordance with API RP 1171, Section 11.4.2.

4. § 192.12 Underground natural gas storage facilities.

(e) Operators of underground gas storage facilities must establish and follow written procedures for operations, maintenance, and emergencies implementing the requirements of API RP 1170 and API RP 1171, as required under this section, including the effective dates as applicable, and incorporate such procedures into their written procedures for operations, maintenance, and emergencies established pursuant to §192.605.

Honeye's procedures for operations, maintenance and emergencies implementing the requirements of API RP 1170 and API RP 1171 were inadequate. Specifically, Honeye does not have a procedure for the joining of API and ANSI flanges as observed in the field portion of the inspection, in accordance with API RP 1171 Section 11.2.1.

Response to this Notice

This Notice is provided pursuant to 49 U.S.C. § 60108(a) and 49 C.F.R. § 190.206. Enclosed as part of this Notice is a document entitled *Response Options for Pipeline Operators in Compliance Proceedings*. Please refer to this document and note the response options. Be advised that all material you submit in response to this enforcement action is subject to being made publicly available. If you believe that any portion of your responsive material qualifies for confidential

treatment under 5 U.S.C. 552(b), along with the complete original document you must provide a second copy of the document with the portions you believe qualify for confidential treatment redacted and an explanation of why you believe the redacted information qualifies for confidential treatment under 5 U.S.C. 552(b).

Following the receipt of this Notice, you have 30 days to submit written comments, revised procedures, or a request for a hearing under §190.211. If you do not respond within 30 days of receipt of this Notice, this constitutes a waiver of your right to contest the allegations in this Notice and authorizes the Associate Administrator for Pipeline Safety to find facts as alleged in this Notice without further notice to you and to issue an Order Directing Amendment. If your plans or procedures are found inadequate as alleged in this Notice, you may be ordered to amend your plans or procedures to correct the inadequacies (49 C.F.R. § 190.206). If you are not contesting this Notice, we propose that you submit your amended procedures to my office within 90 days of receipt of this Notice. This period may be extended by written request for good cause. Once the inadequacies identified herein have been addressed in your amended procedures, this enforcement action will be closed.

It is requested (not mandated) that Honeoye maintain documentation of the safety improvement costs associated with fulfilling this Notice of Amendment (preparation/revision of plans, procedures) and submit the total to Robert Burrough, Director, Eastern Region, Pipeline and Hazardous Materials Safety Administration. In correspondence concerning this matter, please refer to **CPF 1-2018-1022M** and, for each document you submit, please provide a copy in electronic format whenever possible.

Please note, the address for the PHMSA Eastern Region, Office of Pipeline Safety, has changed:

PHMSA, Eastern Region, Office of Pipeline Safety
840 Bear Tavern Road, Suite 300
West Trenton, NJ 08628

Please make a note of this new information in your records. If you have any questions, please contact us at 609-771-7800.

Sincerely,

Robert Burrough
Director, Eastern Region
Pipeline and Hazardous Materials Safety Administration

Enclosure: *Response Options for Pipeline Operators in Compliance Proceedings*