



U.S. Department  
of Transportation

**Pipeline and  
Hazardous Materials  
Safety Administration**

840 Bear Tavern Road, Suite 300  
West Trenton, NJ 08628  
609.771.7800

## WARNING LETTER

### OVERNIGHT EXPRESS DELIVERY

February 8, 2022

Mr. Scott Jaskowiak  
President  
Spire Storage West LLC  
700 Market Street  
St Louis, Missouri 63101

**CPF 1-2022-010-WL**

Dear Mr. Jaskowiak:

From October 13 to 16, 2020, a representative of the Pipeline and Hazardous Materials Safety Administration (PHMSA) pursuant to Chapter 601 of 49 United States Code (U.S.C.) inspected Spire Storage West LLC's (Spire) Underground Natural Gas Storage in Evanston, Wyoming.

As a result of the inspection, it is alleged that you have committed a probable violation of the Pipeline Safety Regulations, Title 49, Code of Federal Regulations (CFR). The item inspected and the probable violation is:

1. **§ 192.12 Underground natural gas storage facilities.**
  - (a) ...
  - (b) *Depleted hydrocarbon and aquifer reservoir UNGSFs.*
    - (1) ...
    - (2) **Each UNGSF that uses a depleted hydrocarbon reservoir or an aquifer reservoir for natural gas storage and was constructed on or before July 18, 2017, must meet the provisions of API RP 1171 (incorporated by reference, see § 192.7), sections 8, 9, 10, and 11, and paragraph (c) of this section, by January 18, 2018, and must meet all provisions of paragraph (d) of this section by March 13, 2021.**

Spire failed to meet the provisions of § 192.12(c) by January 18, 2018. Specifically, Spire's O&M Manual, Management of Change Plan (MOC), Emergency Response Plan (ERP) (Section 10.6.1), and Blowout Contingency Plan (BCP) (Section 10.6.3), applicable to its underground natural gas storage facilities (UNGSF), were not created until March of 2020, past the January 18, 2018 deadline required by § 192.12(b)(2).

Section 192.12(c) requires in part that “Each operator of a UNGSF must prepare and follow for each facility one or more manuals of written procedures for conducting operations, maintenance, and emergency preparedness and response activities under paragraphs (a) and (b) of this section.”

During the inspection, Spire’s O&M Manual, MOC, ERP and BCP were reviewed. PHMSA determined that these manuals were not implemented until after March 2020.


Therefore, Spire failed to prepare an O&M, MOC, ERP, and BCP Manual by January 18, 2018 as required by § 192.12(b)(2).

Under 49 U.S.C. § 60122 and 49 CFR § 190.223, you are subject to a civil penalty not to exceed \$225,134 per violation per day the violation persists, up to a maximum of \$2,251,334 for a related series of violations. For violation occurring on or after January 11, 2021 and before May 3, 2021, the maximum penalty may not exceed \$222,504 per violation per day the violation persists, up to a maximum of \$2,225,034 for a related series of violations. For violation occurring on or after July 31, 2019 and before January 11, 2021, the maximum penalty may not exceed \$218,647 per violation per day the violation persists, up to a maximum of \$2,186,465 for a related series of violations. For violation occurring on or after November 27, 2018 and before July 31, 2019, the maximum penalty may not exceed \$213,268 per violation per day, with a maximum penalty not to exceed \$2,132,679. For violation occurring on or after November 2, 2015 and before November 27, 2018, the maximum penalty may not exceed \$209,002 per violation per day, with a maximum penalty not to exceed \$2,090,022.

We have reviewed the circumstances and supporting documents involved in this case and have decided not to conduct additional enforcement action or penalty assessment proceedings at this time. We advise you to correct the item identified in this letter. Failure to do so will result in Spire Storage West LLC being subject to additional enforcement action.

No reply to this letter is required. If you choose to reply, in your correspondence please refer to **CPF 1-2022-010-WL**. Be advised that all material you submit in response to this enforcement action is subject to being made publicly available. If you believe that any portion of your responsive material qualifies for confidential treatment under 5 U.S.C. 552(b), along with the complete original document you must provide a second copy of the document with the portions you believe qualify for confidential treatment redacted and an explanation of why you believe the redacted information qualifies for confidential treatment under 5 U.S.C. 552(b).

Sincerely,



Robert Burrough  
Director, Eastern Region, Office of Pipeline Safety  
Pipeline and Hazardous Materials Safety Administration