



U.S. Department  
of Transportation

**Pipeline and Hazardous Materials  
Safety Administration**

901 Locust Street, Suite 462  
Kansas City, Missouri 64106-2641

**NOTICE OF PROBABLE VIOLATION  
and  
PROPOSED CIVIL PENALTY**

**CERTIFIED MAIL - RETURN RECEIPT REQUESTED**

October 16, 2018

Mr. Shawn Patterson  
Chief Operations Officer  
Southern Star Central Gas Pipeline, Inc.  
4700 State Route 56  
Owensboro, KY 42301

**CPF 3-2018-1002**

Dear Mr. Patterson:

On May 23-26, 2017, representatives of the Pipeline and Hazardous Materials Safety Administration (PHMSA), Office of Pipeline Safety (OPS), pursuant to Chapter 601 of 49 United States Code (U.S.C.), inspected your Southern Star Central Gas Pipeline, Inc. (SSCGP) near Tonganoxie, Kansas.

As a result of the inspection, it is alleged that you have committed a probable violation of the Pipeline Safety Regulations, Title 49, Code of Federal Regulations (CFR). The items inspected and the probable violation is:

**1. §192.201 Required capacity of pressure relieving and limiting stations.**

**(a) Each pressure relief station or pressure limiting station or group of those stations installed to protect a pipeline must have enough capacity, and must be set to operate, to insure the following:**

**(1) . . .**

**(2) In pipelines other than a low pressure distribution system:**

**(i) If the maximum allowable operating pressure is 60 p.s.i. (414 kPa) gage or more, the pressure may not exceed the maximum allowable operating pressure plus 10 percent, or the pressure that produces a hoop stress of 75 percent of SMYS, whichever is lower;**

SSCGP failed to have its pressure limiting device set to operate at a pressure that would not exceed the maximum allowable operating pressure plus 10 percent. During inspection of the Tonganoxie, Kansas compressor station, PHMSA inspected a relief valve intended to provide overpressure protection on the downstream pipeline. The relief valve had a pressure setting of 605 psig on a facility with a maximum allowable operating pressure (MAOP) of 500 psig. This pressure setting exceeded the MAOP by 21 percent which is above the 10 percent allowance of §192.201(a)(2)(i).

Proposed Civil Penalty

Under 49 U.S.C. § 60122 and 49 CFR § 190.223, you are subject to a civil penalty not to exceed \$209,002 per violation per day the violation persists, up to a maximum of \$2,090,022 for a related series of violations. For violations occurring prior to November 2, 2015, the maximum penalty may not exceed \$200,000 per violation per day, with a maximum penalty not to exceed \$2,000,000 for a related series of violations. The Compliance Officer has reviewed the circumstances and supporting documentation involved in the above probable violation(s) and has recommended that you be preliminarily assessed a civil penalty of \$29,300 as follows:

<u>Item number</u>	<u>PENALTY</u>
1	\$29,300

Response to this Notice


Enclosed as part of this Notice is a document entitled *Response Options for Pipeline Operators in Compliance Proceedings*. Please refer to this document and note the response options. All material submit in response to this enforcement action may be made publicly available. If you believe that any portion of your responsive material qualifies for confidential treatment under 5 U.S.C. 552(b), along with the complete original document you must provide a second copy of the document with the portions you believe qualify for confidential treatment redacted and an

explanation of why you believe the redacted information qualifies for confidential treatment under 5 U.S.C. 552(b).

Following the receipt of this Notice, you have 30 days to submit written comments, or request a hearing under 49 CFR § 190.211. If you do not respond within 30 days of receipt of this Notice, this constitutes a waiver of your right to contest the allegations in this Notice and authorizes the Associate Administrator for Pipeline Safety to find facts as alleged in this Notice without further notice to you and to issue a Final Order. If you are responding to this Notice, we propose that you submit your correspondence to my office within 30 days from the receipt of this Notice. This period may be extended by written request for good cause.

In your correspondence on this matter, please refer to **CPF 3-2018-1002** and, for each document you submit, please provide a copy in electronic format whenever possible.

Sincerely,

A handwritten signature in cursive script that reads "Allan C. Beshore".

Allan C. Beshore  
Director, Central Region, OPS  
Pipeline and Hazardous Materials Safety Administration

Enclosure: *Response Options for Pipeline Operators in Compliance Proceedings*