

VIA ELECTRONIC MAIL TO: JordanBurns@ferrellgas.com and rufusyoungblood@Ferrellgas.com

October 2, 2020

Jordan Burns
Vice President - Legal
Ferrellgas
One Liberty Plaza
Liberty, MO 64068

RE: CPF 3-2019-0001

Dear Mr. Burns:

On August 7-9, 2018, a representative of the Pipeline and Hazardous Materials Safety Administration (PHMSA), Office of Pipeline Safety (OPS), pursuant to Chapter 601 of 49 United States Code (U.S.C.) inspected your liquid propane gas distribution facilities in northern Wisconsin. As a result of the inspection, the Director, Central Region, OPS issued a Notice of Probable Violation, Proposed Civil Penalty and Proposed Compliance Order on April 29, 2019. On April 6, 2020, PHMSA issued a Final Order which made findings of violation, assessed a civil penalty and ordered Ferrellgas to take certain compliance measures.

The records show that Ferrellgas has paid the civil penalty, in addition to submitting records of determining the maximum allowable operating pressure of its systems and the relieving capacity of its relief devices or changing the overpressure protection to monitor regulators. My staff has reviewed these documents and determined that the terms of the Compliance Order have been met. The case is now closed. Thank you for your cooperation in this matter.

Sincerely,

Gregory A. Ochs
Director, Central Region, OPS
Pipeline and Hazardous Materials Safety Administration

cc. Rufus Youngblood, Director Safety, Ferrellgas, rufusyoungblood@Ferrellgas.com