



U.S. Department  
of Transportation  
**Pipeline and Hazardous  
Materials Safety  
Administration**

1200 New Jersey Avenue, SE  
Washington, DC 20590

February 24, 2021

**VIA ELECTRONIC MAIL TO: pdhodgins@paalp.com**

Mr. Patrick D. Hodgins  
Vice President, Health, Safety, & Environmental  
Plains Pipeline, LP  
333 Clay Street, Suite 1600  
Houston, Texas 77002

**Re: CPF No. 4-2020-5013**

Dear Mr. Hodgins:

Enclosed please find the Final Order issued in the above-referenced case to Plains Pipeline, LP. It makes one finding of violation and specifies actions that need to be taken to comply with the pipeline safety regulations. When the terms of the compliance order have been completed, as determined by the Director, Southwest Region, this enforcement action will be closed. Service of the Final Order by electronic mail is effective upon the date of mailing, as provided under 49 C.F.R. § 190.5.

Thank you for your cooperation in this matter.

Sincerely,

ALAN KRAMER  
MAYBERRY

Digitally signed by ALAN  
KRAMER MAYBERRY  
Date: 2021.02.23  
18:27:22 -05'00'

Alan K. Mayberry  
Associate Administrator  
for Pipeline Safety

Enclosures (Final Order and NOPV)

cc: Ms. Mary McDaniel, Director, Southwest Region, Office of Pipeline Safety, PHMSA  
Mr. Harry Pefanis, President, Plains All American Pipeline, LP, hnpefanis@paalp.com  
Mr. Kevin Cunningham, Director, Environmental and Regulatory Compliance, Plains  
Pipeline, LP, khcunningham@paalp.com

**CONFIRMATION OF RECEIPT REQUESTED**

**U.S. DEPARTMENT OF TRANSPORTATION  
PIPELINE AND HAZARDOUS MATERIALS SAFETY ADMINISTRATION  
OFFICE OF PIPELINE SAFETY  
WASHINGTON, D.C. 20590**

<b>In the Matter of</b>	)	)
<b>Plains Pipeline, LP,</b>	)	)
<b>a subsidiary of Plains All American Pipeline, LP,</b>	)	)
<b>Respondent.</b>	)	)

**CPF No. 4-2020-5013**

**FINAL ORDER**

On November 5, 2020, pursuant to 49 C.F.R. § 190.207, the Director, Southwest Region, Office of Pipeline Safety (OPS), issued a Notice of Probable Violation (Notice) to Plains Pipeline, LP (Plains or Respondent), a subsidiary of Plains All American Pipeline, LP. The Notice proposed finding that Respondent had violated one of the pipeline safety regulations in 49 C.F.R. Part 195. The Notice also proposed certain measures to correct the violations. Respondent did not contest the allegations of violation or the corrective measures.

Based upon a review of all of the evidence, pursuant to § 190.213, I find that Respondent violated the pipeline safety regulation listed below, as more fully described in the enclosed Notice, which is incorporated by reference:

49 C.F.R. § 195.589(c) (**Item 1**) — Respondent failed to maintain records in sufficient detail to demonstrate either the adequacy of its corrosion control measures or that corrosion requiring control measures does not exist.

This finding of violation will be considered a prior offense in any subsequent enforcement action taken against Respondent.

**COMPLIANCE ORDER**

Pursuant to 49 U.S.C. § 60118(b) and 49 C.F.R. § 190.217, Respondent is ordered to take the actions proposed in the enclosed Notice to correct the violation. The Director may grant an extension of time to comply with any of the required items upon a written request timely submitted by the Respondent and demonstrating good cause for an extension. Upon completion of ordered actions, Respondent may request that the Director close the case. Failure to comply with this Order may result in the assessment of civil penalties under 49 C.F.R. § 190.223 or in referral to the Attorney General for appropriate relief in a district court of the United States.

**WARNING ITEMS**

With respect to Items 1 and 2, the Notice alleged probable violations of 49 C.F.R. §§ 195.402(a) and 195.430, respectively, but did not propose a civil penalty or compliance order for these items. Therefore, these are considered to be warning items. If OPS finds a violation of any of these items in a subsequent inspection, Respondent may be subject to future enforcement action.

The terms and conditions of this order are effective upon service in accordance with 49 C.F.R. § 190.5.

**ALAN KRAMER**  
**MAYBERRY**

Digitally signed by ALAN  
KRAMER MAYBERRY  
Date: 2021.02.23 18:28:36  
-05'00'

February 24, 2021

---

Alan K. Mayberry  
Associate Administrator  
for Pipeline Safety

---

Date Issued



U.S. Department  
of Transportation  
**Pipeline and Hazardous  
Materials Safety  
Administration**

8701 S. Gessner Rd, Suite 630  
Houston, Texas 77074

**NOTICE OF PROBABLE VIOLATION  
and  
PROPOSED COMPLIANCE ORDER**

**ELECTRONIC MAIL - RETURN RECEIPT REQUESTED**

November 5, 2020

Dean Gore  
Vice President Environmental & Regulatory Compliance  
Plains Pipeline, L.P.  
333 Clay Street, Suite 1600  
Houston, Texas 77002

**CPF 4-2020-5013**

Dear Mr. Gore:

From January 28, 2019 through November 13, 2019, a representative of the Pipeline and Hazardous Materials Safety Administration (PHMSA), Office of Pipeline Safety (OPS), pursuant to Chapter 601 of 49 United States Code (U.S.C.) inspected your Plains Pipeline, L.P. (Plains) procedures and facilities in Houston and Midland, Texas; Cushing, Oklahoma; parts of New Mexico, and Missouri.

As a result of the inspection, it is alleged that you have committed probable violations of the Pipeline Safety Regulations, Title 49, Code of Federal Regulations (CFR). The items inspected and the probable violations are:

- 1. §195.402 Procedural manual for operations, maintenance, and emergencies.**
  - (a) General. Each operator shall prepare and follow for each pipeline system a manual of written procedures for conducting normal operations and maintenance activities and handling abnormal operations and emergencies. This manual shall be reviewed at intervals not exceeding 15 months, but at least once each calendar year, and appropriate changes made as necessary to insure that the manual is effective. This manual shall be prepared before initial operations of a pipeline system commence, and appropriate parts shall be kept at locations where operations and maintenance activities are conducted.**

Plains Pipeline. L.P. (Plains) failed to follow its written procedure for inspecting mainline block valve transmitters. Section 1.3 of Plains' Overpressure Safety Devices procedure requires the devices to be tested at least once each calendar year, not to exceed 15 months. This procedure references and supports another Plains procedure titled Inspect Calibrate and Maintain Overpressure Safety Devices which provides the steps under Section 2.1.2 for the testing of pressure transmitters.

PHMSA inspectors reviewed of the inspection records, which showed that Plains failed to follow its written procedure in Section 1.3. Specifically, Plains failed to inspect 21 pressure transmitters on the Caddo pipeline system for the 2017 calendar year. The inspection records showed that both the upstream and downstream pressure transmitters for MOV 101, 102, 103, 104, 105, 109, 113, 118, 801,120 and the incoming pressure transmitter for MOV 880 were inspected in the 2016 calendar year, but were not re-inspected until the 2018 calendar year. Therefore, Plains failed to follow its written procedure to inspect mainline block valve transmitters at least once each calendar year, not to exceed 15 months.

## **2. §195.430 Firefighting equipment**

**Each operator shall maintain adequate firefighting equipment at each pump station and breakout tank area. The equipment must be-**

- (a) In proper operating condition at all times;**
- (c) Located so that it is easily accessible during a fire.**

Plains failed to have a firefighting equipment located at the Stockholm station and breakout tank facility so that it would be easily accessible during a fire. During the field inspection of the Stockholm station and breakout tank facility, the PHMSA inspector did not observe firefighting equipment that was located and easily accessible within the premises. Section 1 of Plains' Firefighting Equipment Procedure (Revision 2; January 2019) requires the use of fire extinguishers for firefighting in the incipient fire stages. Also, Section 2.2 of the same procedure requires that the firefighting equipment be marked and located so that it can be easily accessible during a fire.

Upon PHMSA' departure from the site, Plains personnel called to state they had located the fire extinguisher somewhere inside the building that had been searched while PHMSA was on site. Plains also stated that it maintains fire extinguishers in all personnel vehicles as required by their procedure. However, §195.430 is specific to having the firefighting equipment located at the site location of a pump station or breakout tank facility. Therefore, the location of the firefighting equipment was not accessible at the Stockholm station and breakout tank facility at the time of PHMSA's inspection.

**3. §195.589 What corrosion control information do I have to maintain**

**(a) You must maintain current records or maps to show the location of—**

**(1) Cathodically protected pipelines;**

**(2) Cathodic protection facilities, including galvanic anodes, installed after January 28, 2002; and**

**(3) Neighboring structures bonded to cathodic protection systems.**

**(c) You must maintain a record of each analysis, check, demonstration, examination, inspection, investigation, review, survey, and test required by this subpart in sufficient detail to demonstrate the adequacy of corrosion control measures or that corrosion requiring control measures does not exist. You must retain these records for at least 5 years, except that records related to Secs. 195.569, 195.573(a) and (b), and 195.579(b)(3) and (c) must be retained for as long as the pipeline remains in service.**

Plains failed to maintain records in sufficient detail to demonstrate the adequacy of its corrosion control measures or that corrosion requiring control measures does not exist on the Hagerman to Lynch 16” pipeline. First, Plains’ ‘Data Gathering for Reactivating or Operational Changes on PAALP Pipelines’ document from June 2018 indicated that 52 pipeline exposures were identified from a close interval survey carried out in 2013. However, Plains was unable to provide any records to demonstrate that there is no corrosion requiring control measures or that the 52 exposure conditions had been remediated.

Second, Plains failed to maintain records of annual inspections carried out on the cathodic protection system on Tank 201. During the field inspection, it was determined there was cathodic protection on the tank bottom, but no pipe to soil survey records were provided for the cathodic protection monitoring. Plains was unable to provide any records demonstrating that cathodic protection inspections had been conducted on Tank 201 for the period from 2012 through November 2019. Therefore, Plains failed to maintain records in sufficient details to demonstrate the adequacy of corrosion control measures or that corrosion requiring control measures does not exist as required by §195.589(c).

**Warning Items**

With respect to items 1 and 2 we have reviewed the circumstances and supporting documents involved in this case and have decided not to conduct additional enforcement action or penalty assessment proceedings at this time. We advise you to promptly correct these items. Failure to do so may result in additional enforcement action.

### Proposed Compliance Order

With respect to items 3 pursuant to 49 U.S.C. § 60118, the Pipeline and Hazardous Materials Safety Administration proposes to issue a Compliance Order to Plains Pipeline L.P. Please refer to the *Proposed Compliance Order*, which is enclosed and made a part of this Notice.

### Response to this Notice

Enclosed as part of this Notice is a document entitled *Response Options for Pipeline Operators in Enforcement Proceedings*. Please refer to this document and note the response options. All material you submit in response to this enforcement action may be made publicly available. If you believe that any portion of your responsive material qualifies for confidential treatment under 5 U.S.C. 552(b), along with the complete original document you must provide a second copy of the document with the portions you believe qualify for confidential treatment redacted and an explanation of why you believe the redacted information qualifies for confidential treatment under 5 U.S.C. 552(b).

Following the receipt of this Notice, you have 30 days to submit written comments, or request a hearing under 49 CFR § 190.211. If you do not respond within 30 days of receipt of this Notice, this constitutes a waiver of your right to contest the allegations in this Notice and authorizes the Associate Administrator for Pipeline Safety to find facts as alleged in this Notice without further notice to you and to issue a Final Order. If you are responding to this Notice, we propose that you submit your correspondence to my office within 30 days from receipt of this Notice. This period may be extended by written request for good cause.

In your correspondence on this matter, please refer to **CPF 4-2020-5013** and, for each document you submit, please provide a copy in electronic format whenever possible.

Sincerely,

MARY LOUISE  
MCDANIEL

 Digitally signed by MARY LOUISE  
MCDANIEL  
Date: 2020.09.24 06:42:11 -05'00'

Mary L. McDaniel, P.E.  
Director, Southwest Region  
Pipeline and Hazardous Materials Safety Administration

Enclosures: *Proposed Compliance Order*  
*Response Options for Pipeline Operators in Enforcement Proceedings*

## PROPOSED COMPLIANCE ORDER

Pursuant to 49 United States Code § 60118, the Pipeline and Hazardous Materials Safety Administration (PHMSA) proposes to issue to Plains Pipeline, L.P. (Plains) a Compliance Order incorporating the following remedial requirements to ensure the compliance of Plains Pipeline with the pipeline safety regulations:

- A. In regard to Item number 3 of the Notice pertaining to 52 exposed portions on the Hagerman to Lynch 16" line identified during a close interval survey conducted in 2013, Plains must review these conditions to ensure that no corrosion requiring control measures exist and where conditions requiring control measures exist, must submit a remedial plan within **30** days of receipt of the Final Order.
- B. In regard to Item number 3 also of the Notice pertaining to failure to provide cathodic protection monitoring records for breakout tank 201, Plains must provide records of cathodic protection monitoring for 2019 and 2020 within **30** days of receipt of the Final Order.
- C. It is requested (not mandated) that Plains maintain documentation of the safety improvement costs associated with fulfilling this Compliance Order and submit the total to Mary L. McDaniel, Director, Southwest Region, Pipeline and Hazardous Materials Safety Administration. It is requested that these costs be reported in two categories: 1) total cost associated with preparation/revision of plans, procedures, studies and analyses, and 2) total cost associated with replacements, additions and other changes to pipeline infrastructure.