



SENT TO COMPLIANCE REGISTRY
 Hardcopy Electronically
 # of Copies 1 / Date 5/28/08

May 16, 2008
 Chris Hoidal
 Director, Western Region
 Pipeline and Hazardous Material Safety Administration
 12300 W. Dakota Ave, Suite 110
 Lakewood, CO 80228

Re: Notice of Amendment
 CPF 5-2008-3011M

Dear Mr. Hoidal,

This letter is written in response to the Notice of Amendment issued for the Fairbanks Natural Gas, LLC (FNG) LNG Storage Sites and facilities in Fairbanks, Alaska. These written responses are to lay out how FNG will make appropriate changes to its written procedures to come into compliance with PHMSA's notice's.

Item #1

FNG will amend its SOPs to state that the Storage Site Facilities will have security lighting connected to an alternate power source. Measures are also being taken at this time to implement this change through electrical upgrades if required to insure the alternate power supply to the security lighting to Storage Site #1.

The revised SOPs will be sent to PHMSA when completed to demonstrate that the notice of amendments have been addressed. If there is anything further that PHMSA would like of FNG on these issues, please feel free to contact me.

Thank you for your time and effort.

Sincerely,

 5-24-08
Matthew J Nardini, PE

Operations Engineer
 Fairbanks Natural Gas
 907-357-7111 office
 815-642-0719 fax