



# BEAR PAW ENERGY, LLC

A SUBSIDIARY OF ONEOK PARTNERS, L.P.

September 23, 2009

VIA FEDERAL EXPRESS

Mr. Chris Hoidal  
Director, Western Region  
Pipeline and Hazardous Materials Safety Administration  
U.S. Department of Transportation  
12300 W. Dakota Ave., Suite 110  
Lakewood, CO 80228

Re: CPF 5-2009-5025


Dear Mr. Hoidal:

On September 16, 2009, Mike Petronis advised Bear Paw Energy, LLC ("BPE") that the six-minute averages BPE had been recording for the Riverview Pipeline pressures in its DCS system were not adequate to assure proper monitoring of the pipeline pressures. To address this matter, one of BPE's technicians programmed into the system a five-second interval so that the system is now recording pressure readings every five seconds. This allows us to monitor and record the pressure every five seconds (or 12 times per minute) and still print out a hard-copy chart of six-minute averages for our files each month. We believe this adjustment will allow for adequate monitoring of the pipeline pressures to assure the safety and integrity of the Riverview Pipeline.

Please feel free to contact me at (918) 588-7414 if you wish to discuss this matter further.

Sincerely,

BEAR PAW ENERGY, LLC

By:   
Craig A. Forsander  
Vice President  
Natural Gas Gathering & Processing Operations

CAF:jr