

December 5, 2023

Mr. Robert Burrough
Director, Eastern Region
Office of Pipeline Safety
Pipeline and Hazardous Materials Safety Administration
840 Bear Tavern Road, Suite 300
West Trenton, NJ 08628

RE: CPF 1-2023-060-NOA – NOTICE OF AMENDMENT – TC ENERGY RESPONSE

Mr. Burrough,

On November 9, 2023 TC Energy, on behalf of its subsidiary, North Baja Pipeline, LLC, received CPF 1-2023-060-NOA – Notice of Amendment (Notice). TC Energy has reviewed the Notice and is providing the following response:

The TC Energy Engineering Standard titled: TEN-PE-FCSTD-G Compressor Station Facility Design (US) was revised to include the following requirement:


“4.8.6 ESD System must be operable from at least two locations, each of which is:

- (i) Outside the gas area of the station;
- (ii) Near the exit gates, if the station is fenced, or near emergency exits, if not fenced;
- and,
- (iii) Not more than 500 feet (153 meters) from the limits of the station”

This standard was published in the TC Energy Controlled Document Library on December 1, 2023, and available all TC Energy employees. By taking these actions, TC Energy contends the requirements of the Notice have been satisfied and requests closure of this Notice.

Should you wish to discuss, please contact me at (832) 320-5031.

Respectfully,

A handwritten signature in black ink that reads "Amy Willis".

Amy Willis
Director, US Regulatory Compliance US Natural Gas

Attachment: TEN-PE-FCSTD-G Compressor Station Facility Design (US)