



09/04/2024

Via Overnight Delivery:

Robert Burrough, Director
PHMSA Eastern Region
840 Bear Tavern Road, Suite 300
West Trenton, NJ 08628

Via Email:

robert.burrough@dot.gov

**Re: Notice of Amendment
CPF 1-2024-050-NOA**

Mr. Burrough:

We have received and reviewed the Notice of Amendment dated August 12, 2022 regarding findings at the time of inspection during inspections taking place from October 3, 2023 to October 5, 2023, and October 31, 2023 to November 2, 2023. Our responses are provided below:

1. 192.605 Procedural manual for operations, maintenance, emergencies failed to include adequate details related to 191.15(d) requiring preparation and filing of supplemental incident reports if additional related information is obtained after a Form PHMSA F 7100.2 is submitted, as prescribed in 192.15(d).

Please find enclosed RH energytrans, LLC's revised and re-issued procedure 15-2 addressing preparation and filing of supplemental incident reports if additional related information is obtained after a Form PHMSA F 7100.2 is submitted.

2. 192.605 Procedural manual for operations, maintenance, emergencies failed to include adequate details related to 192.745(b) requiring taking remedial action promptly to correct any valve found inoperable, or promptly designating an alternative valve, as prescribed in 192.745(b).

Please find enclosed RH energytrans, LLC's revised and re-issued procedure 745-2 addressing remedial action promptly to correct any valve found inoperable, or promptly designating an alternative valve.

3. 192.605 Procedural manual for operations, maintenance, emergencies failed to include adequate details related to 192.605(c)(3) requiring notification to responsible operator personnel when notice of an abnormal operation was received, as prescribed in 192.605(c)(3).

Please find enclosed RH energytrans, LLC's revised and re-issued procedure 605-2 addressing notification to responsible operator personnel when notice of an abnormal operation was received.

If you require any further information, please do not hesitate to reach out to me.

Regards,

RH energytrans LLC



By

Kyle Rhoades

Enclosures:

RH procedures-

15-2

745-2

605-2