

NOTICE OF AMENDMENT

CERTIFIED MAIL - RETURN RECEIPT REQUESTED

January 13, 2011

Mr. Joseph Thorndyke
Station Manager
Santee Cooper - Rainey Generating Station
P.O. Box 70
2900 Opry House Road
Iva, SC 29655

CPF 2-2011-1002M

Dear Mr. Thorndyke:

On October 20-21, 2010, representatives of the Pipeline and Hazardous Materials Safety Administration (PHMSA) inspected the Santee Cooper - Rainey (SCR) Generating Station procedures for Operations and Maintenance (O&M) in Iva, South Carolina, pursuant to Chapter 601 of 49 United States Code.

On the basis of the inspection, PHMSA has identified the apparent inadequacy found within SCR's procedures, as described below:

§192.605 Procedural manual for operations, maintenance, and emergencies.

.... (b) Maintenance and normal operations. The manual required by paragraph (a) of this section must include procedures for the following, if applicable, to provide safety during maintenance and operations.

.... (9) Taking adequate precautions in excavated trenches to protect personnel from the hazards of unsafe accumulations of vapor or gas, and making available when needed at the excavation, emergency rescue equipment, including a breathing apparatus and, a rescue harness and line.

Santee Cooper's O&M procedures were inadequate because they did not include taking adequate precautions in excavated trenches to protect personnel from the hazards of unsafe accumulations of vapor or gas, and making available when needed at the excavation, emergency rescue equipment, including a breathing apparatus and, a rescue harness and line.

At the time of the inspection, SCR personnel explained that this requirement was addressed in the company's APPA Safety Manual, Section 907 and Confine Space Entry Manual. However, these manuals were not referenced in the O&M manual.

Response to this Notice

This Notice is provided pursuant to 49 U.S.C. § 60108(a) and 49 C.F.R. § 190.237. Enclosed as part of this Notice is a document entitled *Response Options for Pipeline Operators in Compliance Proceedings*. Please refer to this document and note the response options. Be advised that all material you submit in response to this enforcement action is subject to being made publicly available. If you believe that any portion of your responsive material qualifies for confidential treatment under 5 U.S.C. 552(b), along with the complete original document you must provide a second copy of the document with the portions you believe qualify for confidential treatment redacted and an explanation of why you believe the redacted information qualifies for confidential treatment under 5 U.S.C. 552(b). If you do not respond within 30 days of receipt of this Notice, this constitutes a waiver of your right to contest the allegations in this Notice and authorizes the Associate Administrator for Pipeline Safety to find facts as alleged in this Notice without further notice to you and to issue a Final Order.

If, after opportunity for a hearing, your plans or procedures are found inadequate as alleged in this Notice, you may be ordered to amend your plans or procedures to correct the inadequacies (49 C.F.R. § 190.237). If you are not contesting this Notice, we propose that you submit your amended procedures to my office within 45 days of receipt of this Notice. This period may be extended by written request for good cause. Once the inadequacies identified herein have been addressed in your amended procedures, this enforcement action will be closed.

In correspondence concerning this matter, please refer to **CPF 2-2011-1002M** and, for each document you submit, please provide a copy in electronic format whenever possible.

Sincerely,

Wayne T. Lemoi
Director, Office of Pipeline Safety
PHMSA Southern Region

Enclosure: *Response Options for Pipeline Operators in Compliance Proceedings*