



**NIST Interagency Report
NIST IR 8535**

Mechanical Metallurgy on Columbia Gas X100 Experimental Pipe

Timothy "Dash" Weeks
Ryan M. White
Jake T. Benzing
Enrico Lucon
Nicholas Derimow
Ashley Kroon
Robert Smith

This publication is available free of charge from:
<https://doi.org/10.6028/NIST.IR.8535>

**NIST Interagency Report
NIST IR 8535**

Mechanical Metallurgy on Columbia Gas X100 Experimental Pipe

Ashley Kroon
Robert Smith*

*Pipeline and Hazardous Materials Safety
Administration
United States Department of Transportation*

** No longer with DOT/PHMSA*

Timothy “Dash” Weeks

Ryan M. White

Jake T. Benzing

Enrico Lucon

Nicholas Derimow

*Applied Chemicals and Materials Division
Material Measurement Laboratory
National Institute of Standards and
Technology*

This publication is available free of charge from:
<https://doi.org/10.6028/NIST.IR.8535>

August 2024



U.S. Department of Commerce
Gina M. Raimondo, Secretary

National Institute of Standards and Technology
Laurie E. Locascio, NIST Director and Under Secretary of Commerce for Standards and Technology

Certain equipment, instruments, software, or materials, commercial or non-commercial, are identified in this paper to specify the experimental procedure adequately. Such identification does not imply recommendation or endorsement of any product or service by NIST, nor does it imply that the materials or equipment identified are necessarily the best available for the purpose.

NIST Technical Series Policies

[Copyright, Use, and Licensing Statements](#)

[NIST Technical Series Publication Identifier Syntax](#)

Publication History

Approved by the NIST Editorial Review Board on 2024-08-22

How to Cite this NIST Technical Series Publication

Weeks T, White RM, Benzing JT, Lucon E, Derimow N, Kroon A, Smith R (2024) Mechanical Metallurgy on Columbia Gas X100 Experimental Pipe. (National Institute of Standards and Technology, Gaithersburg, MD), NIST Interagency Report (IR) NIST IR 8535. <https://doi.org/10.6028/NIST.IR.8535>

Author ORCID IDs

Timothy “Dash” Weeks: 0000-0001-8553-2505

Ryan M. White: 0000-0001-9023-4713

Jake T. Benzing: 0000-0002-7266-870X

Enrico Lucon: 0000-0002-3021-4785

Nicholas Derimow: 0000-0001-7526-1836

Contact Information

timothy.weeks@nist.gov

ryan.white@nist.gov

jake.benzing@nist.gov

enrico.lucon@nist.gov

nicholas.derimow@nist.gov

Abstract

This study evaluates the material properties of an X100 pipeline steel extracted from an experimental transmission pipeline section placed into service in the 1960s. The purpose is to compare these properties with current X100 steel standards. Comprehensive chemical characterization, microstructure analysis, and a series of mechanical tests—including tensile, Charpy impact, and indentation tests—were conducted to assess the long-term stability and reliability of these early high-strength steels. The analysis involved seven different welded sections of the pipeline to account for potential variations within the material and welding procedures.

The findings indicate significant differences in chemical composition across the various pipe sections, suggesting that these sections may represent different experimental materials. The base metal predominantly exhibited a bainite-ferrite microstructure, with noticeable variations near the pipe surfaces. Unannealed girth welds demonstrated higher toughness and increased hardness in their heat-affected zones compared to seam welds. While most sections of the vintage X100 steel met the modern tensile property requirements, several sections did not meet the impact toughness criteria.

In conclusion, the experimental X100 steel aligns with current tensile property requirements, however the steel fails to meet current toughness related requirements. The observed differences in testing methods between current standards and those published in the 1960s were minor, and therefore not a convincing source for observed property differences considering all sources of uncertainty. The absence of original pre-service mechanical testing data prevents conclusions about time-dependent property changes.

Keywords

Pipeline steels; X100 pipe; Welding; Metallurgy; Mechanical engineering.

Executive Summary

This report provides a comprehensive analysis of the vintage Columbia Gas X100 pipeline steel that was pulled from service. The analysis includes chemical composition, microstructure, and mechanical properties. The physical metallurgical analysis was conducted using various techniques such as optical emission spectroscopy, optical microscopy, scanning electron microscopy (SEM), and electron backscatter diffraction (EBSD), whereas the mechanical metallurgical analysis was conducted using notched impact testing (Charpy V-Notch, CVN) and tensile testing.

The primary objectives of this study were to determine if age dependent property changes could be determined. Another key objective was to determine if the extracted line pipe would meet current standards. The report is divided into several key sections, each focusing on different aspects of the analysis.

Chemical Analysis: The results indicated inconsistencies in chemical composition across the seven pipe sections, suggesting that each section might be a different experimental material. Despite these inconsistencies, the pipe sections displayed a bainite-ferrite microstructure typical of X100 pipeline steel.

Microstructure Analysis: The microstructures of the base metal, heat-affected zones (HAZ), and welds were examined using optical and SEM imaging, as well as EBSD. The analysis revealed significant variations in grain size and misorientation within the HAZ. The findings showed that the welds and HAZ contained a mix of martensite, ferrite, and bainite, consistent with previous studies on X100 pipeline steel.

Tensile Testing: Tensile tests were performed on full-thickness flattened strap specimens from the pipe body and seam welds. The results showed that most pipe sections met the current API 5L X100Q requirements, with few exceptions that are mostly due to small sampling sizes. Differences in testing methods between the time of production and the present day were noted, particularly regarding the accuracy of measurement instruments and data acquisition systems.

Instrumented Charpy Testing: Charpy impact tests were conducted on third-size specimens from the base metals, weld metals, and HAZ. The results indicated that the base metals in the longitudinal orientation exhibited high upper shelf energies (USE) and low ductile-to-brittle transition temperatures (DBTT). However, most specimens tested in the transverse orientation did not meet the API 5L requirements. The seam weld metals and HAZ also showed varying degrees of toughness, with only a few specimens meeting the required standards.

Indentation Testing: Vickers and Knoop hardness tests were performed on the base metals, seam welds, and girth welds. The hardness profiles showed an increase in hardness in the HAZ adjacent to the weld cap, while the base metal and weld metal had similar hardness levels. Nano-indentation tests revealed a minor decrease in hardness near the internal pipe surface but no significant change in elastic modulus.

Discussion and Comparison: The report discusses the implications of the findings, highlighting

the challenges in comparing vintage and modern pipeline steel due to differences in testing methods and standards. The vintage X100 steel line pipe was found to be comparable to modern X100 steel in terms of tensile properties and performance. However, the variations in chemical composition and microstructure as well as low and varying toughness results underscore the need for careful evaluation of vintage pipeline materials.

In summary, this report provides valuable insights into the properties and performance of a Columbia Gas X100 pipeline steel, offering a foundation for future research and assessment of similar materials in the pipeline industry. This report further underscores the importance of having access to complete material data at the time of manufacture to accurately detect age dependent property change, especially relevant to degradation, resulting in increased risk and decreased system reliability.

This report is the final deliverable to meet the requirements of the interagency agreement (IAA) between NIST and the U.S. Department of Transportation – Pipeline and Hazardous Materials Safety Administration (DOT/PHMSA). The IAA was funded under DOT contract 693JK319N000013-001, more details about this research project can be found on the DOT/PHMSA website under project number 863.

<https://primis.phmsa.dot.gov/matrix/PrjHome.rdm?prj=863>

Acknowledgements

The authors are grateful for the timely and sacrificial contributions to this project by the technical advisory panel. The advisory panel included Jaclyn Brown (TC Energy), Robert Cryderman (Colorado School of Mines), Carolin Fink (The Ohio State University), James Gianetto (CanmetMATERIALS), Kenneth Lee (DNV-GL), Brian Leis (B N Leis, Consultant, Inc.), and Matthew Merwin (US Steel).

The authors are additionally grateful to Kenneth Lee (DNV-GL, formerly DOT/PHMSA) for providing the pipe materials and to Robert Smith (DOT/PHMSA) for his guidance and encouragement during the project, and especially for navigating the IAA with NIST through a pandemic.

The project would not have been possible without the outstanding and extensive contributions from Ross Rentz (NIST), whose efforts spanned logistics, safety, and test support.

Table of Contents

1. Introduction.....	1
1.1. Motivation.....	1
1.2. Background	2
1.3. Historical Pipe and Data	3
1.4. Project Output.....	7
2. Materials and Methods	8
2.1. As-Received Materials.....	8
2.2. Design of Experiments	12
2.2.1. Chemical Characterization of Base Metal	12
2.2.2. Characterization of Microstructure and Chemistry of Vintage and Modern X100 Pipe	13
2.2.3. Instrumented Charpy Testing and Hardness Mapping of Vintage and Modern X100 Pipe	13
2.2.4. Tensile Testing of Vintage and Modern X100 Pipe	17
2.2.5. Multiscale Indentation Mechanics of Vintage and Modern X100 Pipe.....	20
2.3. Metallography.....	21
2.3.1. Metallographic Preparation	21
2.3.2. Optical Microscopy.....	22
2.3.3. Scanning Electron microscopy.....	23
2.4. Tensile Testing.....	23
2.4.1. Specimen Geometry and Measurements.....	24
2.4.2. Flattening Procedure	25
2.4.3. Specimen Preparation	26
2.4.4. Tensile Testing Procedure	28
2.4.5. Tensile Analysis Procedure	29
2.5. Instrumented Charpy Testing	31
2.6. Indentation Testing	34
2.6.1. Microhardness Indentation.....	34
2.6.2. Nano-indentation	35
2.7. Results.....	35
2.7.1. Material Chemistry	35
2.8. Microstructure Analysis	36
2.8.1. Optical microscopy and BSE imaging.....	36
2.8.2. Electron backscatter diffraction	40
2.9. Tensile Testing.....	47
2.10. Instrumented Charpy Testing	49

2.10.1. Absorbed energy transition curves for base metals - Longitudinal Direction..... 49

2.10.2. Charpy test results at 0 °C for base metals in T direction 54

2.10.3. Charpy test results at 0 °C on seam weld metals and heat affected zones 57

2.11. Charpy test results at 0 °C on girth weld metals and heat affected zones 58

2.12. Indentation Testing 59

3. Discussion and Comparison65

3.1. Chemical Analysis and Pipe Identification 65

3.2. Microstructure Analysis 65

3.3. Tensile Testing..... 67

3.4. Instrumented Charpy Testing 69

3.4.1. Base metals, orientation L (transition curves) 69

3.4.2. Base metals, orientation T (0 °C) 70

3.4.3. Seam weld metals and HAZ (0 °C) 70

3.4.4. Girth weld metals and HAZ (0 °C)..... 71

3.5. Indentation Testing 71

3.5.1. Base Metal 71

3.5.1.1. Seam Welds and Girth Welds 72

4. Conclusions73

References.....75

Appendix A. Historical Pipeline Documents.....80

Appendix B. Pipe Section Details142

Appendix C. Mechanical Test Specimen Cut Plans146

Appendix D. Metallurgy Specimen Locations166

List of Tables

Table 1. As-Received Pipe Section Dimensions and Construction Detail9

Table 2 - Specimen sectioning summary.11

Table 3 - Test matrix for microstructure and chemical analysis – Specimen micrographs are found in Appendix D.....12

Table 4 – Test Matrix for Charpy V-Notch Testing.....16

Table 5 – Test Matrix for Tensile Testing.....19

Table 6 - Test matrix micro-hardness mapping of welds.21

Table 7 - Tensile property requirements for X100M or X100Q – excerpt from API 5L.....31

Table 8 - Chemical composition of vintage X100 pipeline steels from optical emission spectroscopy. .36

Table 9 - Tensile testing results required by API 5L.....48

Table 10 - Third-size Charpy test results on P1S1 (pipe 1, section 1) base metal orientation L.....49

Table 11 - Third-size Charpy test results on P1S2 (pipe 1, section 2) base metal orientation L.....50

Table 12 - Third-size Charpy test results on P2S1 (pipe 2, section 1) base metal orientation L.....50

Table 13 - Third-size Charpy test results on P2S2 (pipe 2, section 2) base metal orientation L.....50

Table 14 - Third-size Charpy test results on P3S1 (pipe 3, section 1) base metal orientation L.....51

Table 15 - Third-size Charpy test results on P3S2 (pipe 3, section 2) base metal orientation L.....51

Table 16 - Third-size Charpy test results on P3S3 (pipe 3, section 3) base metal orientation L.....52

Table 17 - Ductile-to-brittle transition temperatures and upper shelf energies for base metals in L orientation, with estimated standard errors. For *DBTT*, standard error was estimated using the NIST statistical online tool “Transition Curve Fitting Tool” [X]; for *USE*, standard error was calculated based on the standard deviation of the absorbed energy values corresponding to the upper shelf of the curve.52

Table 18 - Results of 0 °C third-size Charpy tests on base metals in T orientation. Values subject to API 5L requirements are shown in bold. Acceptable values are highlighted in green, non-acceptable values in red.....56

Table 19 – Results of third-size Charpy tests at 0 °C on seam welds and HAZ. Acceptable values according to API 5L are highlighted in green, nonacceptable values in red.58

Table 20 - Results of third-size Charpy tests at 0 °C on girth welds and HAZ.59

List of Figures

Figure 1 - Knoop indentation trace across a girth weld, from R. S. Ryan (1965).....4

Figure 2 - Charpy test data (absorbed energy on the left and shear fracture on the right) reported by R. S. Ryan (1965).....5

Figure 3 - Isometric view of each modelled pipe section.....9

Figure 4 - Example of a specimen sectioning plan sent to the waterjet vendor. This plan is for section P1S1, all dimensions are in inches, more detail may be found in Appendix C. Specimen blanks shown are used for CVN, tensile, SE(B) and SE(T) tests. Samplings for microstructure, chemistry and micro-hardness maps are taken from remaining sprue material.....10

Figure 5 – Third-size Charpy specimens used in this investigation.....14

Figure 6 - Schematic illustration of the required specimen orientation and circumferential location of tensile test specimens according to API 5L.....20

Figure 7 - Nominal shape and dimensions of full-wall-thickness tensile specimens. All dimensions are in inches.....24

Figure 8 - Flattening fixture used for transverse tensile specimens. Four-point bend arrangement with a lower span of 4 in and upper span of 2 in.....25

Figure 9 - Post-test photo of a tensile specimen.....27

Figure 10 - Full wall thickness tensile specimens were tested in a servo-hydraulic universal test frame and were gripped in hydraulic grips (left). A close-up view of the gage section of the specimen on the ID side shows how the extensometer is attached to the specimen prior to testing (right).....27

Figure 11 - Stress-strain curve of specimen P4 (from P3S2), illustrating the Slack Plot used in the data analysis spreadsheet. The slack compensation for this specimen was minimal, resulting in a uniform elongation difference of 0.003 %.30

Figure 12 - Example of instrumented force/deflection curve for a test in the ductile-to-brittle transition region.....32

Figure 13 - Example of absorbed energy transition curve for a low-strength steel.....34

Figure 14 – Scanning electron microscope backscatter images (EM3 RTT, EM3 ATT, EM3 PV) and optical bright field images (AM1 RTT, AM1 ATT, AM1 PV) demonstrating the typical microstructure of the pipeline base metal.....38

Figure 15 – Scanning electron microscope backscatter images illustrating the typical microstructure across the regions of a girth weld (EM1 ATT Weld P1G1).....39

Figure 16 – Optical image of seam weld illustrating the consistent grain size between the weld metal, heat affected zone, and base metal (AM2 ATT).....40

Figure 17 - Schematic of the three orthogonal views (PV, RTT, and ATT) characterized with scanning electron microscopy.....41

Figure 18 - a) An optical image of a girth weld, HAZ, and base metal from location KM2, depicted by an axial view through the thickness (ATT) where a white rectangle indicates the location of a multi-tile large-area EBSD map. The b) kernel average misorientation c) grain reference orientation deviation, and d) inverse pole figure maps generated with EBSD while indexing body-centered cubic alpha-Fe are shown above. A child-to-parent reconstruction was performed and a plot of the e) inverse pole figure map of the face-centered-cubic gamma-Fe phase is shown.42

Figure 19 - a) An optical image of a girth weld, HAZ, and base metal from location KM2, depicted by a plan view of the surface (PV) where a white rectangle indicates the location of a multi-tile large-area EBSD map. The b) kernel average misorientation c) grain reference orientation deviation, and d) inverse pole figure maps generated with EBSD while indexing body-centered cubic alpha-Fe are shown above. A child-to-parent reconstruction was performed and a plot of the e) inverse pole figure map of the face-centered-cubic gamma-Fe phase is shown.....42

Figure 20 - a) An optical image of a girth weld, HAZ, and base metal from location EM1, depicted by an axial view through the thickness (ATT) where a white rectangle indicates the location of a multi-tile large-area EBSD map. The b) kernel average misorientation c) grain reference orientation deviation, and d) inverse pole figure maps generated with EBSD while indexing body-centered cubic alpha-Fe are shown above. A child-to-parent reconstruction was performed and a plot of the e) inverse pole figure map of the face-centered-cubic gamma-Fe phase is shown.43

Figure 21 - a) An optical image of base metal from location EM3, depicted by an axial view through the thickness (ATT) where a white rectangle indicates the location of a multi-tile large-area EBSD map from the outer diameter to the interior of the pipe base metal. The b/c/d) child alpha-Fe phase, present at room temperature, and e/f/g) parent gamma-Fe phases are shown side-by-side. Specifically, the b/e) inverse pole figure maps, c/f) grain reference orientation deviation maps, and d/g) grain size diameter maps are provided to show specific changes in microstructure from left (pipe outer diameter) to right (interior of the base metal).44

Figure 22 - Single-tile small-area EBSD maps were recorded from all three orthogonal views (ATT, RTT, and PV_outer diameter) of the base metal at location EM3. The a) inverse pole figure maps, b) grain orientation spread, and c) misorientation histograms provide quantitative differences between the microstructure at the surface of the pipe (PV_outer diameter) and the interior microstructure.45

Figure 23 - Single-tile small-area EBSD maps were recorded from all three orthogonal views (ATT, RTT, and PV_outer diameter) of the base metal at location EM3. The a) grain size diameter maps and b) grain size diameter histograms provide quantitative differences between the microstructure at the surface of the pipe (PV_outer diameter) and the interior microstructure.....46

Figure 24 - Absorbed energy data points and transition curves obtained on the base metals of the different pipes and sections in L orientation.53

Figure 25 - Comparison between DBTT values calculated for the base metals of the different pipes and sections in L orientation. Note: the toughest conditions correspond to the tallest bars (P1S1 and P2S2).53

Figure 26 - Comparison between USE values calculated for the base metals of the different pipes and sections in L orientation.54

Figure 27 – Vickers indentation trace of various base metal specimens.....60

Figure 28 - Nano-indentation hardness and elastic modulus originating from the inner surface of the pipe (specimen XMX RTT).....61

Figure 29 - Nano-indentation hardness and elastic modulus tracing the inner surface of a pipe section (specimen XMX RTT).61

Figure 30 – Vickers indentation hardness map of girth weld (EM1 ATT)62

Figure 31 – Vickers indentation hardness map of girth weld (KM2 ATT)62

Figure 32 – Knoop hardness traces across girth weld (EM1 ATT)63

Figure 33 – Knoop hardness traces across seam weld (AM2 RTT)64

1. Introduction

1.1. Motivation

The US Department of Transportation (DOT), Pipeline and Hazardous Materials Safety Administration (PHMSA), in coordination with the Department of Commerce, National Institute of Standards and Technology (NIST), are congressionally mandated to carry out a program of research, development, demonstration, and standardization to ensure the integrity of pipeline facilities. This requirement was instituted via the Pipeline Safety Improvement Act of 2002 and subsequently amended by the Pipeline Safety, Regulatory Certainty and Job Creation Act of 2011; and 15 U.S.C. §§ 272(b)(5), (10), (11) and 272(c) authorizing NIST statutory authority to undertake these activities. These Acts highlight that NIST shall evince its expertise in materials research and assist in the development of consensus technical standards, as that term is used in section 12(d)(4) of Public Law 104–13 (15 U.S.C. 272 note) and provide an opportunity for PHMSA to seek material research expert services from NIST.

The research herein includes mechanical metallurgy on X100 pipeline steel extracted from an experimental transmission pipeline section placed into service by Columbia Gas in the early 1960s. DOT/PHMSA has expressed an interest in detailed studies on the mechanical properties of the pipe via microstructural analysis, tensile testing, Charpy testing, and hardness mapping. These studies have been conducted on both this pipe prior to use and on a more modern X100 (circa 2000s) and will therefore facilitate discussion about property changes due to time- and service-related degradation and property differences due to chemistry and microstructure. This work extends these studies with the addition of instrumented sub-size Charpy testing, and instrumented nano-indentation. The mechanical properties are correlated with microstructure and chemical information via analytical electron microscopy, thereby providing processing-structure-property-performance relations for the pipe provided and a more modern X100. NIST participated in and conducted research on a modern X100 pipeline steel and girth welds under DOT/PHMSA Research Project DTPH56-07-T-000005, Weld Design, Testing, and Assessment Procedures for High Strength Pipelines [33], Weld Design, Testing, and Assessment Procedures

for High Strength Pipelines [1]. In all studies, base metal, heat-affected zones (HAZs), and weld metals were examined.

1.2. Background

The American Petroleum Institute (API) Specification for Line Pipe (5L [6]) [2] is such that the label, X100, for example, refers to line pipe with 100,100 psi (690 MPa) minimum yield strength. The Columbia Gas System Service Corporation [3] demonstrated the feasibility of utilizing a higher strength X-series steel with minimal economic drawbacks. Such steel was suggested for implementation into onshore gas transmission pipelines [4]. A comprehensive review on the welding of oil and gas pipeline steels suggested a shift from line pipe grades X65, X70, and X80 to higher strength such higher strength grades such as X90, X100, and X120 [5]. These low alloy, carbon steels had previously exhibited fully ductile fracture behavior during full-scale burst tests at ambient temperature [6] [7].

API 5L [2] will be used here as the reference requirements for the pipe body properties. While some tests reported here include seam weld properties, there are no weld procedures (from the 1960's) or weld qualification requirements (from the 1960's) available to compare the provided X100 joints and seams. Moreover, 21st century weld procedures and qualification requirements are unlikely to be applicable to the vintage materials. Additional weld material has been retained for potential future work in this area of interest, but no previous weld data is available for a suitable time-history comparison. Charpy V-Notch (CVN) testing was performed on specimens notched to characterize base metal (BM), weld metal centerline (WMC) and heat affected zone (HAZ) material as part of the requirement for API 5L.

A European Commission report on the mechanical characteristics of API 5L - X100 quantified the mechanical properties and fracture resistance in both plate and pipe for evaluating the effects of pipe forming, as well as defect damage tolerance requirements, and correlated ductile-to-brittle transition temperatures to previously measured values [8]. It has been shown that there existed anisotropic behavior in X100 plates between the rolling and transverse directions [9], and was investigated by the Materials Reliability Division of NIST in 2008 [10]. Pre-strain from forming reduces ductility and crack growth resistance [11]. Environmental factors have also been investigated in X100 steels with respect to strain-aging [12], [13], [14], hydrogen embrittlement

[15], [16], [17], [18], carbonate corrosion [19], simulated bitumen [20], simulated soil [21], oilfield produced water and brines [20], H₂S [23], and NaCl with Mg and Ca [24]. The ductile fracture behavior of X100 has also been characterized in previous studies [25], [26].

The microstructure of X100 has been described as ferritic/bainitic, containing martensite-austenite (MA) [15], as well as acicular ferrite [27]. The effect of the crystallographic texture on the mechanical properties of X100 has also been investigated with respect to finish rolling temperature [28], [29]. The strengthening mechanisms have been attributed to solid solution strengthening, as well as grain boundary, dislocation, and precipitation strengthening [30]. The relationship between crystallographic texture (from rolling) and fracture behavior have also been studied via Charpy impact toughness on X100, where it was observed that controlled rolling processes can result in superior impact toughness when performed at lower temperatures [31].

A series of studies in 2011 reported on the development of optimized welding of X100 [32] and mechanical testing and assessment of X100 welds [1]. They were both prepared for the Design, materials, and Construction Technical Committee of Pipeline Research Council International (PRCI), and the United States Department of Transportation Pipeline and Hazardous Materials Safety Administration (PHMSA). Later studies investigated the on-scene weldability of X100 pipelines [33], microcracks of X100 weld joints heat affected zones (HAZs) [34], as well as structure-property-fracture mechanisms [35]. The morphology of the bainite in the nugget zone in X100 welds was found to be affected by the stirring tool material during friction stir welding [36].

1.3. Historical Pipe and Data

In 1964, the Columbia Gas System Service Corporation (Columbia Gas) requested the United States Steel Corporation to investigate the possibility of producing a large-diameter pipe with a minimum yield stress of 100,000 psi (689 MPa). Columbia Gas produced and installed a section of this pipe parallel to an existing 26 in (0.66 m) pipe. The test section consisted of 1,193 ft (366 m) of 36-inch (0.91 m) OD X100 pipe with a wall thickness of 0.25 inches (6.35 mm) and short sections of X60 with a wall thickness of 0.45 in (11.4 mm). Columbia Gas capped both ends of the 1,193 ft (366 m) section of pipe and connected it to the main transmission pipeline

via a two-inch (50.8 mm) line, making the experimental pipe serve simply as a pressure vessel. The experimental pipe did not transmit gas.

R. S. Ryan described the pipe and installation process in detail [1], though much of the publication focused on the nuances of installing the pipe, including grading/ditching, coating, backfill, and bending long (20 ft - 60 ft/6 m - 18 m) sections of pipe. In the paper, R.S. Ryan noted that US Steel formed the pipe into cylinders, welded it along the seam, and then quenched and tempered it. US Steel heat-treated the seam welds producing the pipe section before field deployment. Workers connected separate sections of 20-foot (6 m) pipe via automated or semi-automated girth welds.

The mechanical property data provided with the original pipe is sparse. The “minimum yield strength” is given as 100,000 psi (689 MPa) with a minimum tensile strength of 115,000 psi (793 MPa) and an elongation of 15 %. There is also a singular Knoop indentation trace across a girth weld (shown in Figure 1) and two graphs related to Charpy impact testing: impact energy and shear area (shown in Figure 2).




Figure 1 - Knoop indentation trace across a girth weld, from R. S. Ryan (1965).




Figure 2 - Charpy test data (absorbed energy on the left and shear fracture on the right) reported by R. S. Ryan (1965).

Unfortunately, these are all the historical data that were provided about the pipe. In the paper from 1965, R.S. Ryan makes three references to other sources which may provide information about the historic X100 pipeline steel:

- “A further indication is the performance of a similar material in the Athens tests.”
- “Generally, the shipping instructions were based on the work done by the AGA NG-18 program.”
- “There are several ways to increase yield strength beyond the present levels of the semi-killed steels, *i.e.*, fully killed steel, alloy steel, and heat treatment such as normalizing or quenching and tempering.”

The first quote references the Athens tests, which were a series of full-scale rupture tests carried out by the Battelle Memorial Institute in Athens, Ohio [37]. The second quote references the American Gas Association NG-18 program, which was a program conducted over approximately 40 years in the mid to late 1990’s. The comprehensive NG-18 program investigated several steel chemistries and testing geometries to produce crack models in natural gas pipeline steels and develop strategies to arrest existing cracks in pipelines [38]. The historical work that was referenced by R.S. Ryan most likely refers to a 1963 NG-18 report [39].

The third quote indicates that the experimental X100 pipe is of the semi-killed type, where the steel is partially de-oxidized during production, typically using silicon. The reduction in oxygen content in semi-killed steel reduces the development of porosity (via the production of CO bubbles) during welding, therefore increasing weldability. In the case of a fully killed steel,

aluminum is used in place of silicon to further reduce the oxygen content and improve weldability. The reference to semi-killed steel in the R. S. Ryan manuscript may indicate some expectation of the chemistry of the experimental X100 pipeline steel. A 2005 report on vintage pipelines authored by Battelle Memorial Institute discusses these various processes with respect to historical timeline and implementation [40].

The Charpy tests performed in this study were conducted on third-size specimens (thickness $B = 3.3$ mm, width $W = 10$ mm). This geometry was chosen for the following reasons.

1. The reported pipe thickness was 0.25" (6.35 mm) and therefore insufficient to extract full-size Charpy specimens. This necessitates the use of subsize specimens since miniaturized samples had not yet been introduced in the 1960s.
2. The energy levels reported in the R. S. Ryan manuscript are indicative of a sub-size geometry and the third-size specimen dimensions result in the maximum material use given the wall thickness limitations.

The orientation of the samples (longitudinal or transversal) is also undocumented in the R. S. Ryan manuscript, while it is reasonable to assume the data in Figure 2 were obtained from the base metal (pipe body).

Open literature resources were exhausted with remaining unknowns about the provided X100 steel. PRCI provided 37 documents related to the AGA NG-18 program. Steels described in these reports were compared to the current knowledge of the vintage X100 pipeline steel and will be discussed where appropriate, yet specific details remain copy protected by PRCI.

Additional information about the historic pipe was sought from TC Energy (previously Columbia Gas). TC Energy was able to provide some historical documentation, but mainly consisting of:

- Records of hydrostatic tests of installed pipe sections.
- Visitor lists and lists of "Workers on Atlantic Seaboard Corporation's 36" X-100 Experimental Line".
- A failure report for a seam weld that failed in the field during installation.
- Invoices and receipts for the use of an AMF welder and miscellaneous supplies for use during the installation of the pipe section(s).

The historic documentation provided by TC Energy is included in Appendix A. One especially notable document is a letter describing the hydrostatic testing of the “36” Line WB-5.” In this letter it is noted that:

- The X-60, .438 Wall Pipe in Sections 1, 2, 4, 5, and 6 has a specified minimum yield of 1460 PSI.
- The original test sheets will remain on file at Dranesville.

This indicates that the thicker pipe wall sections, P3S1 and P3S2, are likely X60 grade material (from 1967), which is not of specific interest to this project. Mechanical testing will be carried out on the base metal, but the multi-thickness, multi-material welds do not provide any insight into the welding of the vintage X100 material.

The second note that the original test sheets will remain on file at Dranesville indicates that there was at one time a stock of original material. Despite communication with US Steel, TC Energy (formerly Columbia Gas), and PRCI, no original material could be located.

1.4. Project Output

There is little data available that is verifiably associated with the X100 pipeline steel referenced in the R.S. Ryan paper. Furthermore, there is no data available that is verifiably associated with the exact sections tested at NIST. Without control specimens (*i.e.*, original X100 pipeline that was not buried or pressurized with natural gas) or data from the original pipe, there is no appropriate way to verify any change or degradation in microstructure, chemistry, or mechanical properties of the line pipe steel provided to NIST. The only data that can be referenced is the minimal Charpy impact and hardness indentation data provided by R.S. Ryan.

As an output to this project:

- The collected data will be compared to the original indentation presented by R.S. Ryan whenever possible.
- All collected data (raw and processed) will be provided in a repository as baseline data for future researchers.
- All specimens and material from the project will be provided to the Pipeline Research Council International (PRCI) for inclusion in their warehouse of pipeline materials for use by future researchers.

The data repository for this project can be found at the following location:

<https://doi.org/10.18434/mds2-3322>

2. Materials and Methods

2.1. As-Received Materials

Three pipe sections of the experimental X100 pipeline were received at NIST and the cut plan that was devised based on the test requirements prescribed by API 5L. The three pipe sections, named Pipe 1 (P1), Pipe 2 (P2) and Pipe 3 (P3), all contain a variety of welds, and pipe body sections with different wall thicknesses, and welding methods. Each pipe body section was formed from quenched and tempered plate, therefore giving them a designation of X100Q, and being categorized as a PSL 2 pipe with submerged arc welded longitudinal seams (SAWL/LSAW). These designations are based on current API 5L line pipe specifications since X100 (Q or M) was not included in the specifications at the time of manufacture. The pipe section dimensions, and construction details are given in Table 1.

The pipe construction details and measurements were collected, and three-dimensional (3D) computer aided design (CAD) software was used to create digital models of the pipes. These CAD models were used for subsequent sectioning plans to ensure that specimens were extracted from known locations in the pipes with respect to key weld features in the pipes. Pipe details can be found in Appendix B.

Table 1. As-Received Pipe Section Dimensions and Construction Detail

Pipe Section	Designation	Total Length	Internal Diameter	Wall Thickness	Seam Welds	Girth Welds	Seam Offset
Pipe 1 (P1)	P1S1	49.5 in (1.26 m)	35.1 in (89 cm)	0.26 in (6.6 mm)	1	1	154°
	P1S2				1		
Pipe 2 (P2)	P2S1	47.25 in (1.2 m)	35.1 in (89 cm)	0.26 in (6.6 mm)	1	1	20°
	P2S2				1		
Pipe 3 (P3)	P3S1	97 in (2.46 m)	35.1 in (89 cm)	0.45 in (11.4 mm)	1	2	95° (S1 to S2)
	P3S2			0.45 in (11.4 mm)	1		26° (S1 to S3)
	P3S3			0.26 in (6.6 mm)	1		

Section Designations include the pipe number and the seam weld number (same as the section number), *e.g.*, P1S1 translates to Pipe number one and seam weld (or section) number one.

Isometric views of the pipe section models can be seen in Figure 3. Not all pipe sections received were coated for corrosion protection, some had some coating and others had none, which resulted in significant corrosion. All sections removed were sent out to a vendor to have that coating removed by media blasting with a fine-grained Silicon-Carbide (SiC) media.




Figure 3 - Isometric view of each modelled pipe section.

The sections removed by plasma cutting were then documented and modelled in the 3D-CAD software modelled, the specimen layout and cut path was designed to maximize the use of available material. Blanks were sectioned for Charpy V-notch (CVN), single-edge bend (SE(B)), single-edge tension (SE(T)), base metal round tensile specimens, all weld-metal (AWM) round tensile specimens, along with net shape full-thickness longitudinal and transverse tensile specimens. Not all specimen types were machined for this study, blanks were retained for potential future research. A total of 19 plasma cut sections were sent to the waterjet vendor. A representative cut plan is shown in Figure 4. All 19 cut plans (including annotations for specific specimen names) are provided in Appendix C. The cut plans were named according to the location of the section, for example P1S1 is a cut plan from pipe section 1 (see Fig. 2) and includes the seam weld, where P1S1-90 is a section taken from pipe section 1 oriented 90 degrees from the seam weld, and P1S1-180 is a section from pipe section 1 oriented 180 degrees from the seam weld. A summary of the test specimens taken from each section is given in Table 2, and more detailed test matrices for specific tests are provided in the following section.




Figure 4 - Example of a specimen sectioning plan sent to the waterjet vendor. This plan is for section P1S1, all dimensions are in inches, more detail may be found in Appendix C. Specimen blanks shown are used for CVN, tensile, SE(B) and SE(T) tests. Samplings for microstructure, chemistry and micro-hardness maps are taken from remaining sprue material.

Table 2 - Specimen sectioning summary.

Section	Microstructure	Chemistry	CVN	Tensile	SE(B)	SE(T)	Hardness
P1S1	SW, BM	SW, BM	SW, BM	SW, BM			SW, BM
P1S1-90	GW, BM	GW, BM	GW, BM	BM			GW, BM
P1S1-180	BM	BM	BM	BM			BM
P1S2	SW, BM	SW, BM	BM	SW, BM			SW, BM
P1S2-90	GW, BM	GW, BM		GW, BM			GW, BM
P1S2-180	BM	BM	BM	BM			BM
P2S1	SW, BM	SW, BM	SW, BM	SW, BM			SW, BM
P2S1-90	GW, BM	GW, BM	GW, BM	BM			GW, BM
P2S1-180	BM	BM	BM	BM			BM
P2S2	SW, BM	SW, BM	SW, BM	SW, BM			SW, BM
P2S2-90	GW, BM	GW, BM	BM	GW, BM			GW, BM
P2S2-180	BM	BM		BM			BM
P3S1	SW, GW, BM	SW, GW, BM	SW, GW, BM	SW, GW, BM	SW	GW, BM	SW, GW, BM
P3S1-90	GW, BM	GW, BM	GW, BM	GW, BM	BM	GW, BM	GW, BM
(P3S1-270)	GW, BM	GW, BM	GW, BM	GW, BM			
P3S1-180	GW, BM	GW, BM		GW, BM	BM	GW, BM	GW, BM
P3S2	SW, BM	SW, BM	BM	SW, BM	BM	BM	SW, BM
(P3S2-90)	GW, BM	GW, BM	BM	GW, BM		BM	GW, BM
(P3S2-270)	BM	BM	BM	BM		BM	BM
(P3S2-180)	BM	BM	BM	BM		BM	BM
P3S3	SW, BM	SW, BM	SW, BM	SW, BM			SW, BM
P3S3-90	GW, BM	GW, BM	BM				GW, BM
P3S3-180	GW, BM	GW, BM	BM				GW, BM

GW = Girth Weld (includes WMC and HAZ, as appropriate)

SW = Seam Weld (includes WMC and HAZ, as appropriate)

BM = Base Metal (includes longitudinal and transverse orientations)

Sections in parenthesis are included in other section cut plans.

Section numbers with -90, -180 and -270 refer to the circumferential section placement with respect to the seam weld (in the "clock" coordinate system common for line pipe, these would be 3 o'clock, 6 o'clock and 9 o'clock respectively).

Specimens for metallographic analysis and indentation were sectioned from the remaining material after water jet cutting. A full layout of all pipe sections with the location of metallographic/indentation samples is included in Appendix D.

2.2. Design of Experiments

2.2.1. Chemical Characterization of Base Metal

Accurate chemical characterization of the vintage X100 base metal is critical to understand how the pipe in question compares to historical and modern steels. Optical emission spectroscopy (OES) was used in this study to determine the chemistry of each of the seven pipe sections (P1S1, P1S2, P2S1, P2S2, P3S1, P3S2, and P3S3) in accordance with ASTM E415 [41]. OES specimens were sections from the metallographic test specimens (Appendix D). The pipe specimens were not adequate to cover the OES aperture, so specimens were melted prior to chemical characterization. The test matrix for this task is given in Table 3.

Table 3 - Test matrix for microstructure and chemical analysis – Specimen micrographs are found in Appendix D.

Section	Seam Weld	Girth Weld	Base Metal	OES Chemistry
P1S1	X		X	X (BM, SW)
P1S1-90		X	X	
P1S1-180			X	
P1S2	X		X	X (BM, SW)
P1S2-90		X	X	
P1S2-180			X	
P2S1	X		X	X (BM, SW)
P2S1-90		X	X	
P2S1-180			X	
P2S2	X		X	X (BM, SW)
P2S2-90		X	X	
P2S2-180			X	
P3S1	X		X	X (BM, SW)
P3S1-90		X	X	
(P3S1-270)		X	X	
P3S1-180		X	X	
P3S2	X		X	X (BM, SW)
(P3S2-90)		X	X	
(P3S2-270)			X	
(P3S2-180)			X	
P3S3	X		X	X (BM, SW)
P3S3-90		X	X	
P3S3-180		X	X	

2.2.2. Characterization of Microstructure and Chemistry of Vintage and Modern X100 Pipe

The welding process is inherently non-equilibrium the solid-state heating and cooling of the weld pool and HAZs can lead to large gradients in material microstructure and chemistry. These gradients and inhomogeneities will have significant impact on the mechanical properties of the weld zone and should be fully characterized to complement investigations of mechanical properties. In this task, NIST analyzed the microstructure and chemistry of the base metal, HAZs, and weld zones via optical and scanning electron microscopes.

Optical imaging provides qualitative information about gradients in grain size, shape, and morphology across the entire weld area and large areas of base metal. The speed of optical imaging means that full optical images of all metallographic specimens have been collected. The full optical images are large (>500 MB each) so they are provided in the data repository (see Section 1.4). A subset of the optical images is shown in the results section.

Backscattered electron imaging in the scanning electron microscope can provide more quantitative information over the entire weld area. Additionally, electron backscatter diffraction (EBSD) provides localized information about crystallographic texture and grain size.

The test matrix for this task is given in Table 3. Microstructure and chemistry information is necessary for each specific component (seam weld, girth weld or base metal) and orientation of the sectioned pipes, one view is provided for each and is available in the project data repository (see Section 1.4).

2.2.3. Instrumented Charpy Testing and Hardness Mapping of Vintage and Modern X100 Pipe

NIST owns three Charpy reference machines (compliant with ASTM E23 [42]) that help maintain an accurate absorbed energy scale for Charpy machines around the world. Currently, NIST certifies twenty-one standard reference materials (SRMs) that underpin quality control of impact toughness for structural steels. Moreover, NIST is currently working with other national metrological institutes (NMIs) to develop an approach to SRM certification that reduces the measurement bias, with a focus on standardizing the design of instrumented strikers to provide comparable force-displacement data across all types of Charpy machines via a true dynamic

calibration procedure. As such, absorbed energy measured under the instrumented impact curve will be traceable to force and time, linking the measurement to more fundamental quantities.

Transition curves for absorbed energy (traditionally known as *KV*) were obtained for base metals of all pipes and sections in the longitudinal (L) orientation, by testing between 8 and 12 third-size Charpy specimens in a range of temperatures encompassing lower shelf, ductile-to-brittle transition region, and upper shelf (between $-196\text{ }^{\circ}\text{C}$ and $100\text{ }^{\circ}\text{C}$). The third-size specimens tested (Figure 5) had a width $W = 3.3\text{ mm}$, which corresponds to $1/3$ of the width of a standard Charpy specimen ($W = 10\text{ mm}$), while thickness B and length L were the same (10 mm and 55 mm , respectively). The notch depth (0.66 mm) also corresponds to $1/3$ of the notch depth for a standard specimen (2 mm). From each *KV* transition curve, the values of ductile-to-brittle transition temperature, *DBTT*, and upper shelf energy, *USE*, were calculated. In addition to *KV* values, values of lateral expansion (*LE*) and shear fracture appearance (*SFA*), estimated from the instrumented force/deflection curves, are reported for information only. All tests were instrumented.




Figure 5 – Third-size Charpy specimens used in this investigation.

For the base metals of selected pipes and sections in the transverse (T) orientation and in different clock positions (0° , 90° , 180°), 3 to 4 third-size Charpy specimens were tested at $0\text{ }^{\circ}\text{C}$. The results obtained in the 90° clock position (P1S1, P2S2, P3S1, P3S2, and P3S3) were compared

with the requirements of API 5L for pipe body of PSL 2 pipes, multiplied by the ratio between sub-size and standard Charpy specimen widths.

For the weld metal and heat-affected zone of each seam weld, between 3 and 6 third-size Charpy specimens were tested at 0 °C. The resulting *KV* values were then compared with the requirement of API 5L for pipe weld and HAZ tests, again multiplied by the ratio between sub-size and standard Charpy specimen widths.

Finally, two third-size Charpy specimens were tested at 0 °C for each girth weld (one in the weld metal and one in the HAZ). Overall, 168 third-size Charpy specimens were tested.

The test matrix for this task is given in Table 4. Data and discussion from the testing are provided in the results section. The full data set is provided in the NIST data repository (see Section 1.4). The number of specimens tested are shown in parentheses: *L* and *T* refer to longitudinal specimens and transverse specimens (these are specimen orientations), the notch orientations are perpendicular to the specimen orientation and are not through-thickness but rather notched from the inside-diameter (ID) side of the section.

Table 4 – Test Matrix for Charpy V-Notch Testing.

Section	Seam Weld	Girth Weld	Base Metal
P1S1-0	WMC (3), HAZ (3)	WMC (1), HAZ (1)	L (4), T (4)
P1S1-90			L (4), T (4)
P1S1-180			L (4), T (4)
P1S2-0	WMC (3), HAZ (3)		L (4), T (4)
P1S2-90			L (4), T (4)
P1S2-180			L (4), T (4)
P2S1-0	WMC (3), HAZ (3)	WMC (1), HAZ (1)	L (4), T (4)
P2S1-180			L (4), T (4)
P2S2-0	WMC (3), HAZ (3)		L (4), T (3)
P2S2-90			L (4), T (4)
P3S1-0	WMC (3), HAZ (3)	WMC (1), HAZ (1) [0°] WMC (1), HAZ (1) [90°]	L (4)
P3S1-90			L (4), T (4)
P3S1-180			L (4)
P3S2-0	WMC (3), HAZ (3)		L (4)
(P3S2-90)			L (4), T (4)
(P3S2-180)			L (4)
P3S3-0	WMC (3), HAZ (3)		L (4), T (4)
P3S3-90			L (4), T (4)
P3S3-180			L (4), T (4)

Tests that were compared to the API 5L requirements are indicated in bold. All specimens were tested at 0 °C, except those longitudinal specimens used to establish the transition curves.

Specimens were all subsize (third-size) type due to pipe wall thickness. For full-size Charpy specimens, the minimum average absorbed energy for the pipe body is 54 J (40 ft-lbs) for X100 pipes, whereas the minimum average absorbed energy for welds and HAZ is 40 J (30 ft-lbs).

2.2.4. Tensile Testing of Vintage and Modern X100 Pipe

NIST participated in and conducted research on a modern X100 pipeline steel and girth welds under DOT/PHMSA Research Project DTPH56-07-T-000005, Weld Design, Testing, and Assessment Procedures for High Strength Pipelines [1]. In addition to conducting curved wide plate (CWP) tests, NIST and project collaborators conducted several small-scale mechanical and fracture tests. Small-scale test results have been disseminated in the final reports of the project.

In this current work, NIST conducted similar small-scale tests on the X100 vintage experimental pipe as were conducted in the previous studies. These tests included full thickness base metal tensile tests to determine longitudinal and transverse tensile properties. These tests also included full thickness tensile tests characterizing both seam welds and girth welds.

The complete test matrix (see Table 2) includes single edge-notch bend (SE(B)) and single edge-notch tension (SE(T)) fracture mechanics tests. It is important to note that these fracture mechanics tests were not performed on the pipe prior to putting it into service, therefore no time-history comparisons can be made. To ensure the test results accurately represent material property differences, the standards, methods, instrumentation techniques, and analysis procedures were compared and considered for potential bias in addition to the uncertainty from the tests. The first proposed activity was to review the original test standards, methods, instrumentation techniques and analysis procedures used for testing the vintage and modern X100 steel and girth-welds. The originals are compared to currently used and accepted techniques and procedures to find differences that would influence the comparison of properties.

The pipes and welds were sectioned, and specimens machined per the test matrix. The next activity was to compare test results and determine the material property differences between each pipe section.

The tensile test matrix for this task is given in Table 5. Summary data from the testing is provided in the results section. Complete test records from each specimen are provided in the project data repository (see Section 1.4). The number of specimens tested are shown in parentheses: *L* and *T* refer to longitudinal specimens and transverse specimens.


The sectioning of tensile specimens from pipe sections is illustrated in Figure 6. This figure is reproduced from Figure 5 of the API 5L specification. The L90 specimen is not required for pipe diameters greater than 20 in. Furthermore, longitudinal specimens are not required at all to meet the API 5L line pipe specification. All longitudinal tests were performed for comparative purposes between original material performance data and modern X100 line pipe steel. Girth weld testing in the longitudinal direction is also not a requirement for API 5L.

Round tensile specimens are an optional geometry according to API 5L, however there are two geometry requirements that are impossible to meet with the vintage pipes provided. Firstly, the minimum diameter for a round tensile specimen according to API 5L is 0.25 in (6.35 mm), and this is not possible on a reduced section with a nominal pipe wall thickness of 0.25 in (6.35 mm). Even if a smaller diameter was used, meeting ASTM A370, the API 5L specification requires that specimens in the transverse direction are made from un-flattened pipe. This would only be possible from the larger wall thickness pipes of P3S1 and P3S2 and very limited comparisons would be possible, so the round bar tensile geometry was not used in this study.

Table 5 – Test Matrix for Tensile Testing.

Section	Seam Weld	Girth Weld	Base Metal
P1S1	L (1), T (2) W (1)		L (1)
P1S1-90			L (3), T (3) T90 (3)
P1S1-180			L (3), T (3) T180 (1)
P1S2	L (1), T (3) W (1)		L (1)
P1S2-90		L (3)	L (3), T (3) T90 (3)
P1S2-180			L (2), T (3) T180 (1)
P2S1	L (1), T (1) W (1)		L (1)
P2S1-90			L (3), T (3) T90 (3)
P2S1-180			L (3), T (3) T180 (1)
P2S2	L (1), T (3) W (1)		
P2S2-90		L (3)	T (3) T90 (3)
P2S2-180			L (2), T (3) T180 (1)
P3S1	L (1), T (3) W (1)		L (2)
P3S1-90			L (3), T (3) T90 (3)
P3S1-180		L (3)	L (3), T (3) T180 (1)
(P3S1-270)		L (3)	L (3)
P3S2	L (1), T (3) W (1)		L (3), T (3)
(P3S2-90)			L (3), T (2) T90 (3)
(P3S2-180)			L (1), T (3) T180 (1)
(P3S2-270)			L (3), T (2) T90 (3)
P3S3	L (2), T (6) W (1)		L (4)
P3S3-90		L (3)	L (6), T (6) T90 (3)
P3S3-180			L (6), T (6) T180 (1)

Numbers in parentheses are the number of specimens tested per section. Bold numbers represent the API 5L minimum requirement. P3S2-90 only has two of the required T90 specimens, however P3S2-270 should be equivalent and has two more specimens to meet the minimum test specimen requirement.

**Key**

- 1 W — transverse weld sample, centred on the weld
- 2 T180 — transverse sample, centred $\approx 180^\circ$ from the longitudinal weld
- 3 T90 — transverse sample, centred $\approx 90^\circ$ from the longitudinal weld
- 4 L90 — longitudinal sample, centred $\approx 90^\circ$ from the longitudinal weld

Figure 6 - Schematic illustration of the required specimen orientation and circumferential location of tensile test specimens according to API 5L.

2.2.5. Multiscale Indentation Mechanics of Vintage and Modern X100 Pipe

The hardness profiles of the weld zone were characterized in the R.S. Ryan paper [1] using a Knoop hardness test. This technique clearly revealed a reduced hardness in the HAZ. The following decades have since resulted in dramatic improvements in the spatial resolution of indentation-based mechanics.

In this task, the single Knoop line profile (duplicating R.S. Ryan) is complemented by automated large-area indentation over both girth and seam welds, extending the one-dimensional historical data array into a two-dimensional property map. This allows for direct comparison with the historical data, while introducing greater spatial resolution for characterizing the HAZ to base metal transition zones.

Knoop hardness traces are made across all seam and girth welds. Vickers indentation is used to measure variations in mechanical properties through the pipe wall thickness. Additionally, Vickers indentation is used to map properties across entire girth and seam welds. The Vickers indentation test results in a smaller, more symmetric indent allowing for higher resolution property mapping over large areas.

Instrumented nano-indentation (using a Berkovich indentation geometry) is used to measure the mechanical property of materials at the nanometer scale. Nano-indentation results in a much smaller plastically deformed zone and much higher precision in lateral positioning, allowing for spatial resolution 100x to 1000x better than Vickers or Knoop indentation. In this case, instrumented nano-indentation is used to measure how variations in the material microstructure (specifically near the internal and external surfaces of the pipe) impact the localized mechanical properties.

The test matrix for this task is given in Table 6. Representative data from the Knoop, Vickers, and nano-indentation testing is provided in the results section. Complete test data are included in the data repository (see Section 1.4).

Table 6 - Test matrix micro-hardness mapping of welds.

Section	Seam Weld	Girth Weld	Base Metal
P1S1	X		X
P1S1-90		X	
P1S2	X		X
P1S2-90		X	
P2S1	X		X
P2S1-90		X	
P2S2	X		X
P2S2-90		X	
P3S1	X		X
P3S1-90		X	
(P3S1-270)		X	
P3S1-180		X	
P3S2	X		X
(P3S2-90)		X	
P3S3	X		X
P3S3-90		X	
P3S3-180		X	

2.3. Metallography

2.3.1. Metallographic Preparation

After separation from their host plate, the metallographic samples were sectioned using a high-speed saw. The saw and the specimen were water-cooled during cutting to provide lubrication

and prevent any significant temperature rise in the specimen being sectioned. No specific corrosion protection was provided during this step, as all specimens would be polished following sectioning. The metallographic samples were sectioned to a major dimension of less than 31 mm to allow for mounting into phenolic resin.

Specimens were then mounted in a thermosetting, electrically conductive phenolic resin using a heated mounting press.

Damage from the high-speed saw was removed using diamond-embedded disks, moving to finer grits during polishing, including 240 grit, 320 grit, 480 grit, 600 grit, 800 grit, and 1200 grit. Following grinding with the diamond disks, specimens were polished using diamond slurry decreasing in grit size including 9 μm , 6 μm and 3 μm . All specimens were subsequently polished with the 1 μm diamond slurry until all scratches from previous polishing steps were removed.

For electron backscatter diffraction and nano-indentation, the specimens were polished using a 0.05 μm colloidal silica suspension with a vibratory polisher for up to four hours. Polishing for more than four hours was found to produce surface relief in the metallographic specimens.

2.3.2. Optical Microscopy

Specimens for optical microscopy re-polished using the preparation steps listed previously and were etched using a 2.5% Nital etchant (5 ml 50% nitric acid solution to 100 ml methanol) to reveal the grain structure. Specimens were submersion etched for approximately 30 seconds, until the polished surface clouded over, and the bulk grain structure was visible. Specimens were immediately washed with isopropanol to prevent corrosion.

Etched metallographic specimens were imaged with a digital optical microscope to provide a bulk overview of the microstructure. Specimens were then imaged in bright field with an inverted metallographic microscope. Images were collected at a magnification of 10x (0.61 μm pixel size) with an image size of 2048 x 2048 pixels. The open-source micro-manager software [43] was used to image over large areas and stitch the resulting images.

A portion of the optical microscope images are included in this report, but the images are very large (>200 MB per image), so the full data set is provided in the data repository (see section 1.4).

2.3.3. Scanning Electron microscopy

Backscattered electron images were collected to provide higher resolution imaging of the base metal, weld, and heat affected zone microstructures. Images were collected with an accelerating voltage of 5 kV, a beam current of 1.3 nA. Dwell time was adjusted as appropriate to produce acceptable single-to-noise ratio. An automated large-area imaging and image stitching software package was used to collect and stitch images over large areas.

In addition, electron backscatter diffraction (EBSD) was used to measure microstructure metrics in welds, heat-affected zones, and base materials. The scanning electron microscope was operated under the following conditions on samples tilted 70 degrees: 30 kV accelerating voltage, 120 μm aperture, and a 19 mm working distance. Large areas were surveyed using a multi-tile method where a given tile was approximately 450 μm x 450 μm in size and the entire row of stitched tiles spanned a length of 8 mm. These EBSD maps were recorded using a step size of 750 nm. Smaller areas were further analyzed in the base metal using a 250 nm step size during acquisition of a single tile.

2.4. Tensile Testing

Testing according to API 5L requires that ASTM A370 be followed as the standard test method, ASTM A370 references ASTM E8. While ASTM A370 provides an overview and references ASTM E8 for detailed procedures, ASTM E8 contains the in-depth guidelines required to perform tension testing accurately and consistently. Despite specimens being curved, the standard application will be for plate-type specimens having a reduced section width of 1.5 in (38.1 mm) and a gauge length of 2 in (50.8 mm). Values stated in in-pound units are regarded as the standard. Units converted from inch-pound to SI are not required for the standard, furthermore in-pound units were the original units used when the vintage X100 pipe sections were manufactured. The plate-type specimen dimensions relevant to this study follow the *Rectangular Tension Test Specimens* fully described in Figure 3 of the ASTM A370 standard (see also Figure 1 of the ASTM E8 standard). Allowable deviations to the specimen geometry are related to the length and width of the grip section (grip-tab). Gauge marks for the purpose of measuring elongation after fracture are replaced with welded studs, described below in section 2.4.3.

2.4.1. Specimen Geometry and Measurements

Full-wall-thickness specimens were waterjet cut from each pipe section; the specimens were dog-bone shaped where the reduced section length was greater than 8 times that of the thickness. All specimens had the same nominal shape, shown in Figure 7. However, the waterjet nozzle was always perpendicular to the working surface and not perpendicular to the tangent point on the surface of the pipe section. This resulted in specimens with parallel edges, but not necessarily perpendicular to the inside diameter or outside diameter surfaces of the pipe section. The cross-sectional area, for stress calculation, was taken as the edge-to-edge width multiplied by the average thickness of the specimen (pipe wall), measured for each specimen. The thickness was measured with a digital micrometer equipped with a flat anvil (OD side) and a ball end anvil (ID side). Three thickness measurements along the length of the specimen were taken and averaged. The edge-to-edge width was the average of three measurements along the reduced section using digital calipers.




Figure 7 - Nominal shape and dimensions of full-wall-thickness tensile specimens. All dimensions are in inches.

2.4.2. Flattening Procedure

Specimens tested that were transverse to the longitudinal axis of the pipe sections required flattening prior to testing. The flattening procedure for these specimens used a four-point bend fixture. Specimens were placed into the fixture and were loaded and moved incrementally to reduce the occurrence of reverse-bending the specimens. The four-point bend fixture is shown in Figure 8. Each specimen required manual adjustments to the incremental loads applied, since a standard load or displacement value for each successive loading did not lead to the desired outcome.




Figure 8 - Flattening fixture used for transverse tensile specimens. Four-point bend arrangement with a lower span of 4 in and upper span of 2 in.

The procedure for each incremental loading began with the specimen grip-tab edge close to the center of one of the bottom span rollers as shown in Figure 8. After loading and unloading, the specimen was shifted so that it was centered within the upper and lower spans and was loaded and unloaded again. The specimen was then shifted again so that the opposite grip-tab was flattened, with a similar alignment to the first loading. The specimen was shifted within these three positions with progressive loading and unloading, until the center (reduced gage section)

was flattened. Flatness of the gage section was verified for each specimen using a ground steel reference plate and feeler gauges (within 0.5 mm). The ends of the specimens, specifically, nearest the grip-tab edges were the least flat section resulting from this method.

This method required some craft to obtain the best possible flatness in the gage section without inducing a reversal in curvature, and subsequent correction. The method was effective on base metal and welded specimens; however, it was more difficult to demonstrate flatness on the welded specimens due to the root pass weld reinforcement.

The remaining curvature of the end tabs presented a possible source of bending in the specimen at the beginning of the test. One of the specimens was instrumented and loaded into the hydraulic grips while data was recorded to capture any bending strain induced due to the gripping process. The procedure was to install and grip the specimen in the upper hydraulic grip, install the extensometer, and zero (tare) the force and extensometer signals while in displacement control. Then switch to force control (set at zero force) and apply gripping pressure on the lower grip-tab while collecting data from the process. Examining the data from this process showed that less than 0.2 % strain was imposed on the specimen as a combined result of a bending moment induced by the gripping processes on the curved grip-tabs and the change in machine displacement to accommodate the zero-force command. This amount of strain is above the signal noise floor but is not large enough to require a procedure change. Furthermore, the post-test analysis procedure for each test includes slack compensation that eliminates non-linear response at the beginning of the test.

2.4.3. Specimen Preparation

Each specimen was measured and scribed for the installation of a threaded stud. The threaded studs were welded to the ID surface of the specimens with a capacitive discharge stud welder. A cam-like fixture with a hardened steel pin was installed on each stud to interface with the extensometer. A post-test photo of a specimen is shown in Figure 9, illustrating the alignment scribe lines and showing the welded studs. A specimen loaded into the hydraulic grips is shown in Figure 10 , along with a photo of the extensometer installed on the specimen.



Figure 9 - Post-test photo of a tensile specimen.



Figure 10 - Full wall thickness tensile specimens were tested in a servo-hydraulic universal test frame and were gripped in hydraulic grips (left). A close-up view of the gage section of the specimen on the ID side shows how the extensometer is attached to the specimen prior to testing (right).

2.4.4. Tensile Testing Procedure

All instruments used during the test procedure were calibrated according to the manufacturer's specification and appropriate ASTM Standards. Each tensile test was conducted according to the same machine control profile. After measurement/layout and stud welding procedures (see above section), each specimen was tested according to the following procedure:

1. Measure specimen thickness and gage length between pins and input into the summary spreadsheet.
2. On gage pins, add a nut, clip gage fixture, and another nut – tighten when aligned.
3. Insert tensile specimen into top hydraulic grip, center it, then tighten w/ hydraulic pressure.
4. Raise bottom grip in displacement mode.
5. Zero the force signal.
6. Go to force control and immediately close the bottom hydraulic grip.
7. Apply a pre-load to the specimen using manual command - 0.1 kip in tension.
8. Install the extensometer and zero the signal.
9. Remain in force control and release the manual command.
10. Click New Specimen in the program "Flat Tensile Test" and type the specimen ID.
11. Click the start button, fill in the user input window, click Ok.
12. While the test runs, measure the next specimen's dimensions and update the summary spreadsheet.
13. At the completion of the test, click new specimen and switch to displacement control.
14. Remove the extensometer.
15. Release the bottom hydraulic grip – remove the specimen half.
16. Release the top hydraulic grip – remove the specimen half.
17. Remove the nuts and clip gage fixtures from the welded studs.
18. Measure total elongation and input into the summary spreadsheet.

Each specimen was tested to failure at room temperature using a displacement-controlled rate of 0.05 in/min.

2.4.5. Tensile Analysis Procedure

The data record for each specimen was analyzed using a spreadsheet template with data reduction and analysis algorithms developed by NIST for this program. This ensured that each specimen was analyzed using the same procedure with similar variable adjustments.

The following generalized procedure uses the spreadsheet and requires some level of engineering judgement; the number of specimens analyzed did not warrant the next level of programming to automate the analysis.

1. Open the tensile analysis spreadsheet template.
2. Navigate to the (next) specimen folder and open the specimen.dat file.
3. Copy-Paste the tab-delimited columns from the specimen.dat file into the Raw Data worksheet of the analysis spreadsheet.
4. Examine the plot shown on the Raw Data worksheet and determine the last significant data point.
5. Delete all data rows past that last significant data point.
6. On the Reduced Data worksheet adjust the number of rows to match the raw data.
7. Examine the Slack Plot and adjust the range to match the best linear portion of the curve.
8. Using the Goal Seek function (on cell J21), find the 0.2 % offset yield stress.
 - a. Adjust the strain range to ensure that the yield strain is within the range.
 - b. Iterate as needed.
9. Copy the specimen results into the summary spreadsheet.
10. Save the file with the specimen ID in the appropriate folder – save the analysis file as the next specimen ID and repeat the steps starting with number 2.

The spreadsheet automatically calculates the engineering stress, engineering strain, and slack-compensated engineering strain. The slack-compensated engineering strain is dependent on the user defined linear range (taken as a percentage of the UTS). This is the same linear range used to calculate the elastic modulus. Slack compensation can affect the 0.2 % offset yield, the stress at 0.5 % strain, as well as the strain at the ultimate tensile strength (UTS), also referred to as uniform elongation. The source of slack can include straightening of curved specimens, noise in the extensometer data, or non-linearities associated with the extensometer seating on the specimen gage pins.

A representative Slack Plot is shown in Figure 9. Here, the difference between the original strain-dependent data and the slack-compensated data is less than 0.13 % for this specimen; some specimens exhibited more signal noise and non-linearity at the beginning of the test than this

one. The maximum difference between the original and slack-compensated strain-dependent data for all the tests was 2.3 %. The horizontal lines in Figure 11 define the upper and lower bounds over which the modulus is calculated. The fitting coefficients of that line are used to calculate the offset strain to compensate for slack. The vertical line is the 0.5 % strain line, and the corresponding stress is determined as the intersection of that line with the stress-strain curve. The 0.2 % offset line has the same slope as the calculated modulus, and the stress is determined as the intersection of that line with the stress-strain curve.




Figure 11 - Stress-strain curve of specimen P4 (from P3S2), illustrating the Slack Plot used in the data analysis spreadsheet. The slack compensation for this specimen was minimal, resulting in a uniform elongation difference of 0.003 %.

Only the data that are relevant to this comparative study is presented. According to API 5L, the yield stress (0.2 % offset method), the yield stress (defined as the stress at 0.5 % strain), the

ultimate tensile strength (UTS), yield to tensile ratio, uniform elongation, and seam weld strength are the only tensile properties of concern.

The tensile requirements for X100Q PSL 2 pipe according to API 5L are given in Table 6. The specified minimum elongation is given by the following equation:

$$A_f = C \frac{A_{xc}^{0.2}}{U^{0.9}}$$

where C is 625,000, A_{xc} for all specimens tested in this study is the cross-sectional area of the specimen measured to the nearest 0.01 in² and U is the minimum tensile strength which is 110,200 psi.

Table 7 - Tensile property requirements for X100M or X100Q – excerpt from API 5L.

Pipe Body Properties						Seam Weld	
Yield Strength (psi)		UTS (psi)		Y/T (ul)	A _f (%) min		UTS (psi)
min	max	min	max	max	0.25 in	0.5 in	min
100,100	121,800	110,200	143,600	0.97	13.7	17	110,200
Yield Strength (MPa)		UTS (MPa)			A _f (%) min		UTS (MPa)
min	max	min	max		6.35 mm	12.7 mm	min
690	840	760	990		13.7	17	760

There is a caveat in API 5L for the yield to tensile (Y/T) ratio for grades greater than X90, where instead of the yield strength being defined as the stress at 0.5 % strain, the yield stress for this ratio is the 0.2 % offset yield stress.

2.5. Instrumented Charpy Testing

Charpy impact tests on third-size specimens extracted from base metals, weld metals, and heat affected zones were conducted on a large-capacity (950 J) machine equipped with an 8 mm¹ instrumented striker. The velocity at impact was 5.47 m/s.

The energy absorbed at specimen fracture (absorbed energy, KV) was measured by means of a digital encoder, based on the fall, and rise angles of the hammer and accounting for windage and

¹ 8 mm indicates the radius of the striking edge.

friction losses. As ancillary information, the following was measured and reported for every specimen tested:

- lateral expansion, LE (mm): combined height of the shear lips generated by plastic deformation of the sample during fracture, measured by means of a caliper; and
- (estimated) shear fracture appearance, SFA_{est} (%): percentage of ductile (shear) fracture surface.

The latter parameter, SFA_{est} , was calculated from the instrumented force-displacement curve of each test performed (see an example in Figure 12), using the following equation:

$$SFA_{est} = \left[1 - \frac{F_{iu} - F_a}{F_m + 0.5(F_m - F_{gy})} \right] \times 100 \quad (1)$$

where in Figure 12:

- F_{iu} = force at unstable crack propagation
- F_a = crack arrest force
- F_m = maximum force
- F_{gy} = force at general yield.

Eq. (1) is one of four formulae reported in the ASTM E2298 and ISO 14556 standards. However, this is the one adopted at NIST for SFA estimation, based on results published in [44].




Figure 12 - Example of instrumented force/deflection curve for a test in the ductile-to-brittle transition region.

For some tests, instrumented data were not recorded due to a malfunction of the acquisition system. In other instances (particularly at the lowest temperatures and for extremely brittle specimens), the analysis of the instrumented curve was extremely difficult, due to the low levels of force and the very pronounced dynamic oscillations that were superimposed onto the actual test record, which rendered almost impossible to determine the characteristic values of force shown in Figure 12.

For each set of tests performed on the base metal of a specific pipe/section in longitudinal (L) orientation, absorbed energy values, KV , were fitted as a function of test temperature using the well-established hyperbolic tangent (TANH) regression model [37]:

$$KV = \frac{LSE+USE}{2} + \frac{USE-LSE}{2} \cdot \tanh\left(\frac{T-DBTT}{C}\right) \quad (2)$$

where:

- T is the temperature ($^{\circ}C$),
- LSE (lower shelf energy) is the asymptotic value that the curve tends to as T decreases (J)
- USE (upper shelf energy) is the asymptotic value that the curve tends to as T increases (J)
- C is the half-width of the transition region between lower and upper shelf ($^{\circ}C$)
- $DBTT$ is the ductile-to-brittle transition temperature ($^{\circ}C$), corresponding to the point where $KV = (LSE+USE)/2$

The regression curve obtained is denominated *transition curve* (example in Figure 13), and the main material parameters extracted from it are $DBTT$ and USE . In the analyses conducted here, LSE was set at the minimum recorded value of absorbed energy.




Figure 13 - Example of absorbed energy transition curve for a low-strength steel.

2.6. Indentation Testing

2.6.1. Microhardness Indentation

Following mounting and metallographic preparation (including final polishing with 1 μm diamond slurry), specimens were placed in an automated microhardness tester. Both Vickers and Knoop indentations were performed with an indenter load of 500 grams and a dwell time of 13 seconds. Indentations were measured automatically using the microhardness tester software.

Vickers indentation was performed across the thickness of the pipe base metal to establish the degree of hardness variation that may exist due to potential through-thickness micro-structural gradients. Weld cross sections (perpendicular to the weld axis) were mapped with Vickers indentation to measure the hardness across the girth or seam weldments, including pipe steel base metal, heat affected zone (HAZ) and weld metal regions.

Knoop hardness indentation traces were performed across weld cross sections to recreate the data presented by R. S. Ryan [1].

2.6.2. Nano-indentation

Following mounting and metallographic preparation (including final polishing with colloidal alumina), specimens were placed on the stage of the nanoindenter. The nanoindenter was equipped with a precision stage and a load transducer, allowing for instrumented indentation and measurement of local hardness and elastic modulus.

Nano-indentation was performed using a Berkovich geometry indenter tip and a quasistatic load function with a maximum load of 5000 μN . Load was applied over 15 seconds, held at the maximum load for 5 seconds, and then unloaded over 15 seconds. Elastic modulus was determined from the loading portion of the force-displacement curve and the hardness was determined based on the known (assumed) tip geometry and the maximum displacement upon loading.

Indentation was performed across a portion of the thickness of the pipe to detect any degree of variation that may exist due to potential through-thickness micro-structural gradients. Additionally, indentations were performed along the internal surface of the pipe to investigate any variation or degradation in mechanical properties that may eventually be attributed to long-term exposure to natural gas, but further research is necessary to explore this possibility.

2.7. Results

2.7.1. Material Chemistry

One (or more) specimens of base metal from each pipe section (P1S1, P1S2, P2S1, P2S2, P2S3, P3S1, P3S2) were characterized by optical emission spectroscopy (OES), which included meltdown of most specimens as the pipe wall thickness was too thin to fully cover the OES aperture. The chemical characterization results, which were critical in the efforts to identify the pipe in the historical literature, are provided in Table 8. Note that specimen OM2 is from a girth weld connecting pipe specimens P3S1 and P3S2.

Table 8 - Chemical composition of vintage X100 pipeline steels from optical emission spectroscopy.

	C	S	P	Si	Cr	Ni	Mn	Cu	Mo	Nb	Ti	Al	V	Co	W	Sn	Fe
AM1 (P1S1)	0.24	0.02	0.016	0.04	0.05	0.02	1.21	0.03	0.1	<0.01	<0.01	0.01	0.08	0.01	0.01	0.01	Bal
AM2 (P1S1)	0.12	0.024	0.012	0.15	0.04	0.03	0.62	0.03	0.45	<0.01	0.01	<0.01	0.02	<0.01	<0.01	<0.01	Bal
DM3 (P1S2)	0.19	0.018	0.010	0.31	0.02	0.02	1.33	0.04	0.01	<0.01	0.01	0.09	<0.01	<0.01	0.01	<0.01	Bal
GM2 (P2S1)	0.25	0.02	0.011	0.27	0.02	0.02	1.24	0.03	0.01	<0.01	0.01	0.07	<0.01	<0.01	<0.01	<0.01	Bal
JM1 (P2S2)	0.24	0.017	0.010	0.29	0.02	0.02	1.31	0.03	0.01	<0.01	0.01	0.08	<0.01	<0.01	<0.01	<0.01	Bal
MM3 (P3S1)	0.22	0.012	0.011	0.03	0.05	0.02	1.21	0.04	0.01	<0.01	<0.01	0.01	0.08	<0.01	<0.01	<0.01	Bal
OM1 (P3S2)	0.21	0.016	0.01	0.27	0.02	0.03	1.23	0.03	0.01	<0.01	0.01	0.07	<0.01	<0.01	<0.01	<0.01	Bal
OM2 (P3S2, GW)	0.13	0.021	0.018	0.51	0.11	0.63	1.19	0.18	0.12	<0.01	0.01	0.02	<0.01	0.01	0.01	0.01	Bal
RM1 (P3S3)	0.19	0.015	0.009	0.28	0.02	0.02	1.29	0.04	0.01	<0.01	0.01	0.08	<0.01	<0.01	<0.01	<0.01	Bal

2.8. Microstructure Analysis

2.8.1. Optical microscopy and BSE imaging

An example of both SEM backscatter imaging on polished specimens and optical bright field imaging on etched specimens is shown in Figure 14. The provided optical and scanning electron images provide a representation of the base metal microstructure, which is consistent through all pipe sections. It should be noted that the optical images provide information like the backscattered images, but the optical image collection time is approximately 1% of the required time to collect a large-area scanning electron image.

Figure 15 illustrates the various microstructures present in and around a girth weld. Inset images include the interface between the weld metal and heat affected zone (red), the microstructure of the weld metal (green), the fine-grained heat affected zone (blue), and the pipe base metal (orange).

Lastly, Figure 16 shows a bright field optical image of a seam weld, the heat affected zone, and the surrounding base metal, showing the consistent grain size between the three distinct regions.

All raw imaging data is provided in the project data repository (see Section 1.4).




Figure 14 – Scanning electron microscope backscatter images (EM3 RTT, EM3 ATT, EM3 PV) and optical bright field images (AM1 RTT, AM1 ATT, AM1 PV) demonstrating the typical microstructure of the pipeline base metal.




Figure 15 – Scanning electron microscope backscatter images illustrating the typical microstructure across the regions of a girth weld (EM1 ATT Weld P1G1).




Figure 16 – Optical image of seam weld illustrating the consistent grain size between the weld metal, heat affected zone, and base metal (AM2 ATT).

2.8.2. Electron backscatter diffraction

Samples from selected pipe sections, welds, and orientations were prepared for further analysis using diffraction-based techniques in the SEM. A summary of the three orthogonal views is depicted in Figure 17 where a perimeter girth weld is used in that example. In many cases, the welding process ranged from automated to semi-automated, and manual methods were also employed. Between the welded regions and the joined base metals are heat-affected zones (HAZ) where, in some locations, the microstructure morphology resembles the base metal, but certain characteristics such as local misorientation and grain size tend to differ from the base metal. In Figure 18, there are effectively two HAZ regions where the HAZ closest to the weld is characterized by an extremely refined grain structure, higher kernel misorientation, and greater grain orientation deviation as compared to the weld. The HAZ region closest to the base metal also showed evidence of grain refinement compared to the base metal but was not as drastic of a difference as depicted in the HAZ closest to the weld, evidenced in both the room temperature alpha-Fe grains as well as the parent austenite grains. The HAZ closest to the base

metal also contained the lowest average kernel misorientation and orientation deviation. The average grain reference orientation deviation (GROD) value in degrees of orientation deviation respectively changed from $\sim 5^\circ$ in the weld to $\sim 4^\circ$ in the HAZ near the weld to $\sim 2^\circ$ in the HAZ near the base metal and back to approximately $\sim 4^\circ$ in the base metal. These same trends are visible in the other orthogonal view, depicted in Figure 19. Regardless of the semi-automated girth weld shown in Figure 18 or the manual girth weld shown in Figure 20, the trends of a duality in HAZ regions exists. This is important to note since tensile specimens excised with a tensile direction parallel the horizontal direction of Figure 18 and Figure 20 fractured at the fusion line. The manual girth weld (location EM1) shown in Figure 20 also contains a columnar microstructure (grain growth is parallel to the highest thermal gradient and varies spatially) in the weld. The manual girth weld also contained large spherical gas pores in the weld.




Figure 17 - Schematic of the three orthogonal views (PV, RTT, and ATT) characterized with scanning electron microscopy.




Figure 18 - a) An optical image of a girth weld, HAZ, and base metal from location KM2, depicted by an axial view through the thickness (ATT) where a white rectangle indicates the location of a multi-tile large-area EBSD map. The b) kernel average misorientation c) grain reference orientation deviation, and d) inverse pole figure maps generated with EBSD while indexing body-centered cubic alpha-Fe are shown above. A child-to-parent reconstruction was performed and a plot of the e) inverse pole figure map of the face-centered-cubic gamma-Fe phase is shown.




Figure 19 - a) An optical image of a girth weld, HAZ, and base metal from location KM2, depicted by a plan view of the surface (PV) where a white rectangle indicates the location of a multi-tile large-area EBSD map. The b) kernel average misorientation c) grain reference orientation deviation, and d) inverse pole figure maps generated with EBSD while indexing body-centered cubic alpha-Fe are shown above. A child-to-parent reconstruction was performed and a plot of the e) inverse pole figure map of the face-centered-cubic gamma-Fe phase is shown.




Figure 20 - a) An optical image of a girth weld, HAZ, and base metal from location EM1, depicted by an axial view through the thickness (ATT) where a white rectangle indicates the location of a multi-tile large-area EBSD map. **The b) kernel average misorientation c) grain reference orientation deviation, and d) inverse pole figure maps generated with EBSD while indexing body-centered cubic alpha-Fe are shown above. A child-to-parent reconstruction was performed and a plot of the e) inverse pole figure map of the face-centered-cubic gamma-Fe phase is shown.**

The base metal was analyzed in three orthogonal views to understand the influence of surface conditions on the microstructure present in these pipe sections. In Figure 21, a multi-tile map was recorded on the ATT view from the outer diameter of the pipe towards the interior base metal. Within the first 200 microns of the outer diameter, a refined grain structure exists and is likely caused by processing routines and environmental effects over time. The refined portion tends to have more randomly oriented grains, lower grain orientation deviation and a smaller grain size. When all three orthogonal planes were analyzed, the trend remained. Figure 22 and Figure 23 respectively quantify the orientation and grain size metrics of the ferritic grains observed with EBSD. The outer diameter surface of the pipe trended towards having a low grain orientation spread of $\sim 1^\circ$, whereas the interior microstructure consistently showed a grain orientation spread (GOS) value of $\sim 2.5^\circ$. When comparing grain boundary misorientations for any given field of view, a bi-modal distribution of boundary types was observed to contain a high number fraction of low-angle grain boundaries (0° to 5°) and a broad distribution of high-angle grain boundaries (greater than 15°). Histograms are provided as the density of boundaries in a map of these fields of view would be difficult to discern. The cumulative

percentages of low-angle grain boundaries (0° to 5°) in the ATT, RTT, and PV_OD views are respectively 57%, 58%, and 42% whereas high-angle grain boundaries (15° to 180°) in the ATT, RTT, and PV_OD views of the base metal were respectively 38%, 38%, and 54%. The grain size diameter of the ferritic grains near the pipe surface was less than 2 microns whereas the grain size of the interior of the pipe trended more towards 7 microns.




Figure 21 - a) An optical image of base metal from location EM3, depicted by an axial view through the thickness (ATT) where a white rectangle indicates the location of a multi-tile large-area EBSD map from the outer diameter to the interior of the pipe base metal. The b/c/d) child alpha-Fe phase, present at room temperature, and e/f/g) parent gamma-Fe phases are shown side-by-side. Specifically, the b/e) inverse pole figure maps, c/f) grain reference orientation deviation maps, and d/g) grain size diameter maps are provided to show specific changes in microstructure from left (pipe outer diameter) to right (interior of the base metal).




Figure 22 - Single-tile small-area EBSD maps were recorded from all three orthogonal views (ATT, RTT, and PV_outer diameter) of the base metal at location EM3. The a) inverse pole figure maps, b) grain orientation spread, and c) misorientation histograms provide quantitative differences between the microstructure at the surface of the pipe (PV_outer diameter) and the interior microstructure.




Figure 23 - Single-tile small-area EBSD maps were recorded from all three orthogonal views (ATT, RTT, and PV_{outer diameter}) of the base metal at location EM3. The a) grain size diameter maps and b) grain size diameter histograms provide quantitative differences between the microstructure at the surface of the pipe (PV_{outer diameter}) and the interior microstructure.

2.9. Tensile Testing

The results presented in Table 9 are based on the requirements of API 5L referenced in Table 7. The data are organized based on the orientation and location of the tested specimens. In cases where multiple specimens were tested, the average value is presented, and the number of specimens tested are indicated by the number in parentheses next to the section identifier (see also Table 5). Sections with multiple specimens are reported as the average with the standard deviation, seam weld specimen for P2S1 is reported with the observed value of stress with an estimated combined uncertainty of 1.06 %.

Table 9 - Tensile testing results required by API 5L.

Pipe Body Results						Seam Weld
Section	YS _{0.2} %	YS _{0.5} %	UTS	Y/T	A _f	UTS
	ksi	ksi	ksi	ul	%	ksi
	(MPa)	(MPa)	(MPa)			(MPa)
P1S1 (2)						137.9 ± 0.9 (951 ± 6)
P1S1-90 (3)	112.8 ± 1.7 (778 ± 12)	107.1 ± 2.4 (738 ± 17)	135.2 ± 0.4 (932 ± 3)	0.83 ± 0.01	18.1 ± 0.8	
P1S1-180 (3)	114.0 ± 0.6 (786 ± 4)	104.2 ± 1.0 (718 ± 7)	135.7 ± 0.4 (936 ± 3)	0.84 ± 0.00	19.1 ± 0.9	
P1S2 (3)						140.3 ± 0.3 (967 ± 2)
P1S2-90 (3)	113.4 ± 0.7 (782 ± 5)	108.7 ± 0.7 (749 ± 5)	139.1 ± 0.1 (959 ± 1)	0.82 ± 0.00	18.3 ± 0.4	
P1S2-180 (3)	119.4 ± 6.7 (823 ± 46)	116.2 ± 13.2 (801 ± 91)	138.3 ± 0.4 (954 ± 3)	0.86 ± 0.05	18.2 ± 0.5	
P2S1 (1)						138.6 ± 1.5 (956 ± 10)
P2S1-90 (3)	115.4 ± 1.1 (796 ± 8)	110.3 ± 3.9 (760 ± 27)	135.6 ± 2.2 (935 ± 15)	0.85 ± 0.01	18.6 ± 0.6	
P2S1-180 (3)	114.6 ± 1.6 (790 ± 11)	109.5 ± 3.5 (755 ± 24)	135.9 ± 0.6 (937 ± 4)	0.84 ± 0.01	18.6 ± 0.3	
P2S2 (3)						139.9 ± 1.1 (965 ± 8)
P2S2-90 (3)	112.4 ± 2.4 (775 ± 17)	98.0 ± 3.4 (676 ± 24)	136.3 ± 0.3 (940 ± 2)	0.82 ± 0.02	15.9 ± 0.6	
P2S2-180 (3)	114.9 ± 2.7 (792 ± 19)	106.8 ± 6.1 (736 ± 42)	137.3 ± 0.3 (947 ± 2)	0.84 ± 0.02	16.7 ± 0.7	
P3S1 (3)						90.9 ± 1.3 (627 ± 9)
P3S1-90 (6)	59.8 ± 0.4 (412 ± 3)	61.2 ± 0.8 (422 ± 6)	86.1 ± 0.7 (594 ± 5)	0.69 ± 0.01	31.8 ± 0.9	
P3S1-180 (3)	59.7 ± 0.1 (412 ± 1)	61.5 ± 0.2 (424 ± 1)	86.6 ± 0.1 (597 ± 1)	0.69 ± 0.00	32.7 ± 0.0	
P3S2 (3)						93.3 ± 0.8 (643 ± 6)
P3S2-90 (3)	65.1 ± 3.1 (449 ± 21)	65.8 ± 1.3 (454 ± 9)	89.8 ± 0.2 (619 ± 1)	0.72 ± 0.03	30.0 ± 1.0	
P3S2-180 (3)	65.6 ± 1.7 (452 ± 12)	67.1 ± 1.4 (463 ± 10)	89.2 ± 1.4 (615 ± 10)	0.74 ± 0.01	30.9 ± 0.4	
P3S3 (5)						134.7 ± 1.0 (928 ± 7)
P3S3-90 (6)	108.7 ± 4.7 (749 ± 32)	99.8* ± 9.2 (688 ± 63)	130.4 ± 0.9 (899 ± 6)	0.83 ± 0.03	19.6 ± 0.6	
P3S3-180 (6)	106.2 ± 2.6 (732 ± 18)	97.7* ± 3.8 (674 ± 26)	131.3 ± 0.6 (905 ± 4)	0.81 ± 0.02	19.7 ± 0.6	

* P3S3 base metal tests failed to meet current API 5L requirements for X100

- Numbers in parenthesis after the section label indicate the number of specimens tested and included in the average and standard deviations given.
- Y/T is the ratio between the yield strength and the ultimate tensile strength.

2.10. Instrumented Charpy Testing

2.10.1. Absorbed energy transition curves for base metals - Longitudinal Direction

The results obtained from third-size Charpy specimens for the obtainment of KV transition curves are provided in Tables 9 to 15. The tables also include values of lateral expansion and estimated shear fracture appearance.

Table 10 - Third-size Charpy test results on P1S1 (pipe 1, section 1) base metal orientation L.

Specimen ID	T (°C)	KV (J)	LE (mm)	SFA (%)	B/FB/NB ²
C10-L2	-196	0.4	0.06	N/A ³	B
B15-L3	-150	0.9	0.00	N/A	B
C10-L4	-135	5.8	0.08	28	B
A3-L3	-125	5.4	0.04	N/A	FB
C10-L3	-100	5.7	0.12	N/A	FB
B15-L4	-85	10.2	0.21	N/A	FB
B15-L2	-75	13.9	0.17	N/A	FB
A3-L2	-50	11.9	0.14	N/A	FB
A3-L1	-25	12.3	0.24	100	FB
B15-L1	0	8.6	0.24	100	FB
C10-L1	21	10.5	0.21	100	FB
A3-L4	100	9.3	0.24	100	FB

² B = specimen broken in two halves upon impact; FB = specimen unbroken upon impact but can be broken with bare fingers without using any tool (finger broken); NB = not broken (*i.e.*, cannot be broken with bare fingers).

³ N/A = not available (instrumented data not acquired or instrumented data analysis not reliable, particularly in the case of fully brittle tests).

Table 11 - Third-size Charpy test results on P1S2 (pipe 1, section 2) base metal orientation L.

Specimen ID	T (°C)	KV (J)	LE (mm)	SFA (%)	B/FB/NB
D1-L3	-196	5.6	0.07	N/A	B
D1-L4	-150	8.1	0.17	N/A	FB
F1-L4	-100	7.0	0.14	23	FB
F1-L3	-75	8.7	0.15	48	B
D1-L2	-50	15.4	0.22	59	FB
F1-L2	-25	13.9	0.19	N/A	FB
D1-L1	0	10.6	0.19	55	FB
F1-L1	21	12.8	0.19	N/a	FB

Table 12 - Third-size Charpy test results on P2S1 (pipe 2, section 1) base metal orientation L.

Specimen ID	T (°C)	KV (J)	LE (mm)	SFA (%)	B/FB/NB
I3-L3	-196	3.3	0.03	N/A	B
G3-L4	-153	3.0	0.05	N/A	B
I3-L4	-100	6.7	0.10	12	B
G3-L3	-75	6.3	0.14	30	FB
I3-L2	-50	12.1	0.24	57	FB
G3-L2	-25	11.9	0.26	67	FB
I3-L1	0	17.1	0.23	85	FB
G3-L1	21	9.8	0.24	100	FB

Table 13 - Third-size Charpy test results on P2S2 (pipe 2, section 2) base metal orientation L.

Specimen ID	T (°C)	KV (J)	LE (mm)	SFA (%)	B/FB/NB
K1-L1	-196	5.0	0.01	N/A	B
K1-L2	-140	3.3	0.03	N/A	B
K1-L3	-100	11.0	0.21	49	FB
K1-L4	-75	7.6	0.18	31	FB
J3-L4	-50	10.2	0.15	47	FB
J3-L3	-25	11.6	0.24	76	FB
J3-L2	0	9.5	0.23	73	FB
J3-L1	21	10.5	0.22	100	FB

Table 14 - Third-size Charpy test results on P3S1 (pipe 3, section 1) base metal orientation L.

Specimen ID	T (°C)	KV (J)	LE (mm)	SFA (%)	B/FB/NB
M18-L1	-196	0.1	0.01	N/A	B
M18-L3	-146	4.1	0.03	N/A	B
O8-L2	-120	0.1	0.04	N/A	B
O8-L3	-102	0.1	0.06	N/A	B
M18-L2	-75	4.3	0.04	N/A	B
M18-L4	-60	10.5	0.29	22	FB
P16-L4	-50	11.4	0.30	35	FB
O8-L4	-40	15.7	0.28	25	FB
P16-L3	-25	17.4	0.47	85	NB
P16-L2	0	19.1	0.48	84	NB
P16-L1	21	20.7	0.54	100	NB
O8-L1	100	19.6	0.56	100	NB

Table 15 - Third-size Charpy test results on P3S2 (pipe 3, section 2) base metal orientation L.

Specimen ID	T (°C)	KV (J)	LE (mm)	SFA (%)	B/FB/NB
N10-L1	-196	0.1	0.06	N/A	B
P12-L1	-150	0.9	0.1	12	B
P12-L2	-125	0.1	0.02	N/A	B
M12-L4	-90	9.5	0.18	31	FB
N10-L3	-75	N/A ⁴	0.12	11	FB
M12-L3	-75	3.6	0.05	N/A	B
M12-L2	-50	8.4	0.25	19	FB
P12-L3	-40	8.8	0.23	27	FB
M12-L1	-25	15.7	0.34	21	NB
N10-L4	0	25.4	0.53	78	NB
N10-L2	21	23.6	0.47	100	NB
P12-L4	100	19.4	0.54	100	NB

⁴ Absorbed energy value not acquired.

Table 16 - Third-size Charpy test results on P3S3 (pipe 3, section 3) base metal orientation L.

Specimen ID	T (°C)	KV (J)	LE (mm)	SFA (%)	B/FB/NB
Q3-L1	-196	1.4	0.00	N/A	B
R9-L1	-150	0.6	0.01	N/A	B
S22-L4	-125	3.8	0.08	50	B
S22-L1	-100	5.4	0.14	24	FB
R9-L4	-85	4.8	0.18	N/A	FB
Q3-L2	-75	9.8	0.14	100	FB
Q3-L4	-65	4.2	0.21	100	FB
R9-L2	-50	13.0	0.27	100	FB
S22-L2	-25	13.3	0.20	100	FB
Q3-L3	0	11.0	0.23	N/A	FB
R9-L3	21	14.5	0.24	100	FB
S22-L3	97	13.7	0.29	100	FB

Absorbed energy transition curves obtained in the L orientation of the base metal for all pipes and sections are compared in Figure 24, while Table 17 collects values of DBTT and USE obtained for all conditions examined. The same values are compared in the bar charts illustrated in Figure 25 and Figure 26, respectively.

Table 17 - Ductile-to-brittle transition temperatures and upper shelf energies for base metals in L orientation, with estimated standard errors. For DBTT, standard error was estimated using the NIST statistical online tool “Transition Curve Fitting Tool” [X]; for USE, standard error was calculated based on the standard deviation of the absorbed energy values corresponding to the upper shelf of the curve.

Pipe	Section	DBTT (°C)	USE (J)
P1	S1	-122.9 ± 15.7	11.0 ± 0.7
	S2	-75.0 ± 0.0012	13.2 ± 1.0
P2	S1	-77.0 ± 31.0	12.7 ± 1.6
	S2	-124.6 ± 12.6	10.1 ± 0.6
P3	S1	-57.7 ± 2.8	19.8 ± 0.5
	S2	-42.7 ± 9.7	22.8 ± 1.8
	S3	-80.9 ± 10.4	13.1 ± 0.6




Figure 24 - Absorbed energy transition curves obtained on the base metals of the different pipes and sections in L orientation.




Figure 25 - Comparison between DBTT values calculated for the base metals of the different pipes and sections in L orientation. Note: the toughest conditions correspond to the tallest bars (P1S1 and P2S2).




Figure 26 - Comparison between USE values calculated for the base metals of the different pipes and sections in L orientation.

2.10.2. Charpy test results at 0 °C for base metals in T direction

Values of absorbed energy obtained at 0 °C from instrumented Charpy tests on third-size specimens from base metals of the different pipes and sections in the transverse orientation are provided in Table 18, which also reports average KV values, as well as values of lateral expansion and estimated shear fracture appearance.

API 5L section 9.8 and Table 8 prescribe the minimum absorbed energy requirements for pipe body of PSL 2 pipes. For X100 pipes with outside diameter, D , between 762 mm and 914 mm, such as the three pipes investigated (P1, P2, and P3), the minimum required average absorbed energy, \overline{KV}_{min} , is 54 J. However, according to section 9.8.1.1, if subsize specimens are used, \overline{KV}_{min} shall be multiplied by the ratio of the subsize specimen to the full-size specimen width, W . For third-size specimens, therefore, \overline{KV}_{min} shall be divided by 3, so that:

$$\overline{KV}_{min} = 54/3 = 18 \text{ J.}$$

Moreover, according to section 9.8.1.2, absorbed energy values from each individual test, KV_i , must be at least equal to 75 % of \overline{KV}_{min} . For third-size specimens, $KV_{i,1/3} \geq 14$ J (rounded to the nearest joule from 13.5 J).

The above requirements only apply to specimens in T direction and from the 90° clock position (results shown in bold in Table 18).

In Table 18, test results that do not fulfil the API 5L requirements are highlighted in red font over pink background. If they satisfy API 5L, they are highlighted in green.

Table 18 - Results of 0 °C third-size Charpy tests on base metals in T orientation. Values subject to API 5L requirements are shown in bold. Acceptable values are highlighted in green, non-acceptable values in red.

Pipe	Section	Angle	Specimen id	KV (J)	KV_{mean} (J)	LE (mm)	SFA_{est} (%)	B/FB/NB
P1	S1	0°	A1-T1	5.03	7.84 ± 2.63	0.15	N/A	FB
			A1-T2	6.17		0.16	N/A	FB
			A1-T3	9.87		0.15	N/A	FB
			A1-T4	10.29		0.18	N/A	FB
		90°	B13-T1	6.95	8.78 ± 2.32	0.17	85	FB
			B13-T2	6.97		0.13	100	FB
			B13-T3	11.80		0.15	100	FB
			B13-T4	9.38		0.15	72	FB
	180°	C12-T1	7.25	8.99 ± 2.82	0.14	63	FB	
		C12-T2	6.69		0.15	100	FB	
		C12-T3	9.09		0.15	71	FB	
		C12-T4	12.94		0.17	100	FB	
	S2	0°	D3-T1	6.17	8.09 ± 2.49	0.16	79	FB
			D3-T2	5.75		0.18	83	FB
D3-T3			9.88	0.19		61	FB	
D3-T4			10.58	0.15		62	FB	
180°		F3-T1	6.96	9.71 ± 1.98	0.15	61	B	
		F3-T2	9.71		0.15	52	FB	
P2	S1	0°	G1-T1	6.40	8.89 ± 2.49	0.12	67	B
			G1-T2	7.11		0.15	65	FB
			G1-T3	10.66		0.17	62	FB
			G1-T4	11.37		0.17	68	FB
		180°	I1-T1	5.88	8.13 ± 2.51	0.17	56	FB
			I1-T2	6.03		0.16	64	FB
			I1-T3	10.16		0.17	70	FB
			I1-T4	10.44		0.17	62	FB
	S2	0°	J1-T1	5.80	7.74 ± 1.75	0.18	73	FB
			J1-T2	8.21		0.18	68	FB
			J1-T3	9.21		0.19	81	B
			K3-T1	7.68		9.53 ± 2.43	0.18	79
		K3-T2	7.54	0.19	63		FB	
		90°	K3-T3	10.23	0.19	62	FB	
K3-T4	12.66		0.17	74	FB			
P3	S1	90°	P18-T1	7.59	8.31 ± 2.18	0.33	100	FB
			P18-T2	5.62		0.30	100	FB
			P18-T3	9.45		0.29	100	FB
			P18-T4	10.59		0.28	85	FB
	S2	90°	M14-T1	8.81	9.88 ± 1.47	0.30	73	FB
			M14-T2	8.67		0.29	100	FB
			M14-T3	10.23		0.27	85	FB
			M14-T4	11.81		0.25	73	FB
	S3	0°	Q1-T1	7.17	8.96 ± 2.5	0.19	100	FB
			Q1-T2	6.61		0.19	100	FB
			Q1-T3	10.17		0.18	85	FB
			Q1-T4	11.88		0.17	84	FB
		90°	R11-T1	8.53	10.53 ± 3.0	0.19	73	FB
			R11-T2	8.39		0.18	69	FB
R11-T3			10.38	0.20		61	FB	
R11-T4			14.81	0.20		85	FB	
180°	S24-T1	7.45	9.17 ± 2.23	0.19	81	FB		
	S24-T2	8.44		0.21	84	FB		
	S24-T3	8.33		0.18	89	FB		
	S24-T4	12.44		0.22	69	FB		

2.10.3. Charpy test results at 0 °C on seam weld metals and heat affected zones

Values of absorbed energy obtained at 0 °C from instrumented Charpy tests on third-size specimens extracted from seam weld metals and heat affected zones (HAZ) for the different pipes and sections are collected in Table 19, which also reports average KV values, as well as values of lateral expansion and estimated shear fracture appearance.

For pipe weld and HAZ tests, API 5L section 9.8.3 requires $\overline{KV}_{min} = 40$ J at 0 °C for pipes in grades > X80 and full-size Charpy specimens. Using the normalization procedure already described in 3.3.2, the minimum for third-size specimen becomes $\overline{KV}_{min,1/3} = 13$ J (rounded to the nearest joule from 13.3 J). Absorbed energy values from each individual test, KV_i , must be at least equal to 75 % of $\overline{KV}_{min,1/3}$. For third-size specimens, $KV_{i,1/3} \geq 10$ J.

In Table 19, test results that do not fulfil the API 5L requirements are highlighted in red font over pink background. If they satisfy API 5L, they are highlighted in green.

Table 19 – Results of third-size Charpy tests at 0 °C on seam welds and HAZ. Acceptable values according to API 5L are highlighted in green, nonacceptable values in red.

Pipe	Section	Material	Specimen id	KV (J)	KV_{mean} (J)	LE (mm)	SFA_{est} (%)	B/FB/NB	
P1	S1	Weld	A2-W1	2.27	4.77 ± 2.17	0.09	7	B	
			A2-W2	5.80		0.10	14	B	
			A2-W3	6.23		0.11	7	B	
		HAZ	A2-H1	6.23	6.95 ± 2.01	0.17	70	FB	
			A2-H2	5.39		0.13	64	FB	
			A2-H3	9.22		0.15	83	FB	
	S2	Weld	D2-W1	6.07	4.43 ± 2.26	0.15	6	B	
			D2-W2	5.37		0.03	18	B	
			D2-W3	1.86		0.12	6	B	
		HAZ	D2-H1	6.24	6.48 ± 1.92	0.17	40	FB	
			D2-H2	4.69		0.14	18	FB	
			D2-H3	8.51		0.13	47	FB	
P2	S1	Weld	G2-W1	2.98	5.15 ± 2.27	0.11	12	B	
			G2-W2	4.96		0.11	17	B	
			G2-W3	7.50		0.15	15	B	
		HAZ	G2-H1	10.08	8.23 ± 2.28	0.15	80	FB	
			G2-H2	8.93		0.14	76	FB	
			G2-H3	5.68		0.13	61	FB	
	S2	Weld	J2-W1	7.65	5.67 ± 2.8	0.16	16	B	
			J2-W2	3.69		0.14	14	B	
		HAZ	J2-H1	11.06	9.29 ± 2.5	0.16	53	B	
			J2-H2	7.52		0.17	68	FB	
P3	S3	Weld	Q2-W1	2.97	3.63 ± 1.66	0.13	30	B	
			Q2-W2	2.41		0.11	17	B	
			Q2-W3	5.52		0.11	17	B	
		HAZ	Q2-H1	5.24	7.7 ± 2.15	0.15	20	B	
			Q2-H2	8.66		0.17	33	B	
			Q2-H3	9.21		0.17	53	B	
		Weld	Q14-W1	2.78	3.35 ± 0.8	0.08	20	B	
			Q14-W2	3.91		0.08	22	B	
			HAZ	Q14-H1	5.67	9.09 ± 3.29	0.16	73	B
				Q14-H2	9.36		0.20	70	B
Q14-H3	12.23	0.19	100	B					

2.11. Charpy test results at 0 °C on girth weld metals and heat affected zones

Values of absorbed energy obtained at 0 °C from instrumented Charpy tests on third-size specimens extracted from girth weld metals and heat affected zones (HAZ) for the different pipes and sections are collected in Table 20, which also reports values of lateral expansion and estimated shear fracture appearance.

There are no absorbed energy requirements in API 5L for girth welds in PSL 2 Pipes.

Table 20 - Results of third-size Charpy tests at 0 °C on girth welds and HAZ.

Pipe	Angle	Material	Specimen ID	KV (J)	LE (mm)	SFA (%)	B/FB/NB
P1	90°	Weld	B2-W1	16.01	0.34	65	B
		HAZ	B2-H1	11.50	0.31	100	FB
P2	90°	Weld	H2-W1	14.84	0.33	73	FB
		HAZ	H2-H1	17.97	0.30	100	FB
P3	0°	Weld	M17-W1	16.29	0.50	N/A	FB
		HAZ	M17-H1	23.19	0.57	100	NB
	90°	Weld	N11-W1	11.84	0.41	N/A	FB
		HAZ	N11-H1	21.73	0.58	100	NB

2.12. Indentation Testing

Vickers hardness indentation traces of base metal specimens are presented in Figure 27 to determine whether there is any inhomogeneity in the properties through the thickness of the pipe. A partial through-thickness nano-indentation trace is shown in Figure 28 and a nano-indentation trace along the inner surface of the pipe is shown in Figure 29. The nano-indentation traces are intended to examine whether there is any variation in material properties based on microstructural changes at the surface of the pipe.

Vickers indentation mapping was used to visualize the variation in mechanical properties over girth welds, including base metal, weld metal, and heat affected zone. Maps of the two girth welds between the 0.25" (6.35 mm) thick pipe sections are shown in Figure 30 and Figure 31.

Knoop hardness indentation traces were made across girth and seam welds to duplicate the tests presented by R. S. Ryan. Five parallel traces were made across each weld, as shown in Figure 32 (girth weld) and Figure 33 (seam weld).

All raw indentation data is provided in the project data repository (see Section 1.4).




Figure 27 – Vickers indentation trace of various base metal specimens.




Figure 28 - Nano-indentation hardness and elastic modulus originating from the inner surface of the pipe (specimen XMX RTT).




Figure 29 - Nano-indentation hardness and elastic modulus tracing the inner surface of a pipe section (specimen XMX RTT).




Figure 30 – Vickers indentation hardness map of girth weld (EM1 ATT)




Figure 31 – Vickers indentation hardness map of girth weld (KM2 ATT)




Figure 32 – Knoop hardness traces across girth weld (EM1 ATT)




Figure 33 – Knop hardness traces across seam weld (AM2 RTT)

3. Discussion and Comparison

3.1. Chemical Analysis and Pipe Identification

To assist in determining the origin of the received pipe the chemical analysis data was compared to those in the 37 NG-18 reports provided by PRCI. Several experimental steels were detailed throughout the NG-18 reports, including information on chemistry, heat treatment, wall thickness, and summary mechanical properties. Unfortunately, there were no steels that matched the chemistry or summary mechanical properties of the vintage Columbia Gas X100 pipe. In some cases, full Charpy impact energy curves were provided in the NG-18 reports, but comparison is not possible without verification that the received vintage Columbia Gas X100 pipe is the same material listed in the tests.

Further complicating the identification of the pipe is the variation in the chemistry of the seven individual pipe sections. It is understood that sections P3S1 and P3S2 (0.45"/11.43 mm wall thickness) is a specimen of X60 based on the Columbia Gas historical documents. However, the variation in chemical data from optical emission spectroscopy seems to suggest that pipe sections P1S1, P1S2, P2S1, P2S2, and P3S3 may in fact all be different experimental materials.

3.2. Microstructure Analysis

The microstructure of base metal, heat-affected zones (HAZ), and welds were analyzed with optical microscopy, SEM backscatter imaging, and EBSD to determine general microstructural morphology, grain size, grain morphology, relative misorientation, and crystallographic alignment. The welds and HAZ contain a mix of martensite, ferrite, and bainite, as indicated by optical and BSE imaging, which is consistent with previous work on X100 pipeline steel [27]. Given the fine size scale of bainite, which is a mixture of ferrite and cementite, and the uncertainty in using EBSD to differentiate the body-centered cubic (BCC) ferrite phase from tetragonal martensite phase, it is common practice to index the microstructure using only the ferrite phase during EBSD measurements and use specific microstructural characteristics to discern between the various features [45], [46]. The base metal of API X100 steel is composed of mostly polygonal ferrite and some acicular ferrite morphologies, but dynamic

recrystallization can occur, depending on the rolling temperature employed during processing [28]. While rolling textures are an effective way of steering properties for a given application, sub-grain structures (dislocation arrays) and grain boundary character/density are economically viable for generating higher strengths [30].

Since the girth welds resulted in greater Charpy strength and higher variability in Knoop hardness and grain size (via optical and BSE imaging) as compared to seam welds, large-area EBSD scans were employed from weld to HAZ to base metal. Previous work on X100 steel welds showed the importance of minimizing coarsened martensite-austenite constituents in the heat affected zone as these features led to an increase in microcracking and cleavage [34]. Further, multiple HAZs have been reported in welded X100 pipeline samples, characterized by a transition in grain size, intragranular misorientation, and grain boundary angle [47]. Grain-size based nomenclature is most commonly employed to describe the differences, such as fine-grained HAZ (FG-HAZ) and coarse-grained HAZ (CG-HAZ). In the current work, the trend of multiple HAZs is also observed. The HAZ closest to the weld is characterized by an extremely refined grain structure (approximately 3 μm diameter globular ferrite), higher kernel misorientation, and increased grain orientation deviation as compared to the weld. The columnar parent austenite grains seen in the weld were longer than 1 mm in many cases and is influenced by welding speed and interpass temperature [48]. The HAZ region closest to the base metal also showed evidence of grain refinement compared to the base metal (approximately 7 μm grain diameter) but was not as drastic of a difference as depicted in the HAZ closest to the weld. Such differences explain the trends in Knoop hardness where a nearly 30% increase in hardness at the weld-HAZ boundary whereas a drastic decrease in hardness is observed near the base metal-HAZ boundary. It is also noteworthy to mention that tensile specimens containing a girth weld tended to fracture at the HAZ. This is likely due to drastic changes in intragranular misorientation. The average GROD value in degrees of orientation deviation respectively changed from $\sim 5^\circ$ in the weld to $\sim 4^\circ$ in the HAZ near the weld to $\sim 2^\circ$ in the HAZ near the base metal and back to approximately $\sim 4^\circ$ in the base metal.

With respect to the base metal, interesting features were observed near the surface of the pipe (outer diameter) in a refined grain structure exists and is likely caused by processing routines

and environmental effects over time. The refined portion tends to have more randomly oriented grains, lower grain orientation deviation and a smaller grain size. When all three orthogonal planes were analyzed, the trend remained. However, given the small volume fraction this region encompasses in full-scale tensile specimens, structure-property correlations were not observed. Rather, the typical bainite-ferrite microstructure observed with equiaxed parent austenite grains indicates a nearly complete recrystallization of grain structure in the EM3 pipe section.

3.3. Tensile Testing

At the time that this X100 pipe was produced, specifications for X100 line pipe did not exist. However, ASTM A370 and ASTM E8 standards did exist and were referenced in the API 5L specification. This is important because some differences in the data between the tests conducted at the time the pipe was produced and now, may be attributed to the differences in test method, specimen preparation, measurement methods or in the analysis. API 5L, ASTM A370 and ASTM E8 all existed at the time the X100 was produced and tested. Without knowing the exact time of production, each of the standards were all updated and published in 1966. For reference to potential changes, the 1966 versions will be compared to current versions.

The current version of API 5L significantly differs from the 1966 version, reflecting advancements in technology and industry standards. The 1966 version is limited in grade specification, while the current version includes higher strength grades like X70, X80, X100, and X120, addressing the need for stronger materials. The introduction of Product Specification Levels (PSL1 and PSL2) in the current version brings stricter requirements for chemical composition, mechanical properties, and testing. Modern testing methods, such as non-destructive testing and Charpy V-Notch impact testing, ensure higher reliability. Additionally, the current version specifies detailed manufacturing processes and enforces stricter controls over chemical composition.

The ASTM A370 standard has seen substantial improvements since its 1966 version, mostly reflecting advancements in measurement technology and test equipment and testing method. The current standard incorporates modern testing equipment and methods, enhancing the

accuracy of measurement requirement. It also provides more detailed testing procedures, improved safety guidelines, and stricter reporting requirements. It integrates advancements in data acquisition and analysis, addressing previous revisions and errata to enhance clarity and usability.

The current version of ASTM E8 has significantly evolved from the 1966 version, incorporating advanced test control methods (Stress Rate, Strain Rate, Crosshead Displacement), and improved gripping technologies for better accuracy. It mandates high-accuracy extensometers for precise strain measurement and provides detailed guidelines for specimen preparation.

There is very little information known about the testing performed on this X100 prior to being placed into service. However, full thickness test specimens had the same specimen geometry requirements as are relevant to the testing reported herein. Differences in test machines and gripping methods are known to affect the test data but it would be difficult to determine an uncertainty associated with those. Furthermore, flattening procedures have not been standardized even for current testing, adding yet another uncertainty element that is difficult to enumerate. Lastly, advances in measurement technologies, to include high-precision extensometers, digital data acquisition systems, and computerized data analysis have the largest potential for significant differences in test data.

Examining the tensile data in Table 9, most of the pipe sections met the current tensile requirements for API 5L X100Q. There are notable sections that failed to meet the minimum requirements.

The average value from section P2S2-90 included three test specimens that were all tested on the same day with the same setup and instrumentation. All three specimens exhibited anomalous strain data evidenced by very low modulus values. If low modulus values are the result of a test or measurement error, it is reasonable to suggest that if the correct modulus values (from suspect strain values) were calculated, then the yield strengths (0.5 %) would have shifted and therefore would have met the minimum required yield strength. The 0.2 % offset yield strength is less sensitive to errors or changes in modulus. Even with anomalous strain values, one of the three specimens would have passed with a yield strength (0.5 %) of 101.9 ksi,

it was the other two specimens that brought the average below specification at 95.6 ksi and 96.4 ksi respectively. The anomaly is still being investigated and those data sets will not be included in the data repository until the data can be further validated. All other tensile data associated with those three specimens are consistent with tests from other sections.

Additionally, those specimens were from the 90 ° circumferential orientation, which is required by API 5L, but specimens tested from P2S2-180 all passed the minimum specification. It is unlikely that the material at the 90 ° position was that significantly different from the 180 ° position, especially when all other 90 ° and 180 ° data are effectively equal within the standard deviation from other pipe sections.

The two sections, P3S1 and P3S2, were made from an X60 grade steel, while they are included in the data, they are not compared to X100 in anyway. These sections have a wall thickness of 0.45 in (11.4 mm), to carry the design pressure of 1,000 psi (6.9 MPa). See Appendix A for additional details about hydro-testing and some material information.

3.4. Instrumented Charpy Testing

3.4.1. Base metals, orientation L (transition curves)

API 5L does not contain provisions or requirements pertaining to the base metal (pipe body) of PSL 2 pipes in longitudinal orientation. The comparison between absorbed energy transition curves, illustrated in Figure 24, shows that P3S1 and P3S2 exhibited the highest upper shelf energies (these are X60), while the lowest⁵ *DBTT* values were yielded by P2S2 and P1S1. This is confirmed by the bar charts in Figure 25 (*USE*) and Figure 26 (*DBTT*). It's interesting to note the lowest value of *USE* corresponds to the lowest value of *DBTT* (P2S2). It's also noteworthy that several investigated conditions (P1S2, P2S1, P2S2) displayed a relatively high lower shelf energy, even at liquid nitrogen temperature (-196 °C). A fair amount of data scatter can be observed for all the investigated conditions.

⁵ As a reminder, a decrease of *DBTT* corresponds to an increase in toughness.

With respect to the Charpy data presented by R. S. Ryan in [1], as already mentioned, we ignore if they were obtained in L or T orientation. The upper shelf energy in Figure 2 (left side) is approximately 33 J, which is much higher than any *USE* value yielded by the pipes/sections considered in this investigation (10.1 J to 22.8 J, Table 18 and Figure 25). We cannot exclude, however, that the results in [1] were obtained from larger subsize specimens, for example half-size ($B = 5$ mm, $W = 10$ mm). In terms of DBTT, the values from [1], which correspond to -33 °C for absorbed energy and -43 °C for shear fracture appearance, are higher than most of the *DBTT* values recorded in this investigation (-124.6 °C to -42.7 °C, Table 18 and Figure 24).

3.4.2. Base metals, orientation T (0 °C)

All pipes and sections were characterized in different clock orientations by performing third-size instrumented Charpy tests at 0 °C. For specimens extracted in the 90° clock position, API 5L prescribes minimum values for the average absorbed energy, as well as for individual *KV* values. These requirements, normalized by the ratio of subsize/full-size specimen widths, correspond to $\overline{KV}_{1/3} \geq 18$ J and $KV_{i,1/3} \geq 14$ J for X100 line pipe.

As shown in Table 18, none of the average values of absorbed energy for specimens extracted in the 90° clock position satisfied the API 5L requirement. As for individual *KV* values, only one out of 20 X100 specimens tested in the 90° clock position met the API 5L requirement (specimen R11-T4 from P2S2, $KV = 14.81$ J).

3.4.3. Seam weld metals and HAZ (0 °C)

The weld metals and heat affected zones of the seam welds of the investigated pipes were characterized by testing third-size Charpy specimens at 0 °C. For seam welds, API 5L prescribes $\overline{KV}_{1/3} \geq 13$ J and $KV_{i,1/3} \geq 10$ J (after normalization based on subsize specimen widths).

As can be seen in Table 19, only one of the 12 average absorbed energy values meet the API 5L requirements. As for individual energy values, only 6 out of 33 tested specimens, all from HAZ, absorbed more than the API 5L minimum. None of the weld metal results were acceptable.

3.4.4. Girth weld metals and HAZ (0 °C)

The weld metals and heat affected zones of the girth welds of the investigated pipes were characterized by testing third-size Charpy specimens at 0 °C. There are no requirements for girth welds of PSL 2 pipes in API 5L.

The comparison between Table 20 (girth welds) and Table 19 (seam welds) shows that, for the three investigated pipes, girth welds are significantly tougher than seam welds. Specifically, the average absorbed energies were 4.50 J (weld metals) and 7.88 J (HAZ) for seam welds, and 14.75 J (weld metals) and 18.60 J (HAZ) for girth welds.

3.5. Indentation Testing

3.5.1. Base Metal

Micro-indentation traces across through-thickness sections of base metal indicate that there is no significant inhomogeneous degradation of the pipe due to the long-term exposure to natural gas and/or corrosive natural elements. The full through-thickness hardness for the 6.35 mm thick X100 pipe in sections P1S1, P1S2, and P2S1, presented in Figure 27, illustrates a hardness of approximately 300 HV with no significant variation through the thickness of the pipe. Note that the steep decreases at the end of the indentation hardness traces are caused by indentations in the phenolic resin mounting media at the end of the indent trace.

The through-thickness Vickers hardness of the thicker 11.43 mm pipe (assumed to be vintage X60 pipe per Columba Gas documents) shows a much lower hardness of about 200 HV. There is no historical data to compare to the thicker vintage X60 steel.

To supplement the through-thickness micro-indentation traces, nano-indentation hardness (Figure 28) was performed to investigate any material property changes related to the significantly smaller grain size at the inner surface of the vintage X100 steel. Nano-indentation hardness can be performed with much higher spatial resolution than micro-indentation hardness without causing interaction of the indentation deformation volumes. Instrumented nano-indentation also allows for calculation of the localized elastic modulus.

With the higher spatial resolution of nano-indentation there appears to be a reduction in nano-indentation hardness at the inner surface (about 3.5 GPa) compared to the bulk base metal (about 4 GPa). This reduction can be seen in the through-thickness nano-indentation trace (Figure 27) and confirmed in the nano-indentation traverse along the inner pipe diameter (Figure 28).

3.5.1.1. Seam Welds and Girth Welds

Knoop hardness indentation traverses were made across both girth and seam welds to duplicate the data presented by R. S. Ryan (Figure 1).

Hardness traverses across a seam weld (Figure 33) illustrate almost no change in indentation hardness through base metal, heat affected zone, and weld metal. This seems reasonable as R.S. Ryan indicates that the seam welds were performed during pipe fabrication and the welded pipe was heat treated following welding. Though there is not variation across the weld, the base metal hardness is approximately 325 HK, which is consistent with the original data from R.S. Ryan. Based on the base metal adjacent to the seam weld(s), there was no significant degradation in hardness after long term exposure to natural gas and/or environmental elements.

The flat hardness curve across the seam weld corresponds well with the homogenous microstructure and grain size of the seam welds. The post-weld heat treatment likely homogenized the weld microstructure and subsequently the mechanical properties.

Unlike the seam welds, the pipe girth welds were performed on site during pipe installation and were not heat treated. Based on the seam weld traverse, the original R. S. Ryan data (Figure 1) appears to be from a non-heat-treated girth weld.

Vickers indentations were used to map the hardness across the entire cross section of girth welds. All tested girth welds (examples in Figure 30 and Figure 31) show an increase in hardness in the heat affected zone, especially adjacent to the weld cap. This is in addition to a reduction in hardness (relative to the base metal) directly between the heat affected zone and the base

metal. This is partially consistent with the data from the original publication, though R.S. Ryan reported that the heat affected zone was not harder than the weld metal.

Five Knoop indentation traverses were performed across girth welds to duplicate the measurement presented by R.S. Ryan. All girth weld hardness traverses (representative data in Figure 32) had some similarities with the R.S. Ryan, specifically the base metal and weld metal had approximately the same hardness and there is a notable reduction in hardness when traversing from base metal through the heat affected zone. In the modern measurements the heat affected zone is significantly harder than the base metal or weld metal. The hardness profile of Traverse 5 in Figure 32, which is near the center of the pipe thickness, is most like the R.S. Ryan hardness traverse.

When comparing the weld microstructure and the hardness trace(s), the increased hardness in the heat affected zone is correlated with the reduced grain size in the HAZ of the girth welds as illustrated in the SEM backscattered imaging in Figure 33.

Like other data presented in this report, the weld hardness traces are difficult to directly compare to the original R. S. Ryan data. Aside from the fact that the indentation load is not reported by R.S. Ryan, it is clear from Figure 32 that the exact position of the hardness traverse within the weld cross section has a significant impact on the hardness profile.

Lastly, an experimental atomic force microscopy (AFM) method called contact resonance was attempted to determine highly localized variation in the material elastic properties. Contact resonance AFM measures the mechanical properties by measuring the change in cantilever resonance frequency as the AFM tip interacts with the specimen. Unfortunately, there was not enough variation in local elastic properties to allow detection using CR-AFM.

4. Conclusions

Microstructural analysis and chemical analysis, including optical emission spectroscopy, optical imaging, backscatter electron imaging, and electron backscatter diffraction was performed on all provided pipe sections. The main conclusions of the microstructural analysis are the following.

1. Chemical composition was inconsistent between the seven distinct pipe sections. It is possible that each pipe section is a different experimental material.
2. All base metal pipe sections displayed a bainite-ferrite microstructure.
3. Reduced grain size was observed at the inner and outer surfaces of pipe in cross sectional microstructural imaging.
4. Annealed seam welds displayed little difference in microstructure between the base metal, weld, and heat affected zone.
5. Unannealed girth welds illustrated a significant reduction in grain size within the heat affected zone.

Circumferential tension tests on full thickness flattened strap tensile specimens were performed on pipe body base metal and seam welds. The main remarks emerging from the results obtained are the following.

1. Test methods used to evaluate the steel line pipe prior to installation in the 1960's are similar to current standards in their method, but advances of instrumentation and data acquisition make direct comparisons challenging with uncertainties from the 1960's being the largest factor.
2. The lack of construction and test data prior to putting the pipes into service make it impossible to determine if the pipes experienced any time-history effects on the tensile properties.
3. The vintage X100 steel line pipe would satisfy the current API 5L minimum tensile requirements for X100Q steel line pipe, with minor notable caveats related to potential testing errors associated with small sample sizes.
4. Circumferential tensile properties of this vintage X100 steel line pipe are in alignment with the tensile properties and performance of modern X100 steel.

Instrumented Charpy tests on third-size specimens ($B = 3.3$ mm, $W = 10$ mm) were performed on base metals in L and T orientations, as well as on weld metals and heat affected zones of seam and girth welds. The main observations emerging from the results obtained are the following.

1. Based on absorbed energy transition curves obtained for longitudinal specimens, the least tough pipe sections are P1S1 and P2S2 (highest *DBTT* and lowest *USE*). The toughest pipes/sections are P3S1 and P3S2 (lowest *DBTT* and highest *USE*), noting that those are an X60 grade pipe.
2. For the base metals in T direction, tests were performed at 0 °C. Considering the API 5L requirements on absorbed energy for specimens extracted in the 90° clock position, none of the pipes satisfies the requirement based on the average absorbed energy,

while only 1 out of 20 specimens tested exceeds the minimum KV required (14 J) by the API specification.

3. For the seam weld metals and HAZ tested at 0 °C, the API 5L requirement on the mean absorbed energy was only met by one HAZ sample. The requirement on the minimum KV of an individual test was satisfied by just 6 specimens out of 33 tested, all from HAZ material.
4. There are no requirements in API 5L for the girth weld metals and HAZ. The results obtained at 0 °C consistently show higher impact toughness than seam welds.

Micro-indentation (Vickers and Knoop) and instrumented nano-indentation was performed on base metal, seam welds, and girth welds to duplicate data in the original R.S. Ryan paper and determine if any inhomogeneous degradation was present in the steels. The main conclusions of the indentation analysis are the following.

1. Knoop hardness made on base metal specimens showed no significant variation in hardness through the thickness of any pipe section.
2. Vickers hardness maps and Knoop hardness traces across girth welds showed an increase in hardness across the heat affected zone. This finding differs from the original results presented by R.S. Ryan, but it is evident that the location of the hardness trace within the girth weld cross section will significantly impact the hardness profile.
3. Knoop hardness traces across seam welds showed no significant variation in hardness between base metal, heat affected zone, and weld metal.
4. Nano-indentation illustrated a minor decrease in the indentation hardness near the internal pipe surface, but no significant change in elastic modulus.

References

- [1] T. Weeks, D. McColskey, and M. Richards, "Weld Design, Testing, and Assessment Procedures for High-strength Pipelines Curved Wide Plate Tests," Summary Report 277-s-01, 2011.
- [2] API SPEC 5L, "Line Pipe," *American Petroleum Institute*, no. 46th Edition, 2018, [Online]. Available: <https://www.api.org/products-and-services/standards/important-standards-announcements/standard-5l>
- [3] R. S. Ryan, "First X-100 line pipe tested by Columbia Gas," *The Oil and Gas Journal*, no. June, pp. 92–96, 1965.
- [4] M. Witek, "Possibilities of using X80, X100, X120 high-strength steels for onshore gas transmission pipelines," *Journal of Natural Gas Science and Engineering*, vol. 27, pp. 374–384, Nov. 2015, doi: 10.1016/j.jngse.2015.08.074.

- [5] S. K. Sharma and S. Maheshwari, "A review on welding of high strength oil and gas pipeline steels," *Journal of Natural Gas Science and Engineering*, vol. 38, pp. 203–217, Feb. 2017, doi: 10.1016/j.jngse.2016.12.039.
- [6] G. Demofonti, G. Mannucci, C. M. Spinelli, and L. Barsanti, "Large Diameter X100 Gas Line pipes: Fracture Propagation Evaluation by Full-Scale Burst Test," *Pipeline Technology*, vol. 1, pp. 509–520, 2000.
- [7] G. Demofonti, G. Mannucci, H. G. Hillenbrand, and D. Harris, "Evaluation of the Suitability of X100 Steel Pipes for High Pressure Gas Transportation Pipelines by Full Scale Tests," in *2004 International Pipeline Conference, Volumes 1, 2, and 3*, Calgary, Alberta, Canada: ASME/EDC, Jan. 2004, pp. 1685–1692. doi: 10.1115/IPC2004-0145.
- [8] G. Mannucci and D. Harris, "Fracture properties of API X 100 gas pipeline steels," European Commission Directorate-General Research, Belgium, Technical Steel Research EUR 20330 EN, 2000.
- [9] J. Besson, Y. Shinohara, T. F. Morgeneyer, and Y. Madi, "Effect of prestrain on ductility of a X100 pipeline steel," *ECF*, vol. 17, 2008, [Online]. Available: <https://hal.science/hal-00329777>
- [10] J. M. Treinen, W. E. Luecke, J. D. McColskey, P. P. Darcis, and Y.-Y. Wang, "Anisotropic Behavior of X100 Pipeline Steel," *ISOPE-2008-700*, 2008.
- [11] J. Besson, Y. Shinohara, T. F. Morgeneyer, and Y. Madi, "Ductile rupture of prestrained X100 pipeline steel sheets," *ECF*, vol. 18, 2010, [Online]. Available: <https://minesparis-psl.hal.science/hal-00541106>
- [12] X. Wu, "Strain-aging Behavior of X100 Line-pipe Steel for a Long-term Pipeline-service Condition," Master's Thesis, University of Calgary, 2010.
- [13] W. Zhao, M. Chen, S. Chen, and J. Qu, "Static strain aging behavior of an X100 pipeline steel," *Materials Science and Engineering: A*, vol. 550, pp. 418–422, Jul. 2012, doi: 10.1016/j.msea.2012.04.095.
- [14] G. Liang, X. Peng, E. S. Juan, and Y. F. Cheng, "Strain Aging of X100 Steel in Service and the Enhanced Susceptibility of Pipelines to Stress Corrosion Cracking," *J. of Materi Eng and Perform*, vol. 22, no. 12, pp. 3778–3782, Dec. 2013, doi: 10.1007/s11665-013-0683-z.
- [15] M. A. Arafin and J. A. Szpunar, "Effect of bainitic microstructure on the susceptibility of pipeline steels to hydrogen induced cracking," *Materials Science and Engineering: A*, vol. 528, no. 15, pp. 4927–4940, Jun. 2011, doi: 10.1016/j.msea.2011.03.036.
- [16] H. M. Ha, I. M. Gadala, and A. Alfantazi, "Hydrogen Evolution and Absorption in an API X100 Line Pipe Steel Exposed to Near-Neutral pH Solutions," *Electrochimica Acta*, vol. 204, pp. 18–30, Jun. 2016, doi: 10.1016/j.electacta.2016.03.167.
- [17] B. P. Somerday and P. Sofronis, Eds., "Hydrogen-Accelerated Fatigue Crack Growth in Arc Welded X100 Pipeline Steel," in *International Hydrogen Conference (IHC 2016): Materials Performance in Hydrogen Environments*, ASME Press, 2017, pp. 219–227. doi: 10.1115/1.861387_ch23.
- [18] R. Khatib Zadeh Davani, M. Mohtadi-Bonab, S. Yadav, E. Entezari, J. Cabezas, and J. Szpunar, "Effect of Quench Tempering on Hydrogen Embrittlement and Corrosion Behavior of X100 Pipeline Steel," *Metals*, vol. 13, no. 5, p. 841, Apr. 2023, doi: 10.3390/met13050841.

- [19] A. Mustapha, E. A. Charles, and D. Hardie, "Evaluation of environment-assisted cracking susceptibility of a grade X100 pipeline steel," *Corrosion Science*, vol. 54, pp. 5–9, Jan. 2012, doi: 10.1016/j.corsci.2011.08.030.
- [20] H. Liang, J. Liu, A. Alfantazi, and E. Asselin, "Corrosion behaviour of X100 pipeline steel under a salty droplet covered by simulated diluted bitumen," *Materials Letters*, vol. 222, pp. 196–199, Jul. 2018, doi: 10.1016/j.matlet.2018.03.168.
- [21] Y. Chen, Z. Wang, X. Wang, X. Song, and C. Xu, "Cathodic Protection of X100 Pipeline Steel in Simulated Soil Solution," *International Journal of Electrochemical Science*, vol. 13, no. 10, pp. 9642–9653, Oct. 2018, doi: 10.20964/2018.10.23.
- [22] J. Zhao, D. Xiong, Y. Gu, Q. Zeng, and B. Tian, "A comparative study on the corrosion behaviors of X100 steel in simulated oilfield brines under the static and dynamic conditions," *Journal of Petroleum Science and Engineering*, vol. 173, pp. 1109–1120, Feb. 2019, doi: 10.1016/j.petrol.2018.10.072.
- [23] L. Gan, F. Huang, X. Zhao, J. Liu, and Y. F. Cheng, "Hydrogen trapping and hydrogen induced cracking of welded X100 pipeline steel in H₂S environments," *International Journal of Hydrogen Energy*, vol. 43, no. 4, pp. 2293–2306, Jan. 2018, doi: 10.1016/j.ijhydene.2017.11.155.
- [24] X. Yang, T. Hao, Q. Sun, Z. Zhang, and Y. Lin, "The Corrosion Behavior of X100 Pipeline Steel in a Sodium Chloride Solution Containing Magnesium and Calcium," *Materials*, vol. 16, no. 15, p. 5258, Jul. 2023, doi: 10.3390/ma16155258.
- [25] R. Ghajar, G. Mirone, and A. Keshavarz, "Ductile failure of X100 pipeline steel – Experiments and fractography," *Materials & Design*, vol. 43, pp. 513–525, Jan. 2013, doi: 10.1016/j.matdes.2012.07.032.
- [26] J. W. Sowards, C. N. McCowan, and E. S. Drexler, "Interpretation and significance of reverse chevron-shaped markings on fracture surfaces of API X100 pipeline steels," *Materials Science and Engineering: A*, vol. 551, pp. 140–148, Aug. 2012, doi: 10.1016/j.msea.2012.04.108.
- [27] Y. X. Tian, B. Wang, J. L. Li, B. L. Chen, and Q. Feng, "Microstructure and Properties of X100 High Strength Pipeline Steel," *MSF*, vol. 814, pp. 325–332, Mar. 2015, doi: 10.4028/www.scientific.net/MSF.814.325.
- [28] S. Nafisi, M. A. Arafin, L. Collins, and J. Szpunar, "Texture and mechanical properties of API X100 steel manufactured under various thermomechanical cycles," *Materials Science and Engineering: A*, vol. 531, pp. 2–11, Jan. 2012, doi: 10.1016/j.msea.2011.09.072.
- [29] D. H. Lee *et al.*, "Effects of Start and Finish Cooling Temperatures on the Yield Strength and Uniform Elongation of Strain-Based API X100 Pipeline Steels," *Metall Mater Trans A*, vol. 49, no. 10, pp. 4536–4543, Oct. 2018, doi: 10.1007/s11661-018-4738-5.
- [30] X. Ye *et al.*, "Microstructure Characterization and Strengthening Mechanism Analysis of X100 Pipeline Steel," *Coatings*, vol. 13, no. 4, p. 706, Mar. 2023, doi: 10.3390/coatings13040706.
- [31] X.-L. Yang, Y.-B. Xu, X.-D. Tan, and D. Wu, "Relationships among crystallographic texture, fracture behavior and Charpy impact toughness in API X100 pipeline steel," *Materials Science and Engineering: A*, vol. 641, pp. 96–106, Aug. 2015, doi: 10.1016/j.msea.2015.06.029.

- [32] M. A. Quintana, "Development of Optimized Welding Solutions for X100 Line Pipe Steel," The Lincoln Electric Company, Summary Report 278-S-01, 2011. [Online]. Available: <https://rosap.nrl.bts.gov/view/dot/34620>
- [33] P. Y. Wang and Z. Y. Mou, "Study on the Weldability of X100 Pipeline Steel on Scene," *AMR*, vol. 753–755, pp. 343–352, Aug. 2013, doi: 10.4028/www.scientific.net/AMR.753-755.343.
- [34] X. Li, X. Ma, S. V. Subramanian, and C. Shang, "EBSD characterization of secondary microcracks in the heat affected zone of a X100 pipeline steel weld joint," *Int J Fract*, vol. 193, no. 2, pp. 131–139, Jun. 2015, doi: 10.1007/s10704-015-0024-3.
- [35] X. Li, X. Ma, S. V. Subramanian, R. D. K. Misra, and C. Shang, "Structure–Property–Fracture Mechanism Correlation in Heat-Affected Zone of X100 Ferrite–Bainite Pipeline Steel," *Metallurgical and Materials Transactions E*, vol. 2, no. 1, pp. 1–11, Mar. 2015, doi: 10.1007/s40553-014-0036-3.
- [36] H. B. Cui, G. M. Xie, Z. A. Luo, J. Ma, G. D. Wang, and R. D. K. Misra, "The microstructural evolution and impact toughness of nugget zone in friction stir welded X100 pipeline steel," *Journal of Alloys and Compounds*, vol. 681, pp. 426–433, Oct. 2016, doi: 10.1016/j.jallcom.2016.03.299.
- [37] R. J. Eiber, A. R. Duffy, and G. M. McClURE, "Recent Developments in the Evaluation of Fracture Toughness of Line Pipe," in *Fracture Toughness*, 1965, pp. 445–469.
- [38] Thompson and Lawson, "L51691 Fracture Control Technology for Natural Gas Pipelines," Pipeline Research Council International, Inc. (PRCI), Chantilly, Virginia, Pages 203, Dec. 1993. doi: 10.55274/R0011368.
- [39] G. M. McClure, R. J. Eiber, and A. R. Duffy, "Full-Scale Fracture Characteristics of Line Pipe and Correlation with Laboratory Tests," *Pipeline Research Council International*, vol. NG-18-10-R01, p. 122, 1963, doi: <https://doi.org/10.55274/R0012031>.
- [40] E. B. Clark, B. N. Leis, and R. J. Eiber, "Integrity Characteristics of Vintage Pipelines," Battelle Memorial Institute, Final Report F-2002--50435, 2005. [Online]. Available: <https://www.phmsa.dot.gov/pipeline/gas-transmission-integrity-management/integrity-characteristics-vintage-pipelines>
- [41] ASTM E415, *Test Method for Analysis of Carbon and Low-Alloy Steel by Spark Atomic Emission Spectrometry*, 2021. doi: 10.1520/E0415-21.
- [42] ASTM E23, *Test Methods for Notched Bar Impact Testing of Metallic Materials*, 2024. doi: 10.1520/E0023-24.
- [43] A. Edelstein, N. Amodaj, K. Hoover, R. Vale, and N. Stuurman, "Computer Control of Microscopes Using μ Manager," *Current Protocols in Molecular Biology*, vol. 92, no. 1, p. 14.20.1-14.20.17, 2010, doi: <https://doi.org/10.1002/0471142727.mb1420s92>.
- [44] E. Lucon, M. L. Martin, B. L. Calvo, X. Chen, and M. A. Sokolov, "Assessment of Different Approaches for Measuring Shear Fracture Appearance in Charpy Tests," *Journal of Testing and Evaluation*, vol. 51, no. 5, pp. 2833–2846, 2023, doi: <https://doi.org/10.1520/JTE20220691>.
- [45] A. A. Gazder, F. Al-Harbi, H. Th. Spanke, D. R. G. Mitchell, and E. V. Pereloma, "A correlative approach to segmenting phases and ferrite morphologies in transformation-induced plasticity steel using electron back-scattering diffraction and energy dispersive X-

ray spectroscopy," *Ultramicroscopy*, vol. 147, pp. 114–132, Dec. 2014, doi: 10.1016/j.ultramic.2014.07.005.

- [46] M.-S. Baek, K.-S. Kim, T.-W. Park, J. Ham, and K.-A. Lee, "Quantitative phase analysis of martensite-bainite steel using EBSD and its microstructure, tensile and high-cycle fatigue behaviors," *Materials Science and Engineering: A*, vol. 785, p. 139375, May 2020, doi: 10.1016/j.msea.2020.139375.
- [47] G. Wang *et al.*, "The Evolution and Distribution of Microstructures in High-Energy Laser-Welded X100 Pipeline Steel," *Materials*, vol. 12, no. 11, p. 1762, May 2019, doi: 10.3390/ma12111762.
- [48] R. J. Devaney, P. E. O'Donoghue, and S. B. Leen, "Effect of welding on microstructure and mechanical response of X100Q bainitic steel through nanoindentation, tensile, cyclic plasticity and fatigue characterisation," *Materials Science and Engineering: A*, vol. 804, p. 140728, Feb. 2021, doi: 10.1016/j.msea.2020.140728.

Appendix A. Historical Pipeline Documents

Subject _____

Classified By _____
(Initials)

Retention Period _____

Date Received _____

Verified By _____
(Initials)

Reference **December 2, 1964**

Destruction Date _____

Mr. C. F. Brisley

Mr. Leo J. Payne

36" X-100, .250 Wall Experimental Line

On November 25, 1964, 1193' of 36", X-100, .250 Wall experimental pipe was laid east of Petersburg Valve parallel to our 26" Line WB Loop. This line was subjected to a hydrostatic test at 1183.5# psi. for a period of 14 hours. On November 30, 1964 this line was loaded through a 2" connection to 26" Line WB Loop and will float with line pressure.

A copy of the attached charts and Pipelines and Mains Test Data were mailed to Logan Wallingford at Columbus, Ohio.

Leo J. Payne

Attachments


cc: Logan Wallingford

W. P. Diehl, Jr.

PIPELINES AND MAINS TEST DATA

COMPANY Atlantic Seaboard Corporation			DATE November 27, 1964		
STATE West Virginia		DIVISION Elkins		DISTRICT Petersburg	
LINE NUMBER Line WB-5			ACCOUNT OR WORK ORDER NUMBER 186-1-1-879 Installing Research Pipe - Acct. No. /		
PIPE DATA					
1	PIPE SIZE, NOM. O. D. 36"	LENGTH, FT. 1193	MILES .26		
2	WALL THICKNESS - INS. .250	GRADE X-100	MINIMUM SPECIFIED YIELD STRENGTH 100,000		
3	MANUFACTURER U. S. Steel	PURCHASE ORDER NO.		DATE	
4	TYPE OF LONGITUDINAL SEAM, IF ANY Submerged Arc Welded				
5	COLD EXPANDED Yes	MILL INSPECTED BY			
DESIGN DATA					
6	CONSTRUCTION TYPE "F" .72				
7	LONGITUDINAL JOINT FACTOR "E" 1.00				
8	TEMPERATURE DERATING FACTOR "T" 1.00				
9	DESIGN PRESSURE 1000 PSIG	(See Approved Procedure No. 95, System Standard Policy for Piping Design Pressure)			
PROOF TEST DATA					DATE OF PROOF TEST Nov. 25, 1964
10	LOCATION CLASS Class 1	TEST MEDIUM Water			
11	TEST PRESSURE Minimum 1183.5 PSIG	DURATION OF TEST 14 HOURS			
WITNESSED BY:		CONTRACTOR		COMPANY <i>W.P. Dick, Jr.</i>	
TEST ACCEPTED BY:					
LEAKAGE TEST DATA (See Form No. G - 10412)					DATE OF LEAKAGE TEST
12	TEST MEDIUM	TEST PRESSURE PSIG			
13	LENGTH OF TEST	PRESSURE LOSS PSIG			
14	CALCULATED LEAKAGE, CUBIC FEET LOSS PER MILE OF EQUIVALENT 3" AT 100 PSIG				CU. FT.
WITNESSED BY:		CONTRACTOR		COMPANY	
TEST ACCEPTED BY:					

NOTE: If the line falls into more than one Construction Type (excepting road, railroad crossings, fabricated assemblies, spans, .) complete separate sheet for each type.





STATION NAME

Hydrostatic Test on 1193 ft. of 36" x .250" X-100 pipe
Line WB-5, Experimental Sect.



FORM CSA-119

Average
Value

STATION NUMBER


CHART PERIOD		
MO.	DATE	HOUR
1964		
ENDING	Nov. 25	8 A.M.
BEGIN'G	Nov. 24	6 P.M.

CHART PLACED BY:

CHART REMOVED BY: *William P. DeWitt Jr.*

REMARKS: *Rain during Test Period*


Form ARC 408



Hunter Phantom Chair
THE FOXBORO COMPANY
798494
U.S.A.
MASS.
FOXBORO

FOXBORO BACK PRINTING NO. 1781

TO BE FILLED OUT WHEN CHART IS PLACED	STATION NUMBER <i>Hydrostatic Test on 1193 ft of 36" x 250;</i> STATION NAME <i>X-100 pipe - Line WB-5 Experimental Section</i> CHART ON <i>Nov. 24, 1964</i> AT <i>6:00 P.M.</i> SIGNED <i>Rain during test period</i>
TO BE FILLED OUT WHEN CHART IS REMOVED	CHART OFF <i>Nov. 25, 1964</i> AT <i>8:00 A.M.</i> REMARKS <i>Pressure pump and gauges located at low end of section. 82 ft diff. in elevation to high point resulting in minimum test pressure of 1183.5 psi.</i> SIGNED _____
OFFICE	AVERAGE _____ FACTOR _____ <i>William F. Dault, Jr.</i>



ARCCO
RECORDING CHARTS

METER ON OFF

LOCATION
F 0-120-12U
Los Angeles, California

Begin 7:10 P.M.
1/24-64

PRINTED



STATION NAME

Hydrostatic Test on 1193 Ft. of 36" x .250" X-100 pipe
Line MB-5, Experimental Sect.



FORM CS-117

Average Value

STATION NUMBER


CHART PERIOD			
ENDING	MO.	DATE	HOUR
1964	Nov.	25	8 A.M.
BEGIN'G	Nov.	24	6 P.M.

CHART PLACED BY:

CHART REMOVED BY: *William A. DeWitt*

REMARKS: *Rain during Test Period*

Form ARC 608



TO BE FILLED OUT WHEN CHART IS PLACED	STATION NUMBER <i>Hydrostatic Test on 1193 ft of 36" x 250"</i> STATION NAME <i>X-100 pipe - Line NB-5 Experimental Section</i> CHART ON <i>Nov. 24, 1964</i> AT <i>6:00 P.M.</i> SIGNED <i>None during test period</i>
TO BE FILLED OUT WHEN CHART IS REMOVED	CHART OFF <i>Nov. 25, 1964</i> AT <i>8:00 A.M.</i> REMARKS <i>Pressure pump and gauges located at low end of section. 82 ft diff. in elevation to high point resulting in minimum test pressure of 1183.5 psi.</i> SIGNED
OFFICE	AVERAGE _____ FACTOR _____ <i>William P. Swell, Jr.</i>

File - X-100

VISITORS TO ATLANTIC SEABOARD CORPORATION'S
36" X-100 EXPERIMENTAL LINE

<u>NAME</u>	<u>COMPANY</u>
Sy Orlofsky	Columbia Gas System Service Corporation
Robert S. Ryan	Columbia Gas System Service Corporation
R. C. Wolfe	Columbia Gas System Service Corporation
Edward Dzubak	Columbia Gas System Service Corporation
Donald R. Feltz	Columbia Gas System Service Corporation
Donald A. Benjamin	Columbia Gas System Service Corporation
Daniel J. Coffee	Manufacturers Light and Heat Company
D. D. Defibaugh	Manufacturers Light and Heat Company
J. Norman Bossert	Manufacturers Light and Heat Company
Arthur L. Towne	Manufacturers Light and Heat Company
T. T. Greene	Columbia Gulf
Glenn Tollerene	Columbia Gulf
George Eichenberger	Ohio Fuel Gas Company
Wade Gwinn	Ohio Fuel Gas Company
Boyd Shaw	Ohio Fuel Gas Company
Stanley Harward	Ohio Fuel Gas Company
W. W. Ferrell	United Fuel Gas Company
Ira Good	United Fuel Gas Company
C. P. Brisley	United Fuel Gas Company
Jack G. Brown	United Fuel Gas Company
N. A. Rupe	United Fuel Gas Company
J. Frank Dickerson	United Fuel Gas Company
Camden Garrett	United Fuel Gas Company
Donald C. White	United Fuel Gas Company
R. P. Ballard	United Fuel Gas Company

<u>NAME</u>	<u>COMPANY</u>
Robert L. Morris	United Fuel Gas Company
Bill E. Sebok	United Fuel Gas Company
Jon O. Loker	United Fuel Gas Company
Byron E. Ashley	United Fuel Gas Company
W. Lynn Dolly	United Fuel Gas Company
Jimmy E. Sligh	Kentucky Gas Transmission Corp.
Forrest H. Smith	Kentucky Gas Transmission Corp.
Leo J. Payne	Atlantic Seaboard Corporation
H. C. Arthur	Atlantic Seaboard Corporation
R. E. Lynn	Atlantic Seaboard Corporation
William H. Isner	Atlantic Seaboard Corporation
P. O. Hamer	Atlantic Seaboard Corporation
H. C. Mefford, Jr.	Atlantic Seaboard Corporation
E. F. Hepler	Atlantic Seaboard Corporation
P. J. Smith	Atlantic Seaboard Corporation
Bob Collett	Atlantic Seaboard Corporation
Lloyd Ulrich	Atlantic Seaboard Corporation
H. W. Morris	Atlantic Seaboard Corporation
G. G. Gum	Atlantic Seaboard Corporation
W. J. Fridley	Atlantic Seaboard Corporation
C. G. Simmons	Atlantic Seaboard Corporation
Kenneth Wright	Atlantic Seaboard Corporation
M. J. Walton	Atlantic Seaboard Corporation
F. C. Gum	Atlantic Seaboard Corporation
L. D. Goad	Atlantic Seaboard Corporation
Frank Pangle	Atlantic Seaboard Corporation

<u>NAME</u>	<u>COMPANY</u>
John Hinkle	Atlantic Seaboard Corporation
Austin Strawderman	Atlantic Seaboard Corporation
Marvin Sager	Atlantic Seaboard Corporation
E. D. Kesner	Atlantic Seaboard Corporation
John Hardy	Atlantic Seaboard Corporation
L. L. Miller, Jr.	Atlantic Seaboard Corporation
C. F. Ritenour	Atlantic Seaboard Corporation
Richard Ambrose	Atlantic Seaboard Corporation
Snowden Alt	Atlantic Seaboard Corporation
Bernie Rome	American Machine Foundry
Hal Gould	American Machine Foundry
Gordon Buck	American Machine Foundry
Chuck Wald	American Machine Foundry
Harry Burdett	American Machine Foundry
Earl Tice	Thomas Contractors
Paul Dion	Thomas Contractors
Kelsey Jones	Thomas Contractors
David Gerould	Croise-Perrault
Tom Morgan	Croise-Perrault
Ben Montgomery	Croise-Perrault
Cliff Hunt	Croise-Perrault
Roger Jones	U. S. Steel
Jaye Gamble	U. S. Steel
Bill Marner	Linde
George Palmer	Hobart
Bill Heineman	United Gas Company
Robert Cunningham	United Gas Company

T. S. Tilford	United Gas Company
William Hitchcock	Texas Eastern Gas Company
Art Bradfield	Southern California Gas Company
Sam Nettles	Consolidated X-Ray
Carl Winters	Wilson Welding Supply
Dale Smith	Washington Gas & Light
Bill Graham	Washington Gas & Light
Ike Goodwin	Washington Gas & Light
Joe Chapman	Crutcher-Rolf-Cummins
E. G. Summers	General Pipeline Construction, Inc.
Herb Wilson	General Pipeline Construction, Inc.
George Campbell	Helicopter Patrol, Inc.
H. A. Sosnin	Piping Consultant
Robert Scarborough	Federal Power Commission
Lou Sache	Federal Power Commission
Lou Mendonsa	Federal Power Commission
Fred Cornelius	Federal Power Commission
Ray Beirne	Federal Power Commission
Ron Prehoda	Federal Power Commission

WORKERS ON ATLANTIC SEABOARD CORPORATION'S
36" X-100 EXPERIMENTAL LINE

<u>NAME</u>	<u>COMPANY</u>
Logan Wallingford	Columbia Gas System Service Corporation
Richard B. Gwin	Columbia Gas System Service Corporation
Bruce L. Hutt	Columbia Gas System Service Corporation
Claude W. Churchheus	Columbia Gas System Service Corporation
Marion Bailey	Kentucky Gas Transmission
Paul B. Poliskey	United Fuel Gas Company
Roger L. Young	United Fuel Gas Company
Ross V. Carper	United Fuel Gas Company
W. P. Diehl, Jr.	Atlantic Seaboard Corporation
T. E. Dean	Atlantic Seaboard Corporation
Henry A. Dean	Atlantic Seaboard Corporation
B. C. Richard	Atlantic Seaboard Corporation
Merle Foudray	Pipeline Maintenance & Construction

COLUMBIA GAS SYSTEM
FACILITY FAILURE REPORT
 (CONFIDENTIAL DATA)

COMPANY Atlantic Seaboard Corporation

DEPARTMENT Transmission

TYPE OF FACILITY THAT FAILED: (PIPE, VALVE, POWER ROD, REGULATOR, FITTING, ETC.)	DATE OF FAILURE 6-2-67	LOCATION OF FAILURE	COUNTY Grant	STATE W. Va.
FAILURE OCCURRED AT <input type="checkbox"/> ROAD CROSSING <input type="checkbox"/> BUSINESS DISTRICT <input type="checkbox"/> RESIDENTIAL AREA <input checked="" type="checkbox"/> OTHER Pasture				
DESCRIBE FAILURE INCLUDING ANY PECULIARITIES OR DEFECTS IN FAILED PARTS, CORROSION, EVIDENCE OF PRIOR DAMAGE, PREVIOUS REPAIRS, ETC. ATTACH PHOTOGRAPHS OR DRAWINGS, IF POSSIBLE. INCLUDE SKETCH OF FAILURE IF PERTINENT. ATTACH ADDITIONAL SHEETS, IF NECESSARY, TO DESCRIBE FAILURE.				
<p>Failure occurred at 9 O'clock position looking East. Failure was adjacent to longitudinal seam in one joint for 65 in., then trailed off diagonally toward bottom of pipe for total length of 77 in. Failure sheared through girth field weld, then 31 in. into next joint and trailed off toward top of pipe through longitudinal seam at 11 O'clock position for total length in this joint of 41 in. Total length of failure was 118 in. This pipe coated with coal tar enamel and no evidence of corrosion in area of failure.</p>				
SOME TYPES OF FRACTURES HAVE CHARACTERISTIC "CHEVRON" OR "HERRINGBONE" MARKS THAT POINT TO THE FRACTURE ORIGIN. CAN ORIGIN OF FRACTURE BE LOCATED <input type="checkbox"/> YES <input type="checkbox"/> NO				
LOCATION OF FRACTURE ORIGIN				
CAUSE OF FAILURE				
WAS THE CAUSE OF FAILURE DEFINITELY ESTABLISHED <input type="checkbox"/> YES <input checked="" type="checkbox"/> NO		IF NOT, WERE ANY POSSIBLE CAUSES DISCOVERED <input checked="" type="checkbox"/> YES <input type="checkbox"/> NO		
DESCRIBE CAUSE OR POSSIBLE CAUSES				
<p>Possible cause discovered was longitudinal seam weld. The build-up of weld metal along seam weld was offset approximately 1/4" between inside and outside of pipe.</p>				
WHAT CAN BE DONE TO PREVENT FUTURE FAILURE OF THIS TYPE				
CIRCUMSTANCES				
INTERNAL PRESSURE AT POINT OF FAILURE 1350 PSIG		IF MECH. EQUIP., LOAD FACTOR AT TIME OF FAILURE		
LOCATION <input type="checkbox"/> ABOVE GROUND <input checked="" type="checkbox"/> BELOW GROUND		IF BELOW GROUND, DEPTH OF FILL 40 IN'S	TEMPERATURE OF PART AT TIME OF FAILURE Unknown	AMBIENT 65 °F
FAILURE WAS DUE TO <input type="checkbox"/> LEAK <input checked="" type="checkbox"/> BLOWOUT <input type="checkbox"/> OPERATING MECHANISM		FAILURE OCCURRED DURING <input type="checkbox"/> OPERATION <input checked="" type="checkbox"/> TEST		
DID FIRE OCCUR <input type="checkbox"/> YES <input checked="" type="checkbox"/> NO		OTHER IMPORTANT CIRCUMSTANCES		

HISTORY

DATE INSTALLED Nov. 1964	WAS THE FACILITY PROOF TESTED AFTER CONSTRUCTION <input checked="" type="checkbox"/> YES <input type="checkbox"/> NO	TYPE OF TEST <input checked="" type="checkbox"/> HYDRO-STATIC <input type="checkbox"/> GAS <input type="checkbox"/> OTHER
TEST PRESSURES	MAXIMUM 1225 PSIG MINIMUM 1183.5 PSIG	TIME HELD 14 hours A. M. P. M.
LATER TEST IN YEAR	TEST PRESSURES MAXIMUM PSIG MINIMUM PSIG	TIME HELD A. M. P. M.
FACILITY WAS BUILT	<input checked="" type="checkbox"/> IN ACCORDANCE WITH ASA B.31.1.8-1955 <input type="checkbox"/> PRIOR TO 1955 <input type="checkbox"/> OTHER CODE OR STANDARD	
DESIGN PRESSURE	CONSTRUCTION TYPE (OR DIVISION CLASS) ACCORDING TO CODE Type A	
REMARKS OR OTHER PERTINENT INFORMATION CONCERNING HISTORY		

SPECIFICATIONS OF MATERIAL

PIPE	SPECIFICATIONS (A.P.I., A.S.T.M., ETC.) API 5L-X	MANUFACTURER U. S. Steel	NOMINAL O. D. 36 IN'S	WALL THICKNESS .250 IN.
	MILL TEST PRESSURE Unknown PSIG	OR MANUFACTURER'S TEST		SPECIFIED MINIMUM YIELD STRENGTH 100,000 PSI
	TYPE <input type="checkbox"/> SEAMLESS <input type="checkbox"/> RESISTANCE WELDED <input type="checkbox"/> FLASH WELDED <input checked="" type="checkbox"/> DOUBLE SUBMERGED ARC WELDED <input type="checkbox"/> SINGLE SUBMERGED ARC WELDED <input type="checkbox"/> LAP WELDED <input checked="" type="checkbox"/> BUTT WELDED <input checked="" type="checkbox"/> EXPANDED <input type="checkbox"/> NONEXPANDED			
	OTHER DATA _____ _____			
FABRICATED FITTING OR ASSEMBLY	TYPE			
	<input type="checkbox"/> FIELD FABRICATED <input type="checkbox"/> MANUFACTURED		NAME OF MANUFACTURER	
	DESCRIPTION OR SPECIFICATION			
	MATERIAL			
OTHER DATA				
OPERATING MECHANISM OR EQUIPMENT	DESCRIPTION			
	NAME OF MANUFACTURER		MATERIAL	
	OTHER DATA			

DATE OF REPORT	6-6-67	PREPARED BY <i>W. P. Diehl, Jr.</i>
----------------	---------------	--

COLUMBIA GAS SYSTEM
FACILITY FAILURE REPORT
 (CONFIDENTIAL DATA)

COMPANY Atlantic Seaboard Corporation DEPARTMENT Transmission

TYPE OF FACILITY THAT FAILED: (PIPE, VALVE, POWER ROD, REGULATOR, FITTING, ETC.)		DATE OF FAILURE	LOCATION OF FAILURE	COUNTY	STATE
Pipe		6-8-67		Grant	W. Va.
FAILURE OCCURRED AT		<input type="checkbox"/> ROAD CROSSING <input type="checkbox"/> BUSINESS DISTRICT <input type="checkbox"/> RESIDENTIAL AREA <input checked="" type="checkbox"/> OTHER Pasture			
DESCRIBE FAILURE INCLUDING ANY PECULIARITIES OR DEFECTS IN FAILED PARTS, CORROSION, EVIDENCE OF PRIOR DAMAGE, PREVIOUS REPAIRS, ETC. ATTACH PHOTOGRAPHS OR DRAWINGS, IF POSSIBLE. INCLUDE SKETCH OF FAILURE IF PERTINENT. ATTACH ADDITIONAL SHEETS, IF NECESSARY, TO DESCRIBE FAILURE.					
<p style="text-align: center;">Failure occurred at the 9 o'clock position looking East. Failure was adjacent to the longitudinal seam and moved along the seam for approximately 4 feet in a Western direction until it hit a girth field weld where it ran around the heat affected zone of the weld shearing about 90 percent of the weld. The failure moved along the seam in an Eastern direction from the origin for about 3 feet and then trailed off diagonally toward the top of the pipe. Approximately 9 feet of pipe was effected by the failure. This pipe was coated with coal tar enamel and there was no evidence of corrosion in the area of failure.</p>					
SOME TYPES OF FRACTURES HAVE CHARACTERISTIC "CHEVRON" OR "HERRINGBONE" MARKS THAT POINT TO THE FRACTURE ORIGIN. CAN ORIGIN OF FRACTURE BE LOCATED					
<input type="checkbox"/> YES <input type="checkbox"/> NO					
LOCATION OF FRACTURE ORIGIN					
CAUSE OF FAILURE					
WAS THE CAUSE OF FAILURE DEFINITELY ESTABLISHED		IF NOT, WERE ANY POSSIBLE CAUSES DISCOVERED			
<input type="checkbox"/> YES <input type="checkbox"/> NO		<input type="checkbox"/> YES <input type="checkbox"/> NO			
DESCRIBE CAUSE OR POSSIBLE CAUSES					
<p style="text-align: center;">Possible cause discovered was longitudinal seam weld.</p>					
WHAT CAN BE DONE TO PREVENT FUTURE FAILURE OF THIS TYPE					
CIRCUMSTANCES					
INTERNAL PRESSURE AT POINT OF FAILURE		IF MECH. EQUIP., LOAD FACTOR AT TIME OF FAILURE			
1470 PSIG					
LOCATION	<input type="checkbox"/> ABOVE GROUND <input checked="" type="checkbox"/> BELOW GROUND	IF BELOW GROUND, DEPTH OF FILL	IN'S	TEMPERATURE OF PART AT TIME OF FAILURE	° F
FAILURE WAS DUE TO	<input type="checkbox"/> LEAK <input checked="" type="checkbox"/> BLOWOUT <input type="checkbox"/> OPERATING MECHANISM	FAILURE OCCURRED DURING		<input type="checkbox"/> OPERATION <input checked="" type="checkbox"/> TEST	
DID FIRE OCCUR	<input type="checkbox"/> YES <input checked="" type="checkbox"/> NO	OTHER IMPORTANT CIRCUMSTANCES			

HISTORY

DATE INSTALLED Nov. 1964	WAS THE FACILITY PROOF TESTED AFTER CONSTRUCTION <input checked="" type="checkbox"/> YES <input type="checkbox"/> NO	TYPE OF TEST <input checked="" type="checkbox"/> HYDRO-STATIC <input type="checkbox"/> GAS <input type="checkbox"/> OTHER		
TEST PRESSURES	MAXIMUM 1225 PSIG	MINIMUM 1183.5 PSIG	TIME HELD 14 Hours A. M. P. M.	MAXIMUM OPERATING PRESSURE 800 PSIG
LATER TEST IN YEAR	TEST PRESSURES	MAXIMUM PSIG	MINIMUM PSIG	TIME HELD A. M. P. M.
FACILITY WAS BUILT	<input checked="" type="checkbox"/> IN ACCORDANCE WITH ASA B.31.1.8-1955		<input type="checkbox"/> PRIOR TO 1955	<input type="checkbox"/> OTHER CODE OR STANDARD
DESIGN PRESSURE 1000 PSIG	CONSTRUCTION TYPE (OR DIVISION CLASS) ACCORDING TO CODE Type A			

REMARKS OR OTHER PERTINENT INFORMATION CONCERNING HISTORY


SPECIFICATIONS OF MATERIAL

PIPE	SPECIFICATIONS (A.P.I., A.S.T.M., ETC.) API 5L-X	MANUFACTURER U. S. Steel	NOMINAL O. D. 36 IN'S	WALL THICKNESS .250 IN.
	MILL TEST PRESSURE Unknown PSIG	OR MANUFACTURER'S TEST		SPECIFIED MINIMUM YIELD STRENGTH 100,000 PSI
	TYPE			
	<input type="checkbox"/> SEAMLESS <input type="checkbox"/> RESISTANCE WELDED <input type="checkbox"/> FLASH WELDED <input checked="" type="checkbox"/> DOUBLE SUBMERGED ARC WELDED <input type="checkbox"/> SINGLE SUBMERGED ARC WELDED <input type="checkbox"/> LAP WELDED <input checked="" type="checkbox"/> BUTT WELDED <input checked="" type="checkbox"/> EXPANDED <input type="checkbox"/> NONEXPANDED			
OTHER DATA				

FABRICATED FITTING OR ASSEMBLY	TYPE	
	<input type="checkbox"/> FIELD FABRICATED <input type="checkbox"/> MANUFACTURED	NAME OF MANUFACTURER
	DESCRIPTION OR SPECIFICATION	
	MATERIAL	
OTHER DATA		

OPERATING MECHANISM OR EQUIPMENT	DESCRIPTION	
	NAME OF MANUFACTURER	MATERIAL
	OTHER DATA	

DATE OF REPORT June 16, 1967	PREPARED BY <i>Douglas J. Wilson</i>
--	---



CROTCH
SECTION

weld location

Note: Mechanical Stress Relief Required Between end weld Pass


Dcw 7/19/65

ALT Δ	DESCRIPTION	DATE	BY
BONNEY FORGE and TOOL WORKS ALLENTOWN, PENNSYLVANIA			
TITLE <i>SPECIAL 36" (.500) X-60 X 6" (.432) WELDOLET</i>			
DR	MATERIAL		
CK	<i>A105-GR II (36,000 MIN. YIELD)</i>		
APP	HEAT TREATMENT	DWG. NO.	
	<i>7-2-65</i>	<i>109-06-010</i>	

DO NOT SCALE PRINT
DIMENSIONS ARE IN INCHES

SCALE
FULL

PROPOSED METHOD OF JOINING 36", X-60, .500 WALL PIPE TO 36", X-100, .250 WALL EXPERIMENTAL PIPE. TRANSITION MUST BE WELDED WITH MICROWIRE.



ATLANTIC SEABOARD CORPORATION

TIE-IN TO X-100 EXPERIMENTAL PIPE AT PETERSBURG.

SCALE 1/4" = 1'-0" REF.	
DATE	6-28-65
DRAWN	P.J.S.
CHK'D	
APP'D	
APP'D	
DWG. NO.	2527

Testing File

Subject _____

Classified By _____ (Initials)

Retention Period _____

Date Received _____

Verified By _____ (Initials)

June 22, 1967

Reference _____

Destruction Date _____

Mr. C. P. Brisley

Mr. J. Frank Dickerson

Hydrostatic Test - 36" Line WB-5

Atlantic Seaboard personnel have completed the hydrostatic testing of 36" Line WB-5 from Route 220 to the Moorefield Valve Setting. This is the section of 36" laid by Carl Smith in 1965 and includes the X-100 Experimental Pipe laid in 1964.

Due to elevation differences it was necessary to divide this portion of line into six test sections.

Attached copies of Pressure and Temperature Charts reflect the 24-Hour Test conditions for each section. In addition, a pressure sheet listing the deadweight readings and other pertinent test information is included.

The X-60, .438 Wall Pipe in Sections 1, 2, 4, 5, and 6 has a specified minimum yield of 1460 Psi. These sections were subjected to a maximum test pressure equal to 110% of SMYS or 1606 Psi. Section #3, which contained the 1185' of Experimental Pipe, was subjected to a maximum test pressure equal to 110% of the SMYS for X-100, .250 Wall Pipe or 1529 Psi. The minimum test pressure for all sections was 1.25 of the design pressure of 1000 Psi or 1250 Psi.

The original test sheets will remain on file at Dranesville.

There were no failures on the X-60, .438 wall pipe however two seam failures were encountered on the X-100, .250 Wall Experimental Pipe. Facility Failure Reports will follow under separate cover. Pipe Line and Mains Test Data Sheets for the 51,936 feet of X-60, .438 Wall and the 1185' of X-60, .250 Wall are forwarded for your disposition.

As a result of this test, 36" Line WB-5 from Route 220 to the Moorefield Valve is qualified for operation at 1000 Psi.

J. Frank Dickerson
Staff Engineer

- cc: R. E. Lynn
- Attachments:
- Pressure Charts (6)
 - Temperature Charts (6)
 - Pressure Sheets (6)
 - Pipe Line & Mains Test Data Sheets (2)

Test Section No. 6 - 36" Line WB-5

5,240 Ft. of 36", X-60, .438" Wall

Dead Weight Readings

<u>Time</u>	<u>Pressure</u>	<u>Remarks</u>
June 2, 1967		
6:25 P.M.	1470	
6:35	1607	36" Ball Valve at Moorefield Gate Setting Leaking
6:45	1600	
6:55	1596	
7:05	1595	
7:15	1593	
7:25	1593	
7:35	1592	Repressure
7:40	1607	
7:50	1607	
8:00	1605	
8:10	1605	
8:20	1604	
8:30	1602	
8:40	1601	
8:50	1601	
9:00	1601	
June 3, 1967		
8:00 A.M.	1588	
8:30	1588	
9:00	1588	
9:30	1588	
10:00	1588	
10:30	1588	
11:00	1588	
11:30	1588	
12:00	1579	
12:10	1579	
12:20	1579	
12:30	1579	
12:40	1579	
12:50	1579	
1:00 P.M.	1579	
1:30	1579	
2:00	1579	Repressure
2:10	1609	
2:20	1609	
2:30	1609	
2:40	1608	
2:50	1608	
3:00	1608	
3:10	1608	
3:30	1607	
4:00	1607	
4:30	1606	
5:00	1606	
5:30	1606	
6:00	1606	
6:30	1606	Test Off

Test Section No. 4 -- 36" Line WB-5
 7,000 Ft. of 36" Pipe, X-60, .438" Wall
 Dead Weight Readings:

<u>Time</u>	<u>Pressure</u>	<u>Remarks</u>
June 4, 1967		
9:45 A.M.	1070	Start Pressuring
10:00	1255	Test On
10:10	1251	
10:20	1250	
10:30	1249	
10:40	1248	
10:50	1247	
11:00	1247	
11:10	1246	
11:20	1246	
11:30	1246	
11:40	1246	
11:50	1246	
12:00	1245	
12:30	1245	
1:00 P.M.	1245	
1:30	1244	
2:00	1244	
2:30	1243	
3:00	1243	
3:30	1243	
3:55	1243	
4:30	1243	
5:00	1242	
6:00	1242	
7:00	1242	
8:00	1242	
June 5, 1967		
8:00 A.M.	1240	
9:00	1240	
10:00	1242	Test Off

Test Section No. 1 - 36" Line WB-5

7,000' of 36" Pipe, X-60, .438" Wall

Dead-weight readings:

<u>Time</u>	<u>Pressure</u>	<u>Remarks</u>
June 6, 1967		
4:28 pm	505	Start Pressuring
6:07	1606	Test on
6:17	1600	Small leak in bull plug, repaired (time 6:17 to 6:23)
6:27	1597	
6:37	1596	
6:47	1595	
6:57	1594	
7:07	1593	
7:30	1591	
8:00	1590	
June 8, 1967		
8:00 am	1582	1317# = 1582# because of difference in elevation
Moved to upper manifold -		
9:15	1317	
10:00	1317	
11:00	1317	
12:00	1317	
1:00 P.M.	1317	
2:00	1317	
3:00	1317	
4:00	1317	
5:00	1317	
6:07	1317	Test Off

Test Section No. 2 - 36" Line WB-5
 7,000' of 36" Pipe, X-60, .438" Wall

Dead-weight readings:

<u>Time</u>	<u>Pressure</u>	<u>Remarks</u>
June 7, 1967		
9:26 A.M.	1337	Start Pressuring
9:40	1532	Out of Water - Adjusted recording gage with dead weight
10:12	1529	Start Pressuring
10:20	1605	Test On
10:30	1601	
10:40	1600	
10:50	1599	
11:00	1599	
11:10	1599	
11:20	1599	
11:30	1599	
12:00	1597	
1:00 P.M.	1597	Slight leak in 2" Valve
2:00	1595	
3:00	1594	
4:00	1593	
5:00	1593	
6:00	1593	
June 8, 1967		
8:00 A.M.	1593	
9:00	1593	
10:00	1593	
10:20	1593	Test Off

Test Section No. 3 - 36" Line WB-5

1,185 ft. of 36" Pipe, X-100, .250" Wall

10,015 ft. of 36" Pipe, X-60, .438" Wall

Dead-weight readings:

<u>Time</u>	<u>Pressure</u>	<u>Remarks</u>
June 13, 1967		
8:22 A.M.	473	Starting Pressure
10:08	953	Stop Pressuring
10:23	953	Started Pressuring
11:33	1486	Test on
11:43	1481	
11:53	1478	
12:03	1478	
12:13	1476	
12:23	1475	
12:33	1475	
1:00 P.M.	1475	
1:30	1473	Slight Leak In Dead Weight
2:00	1472	
2:30	1471	
3:00	1471	
3:30	1470	
4:00	1470	
4:00 to 4:20		Working on Dead Weight
4:20	1469	
4:30	1469	
5:00	1469	
5:30	1469	
6:00	1469	
6:05	1469	Start Repressure
6:08	1486	End Repressure
6:18	1484	
6:28	1484	
6:38	1484	
6:48	1484	
6:58	1484	
7:08	1484	
June 14, 1967		
8:00 A.M.	1478	
9:00	1478	
10:00	1478	
11:00	1478	
11:33	1478	Test Off

Hydrostatic test of 1,185 ft. of 36" pipe, X-100, .250" wall and 10,095 ft. of 36" pipe, X-60, .438" wall. (Line WB-5) Test pressure at dead-weight location 1486. Date of Test - June 13, 1967.

<u>Dead-weight Pressure</u>	<u>Pump Stroke Counter</u>	<u>No. of Pump Strokes</u>
1100	5704	
1110	6056	352
1120	6378	322
1130	6710	332
1140	7041	331
1150	7384	343
1160	7707	323
1170	8031	324
1180	8345	314
1190	8655	310
1200	8983	328
1210	9289	306
1220	9601	312
1230	9907	306
1240	10210	303
1250	10507	297
1260	10820	313
1270	11107	287
1280	11402	295
1290	11691	289
1300	11990	299
1310	12277	287
1320	12570	293
1330	12849	279
1340	13143	294
1350	13478	335
1360	13720	242
1370	13998	278
1380	14258	260
1390	14556	298
1400	14839	283
1410	15116	277
1420	15381	265
1430	15661	280
1440	15949	288
1450	16201	252
1460	16507	306
1470	16771	264
1480	17044	273
1486	17135	91

PIPELINES AND MAINS TEST DATA


COMPANY Atlantic Seaboard Corporation			DATE June 16, 1967		
STATE W. Va.		DIVISION Elkins		DISTRICT Petersburg	
LINE NUMBER 36" Line WB-5			ACCOUNT OR WORK ORDER NUMBER ASC Budget 3505 W.O. 359-21		
PIPE DATA					
1	PIPE SIZE, NOM. O. D. 36"	LENGTH, FT. 1,185		MILES 0.224	
2	WALL THICKNESS - INS. .250	GRADE X-100		MINIMUM SPECIFIED YIELD STRENGTH 100,000 PSI	
3	MANUFACTURER U. S. Steel		PURCHASE ORDER NO. C-21233		DATE June 25, 1964
4	TYPE OF LONGITUDINAL SEAM, IF ANY Double Submerged Arc Welded				
5	COLD EXPANDED Yes		MILL INSPECTED BY		
DESIGN DATA					
6	CONSTRUCTION TYPE "F" .72				
7	LONGITUDINAL JOINT FACTOR "E" 1.00				
8	TEMPERATURE DERATING FACTOR "T" 1.00				
9	DESIGN PRESSURE 1000	PSIG (See Approved Procedure No. 95, System Standard Policy for Piping Design Pressure)			
PROOF TEST DATA				DATE OF PROOF TEST June 13 & 14, 1967	
10	LOCATION CLASS 1		TEST MEDIUM Water		
11	TEST PRESSURE 1529		DURATION OF TEST 24		HOURS
WITNESSED BY:		CONTRACTOR		COMPANY <i>Douglas J. Wilson</i>	
TEST ACCEPTED BY: <i>Frank Dickson</i>					
LEAKAGE TEST DATA (See Form No. G - 10412)				DATE OF LEAKAGE TEST	
12	TEST MEDIUM		TEST PRESSURE		PSIG
13	LENGTH OF TEST		PRESSURE LOSS		PSIG
14	CALCULATED LEAKAGE, CUBIC FEET LOSS PER MILE OF EQUIVALENT 3" AT 100 PSIG				CU. FT.
WITNESSED BY:		CONTRACTOR		COMPANY	
TEST ACCEPTED BY:					

NOTE: If the line falls into more than one Construction Type (excepting road, railroad crossings, fabricated assemblies, spans, .) complete separate sheet for each type.

PIPELINES AND MAINS TEST DATA

COMPANY Atlantic Seaboard Corporation		DATE June 16, 1967	
STATE W. Va.	DIVISION Elkins	DISTRICT Petersburg	
LINE NUMBER 36" Line WB-5		ACCOUNT OR WORK ORDER NUMBER ASC Bud. 3505 W.O. 359-21	
PIPE DATA			
1	PIPE SIZE, NOM. O. D. 36"	LENGTH, FT. 51,936	MILES 9.84
2	WALL THICKNESS - INS. .438	GRADE X-60	MINIMUM SPECIFIED YIELD STRENGTH 60,000 PSI
3	MANUFACTURER U. S. Steel	PURCHASE ORDER NO. 593	DATE Jan. 26, 1965
4	TYPE OF LONGITUDINAL SEAM, IF ANY Double Submerged Arc Welded		
5	COLD EXPANDED Yes	MILL INSPECTED BY Pittsburgh Testing Laboratory	
DESIGN DATA			
6	CONSTRUCTION TYPE "F" .72		
7	LONGITUDINAL JOINT FACTOR "E" 1.00		
8	TEMPERATURE DERATING FACTOR "T" 1.00		
9	DESIGN PRESSURE 1,000 PSIG	(See Approved Procedure No. 95, System Standard Policy for Piping Design Pressure)	
PROOF TEST DATA			DATE OF PROOF TEST 1967 June 2, 3, 4, 5, 6, 7 & 8,
10	LOCATION CLASS 1	TEST MEDIUM Water	{ SEC. 6 } { SEC. 7 & 8 } { SEC. 1 } { SEC. 2 }
11	TEST PRESSURE 1606 PSIG	DURATION OF TEST 24 HOURS	
WITNESSED BY:		CONTRACTOR	COMPANY <i>Douglas J. Wilson</i>
TEST ACCEPTED BY: <i>Frank Dickerson</i>			
LEAKAGE TEST DATA (See Form No. G - 10412)			DATE OF LEAKAGE TEST
12	TEST MEDIUM	TEST PRESSURE	PSIG
13	LENGTH OF TEST	PRESSURE LOSS	PSIG
14	CALCULATED LEAKAGE, CUBIC FEET LOSS PER MILE OF EQUIVALENT 3" AT 100 PSIG		CU. FT.
WITNESSED BY:		CONTRACTOR	COMPANY
TEST ACCEPTED BY:			

NOTE: If the line falls into more than one Construction Type (excepting road, railroad crossings, fabricated assemblies, spans, ...) complete separate sheet for each type.



CAS TEST OF LINE WD-5-36" - 1965 CONSTRUCTION
 ASC BOD. 3505, W.D. 359-70
 AVE DEAD WT PRESSURE 600-884 psig

Hunter Phantom Chart
 THE FOXBORO COMPANY
 U.S.A.
 798494

Start Test
 10:00 AM
 (1) 10:00 AM
 (2) 10:30 AM
 (3) 11:00 AM
 (4) 11:30 AM
 (5) 12:00 PM

11P.M. MIDNIGHT 1A.M. 2A.M. 3A.M. 4A.M. 5A.M. 6DAY 7A.M. 8A.M. 9A.M. 10A.M. 11A.M. NOON 1P.M. 2P.M. 3P.M. 4P.M. 5P.M. 6NIGHT 7P.M. 8P.M. 9P.M. 10P.M.

1000
900
800
700
600
500
400
300
200
100
100
200
300
400
500
600
700
800
900
1000

TRANSMITTAL SLIP

<input type="checkbox"/> Immediate action desired	Date 12-17-64
TO Mr. Forrest Robinson	
FROM Jack G. Brown	
With reference to the attached:	
<input type="checkbox"/> Take charge	
<input type="checkbox"/> Approval required	<input type="checkbox"/> Return to me
<input type="checkbox"/> Signature required	<input type="checkbox"/> Return to me
<input type="checkbox"/> Prepare reply for my signature	
<input type="checkbox"/> Reply. Send me copy	
<input type="checkbox"/> Advise status	
<input type="checkbox"/> Review and contact me this _____ A.M. _____ P.M.	
<input type="checkbox"/> Comments desired	
<input type="checkbox"/> Recommendations desired	
<input type="checkbox"/> Note and return	
<input type="checkbox"/> Note and file	
<input type="checkbox"/> For your information	
Remarks: This has been approved for payment. These are your information copies.	



AMERICAN MACHINE & FOUNDRY COMPANY
ADVANCED PRODUCTS GROUP, Greenwich, Conn.

REMIT TO: **261 Madison Avenue, New York 16, N.Y.**

CUSTOMER'S ORDER NO. & DATE P. O. 35252	REQUISITION OR CONTRACT NO.	CUSTOMER CODE	REFER TO JOB ORDER NO.
INVOICE NO. 1437	TERMS Net 30 Days		INVOICE DATE Dec 7, 1964

TO [Atlantic Seaboard Corporation
 1700 Mac Corkle Ave., S. E.
 Charleston 25, West Virginia]

SHIPPED TO AND DESTINATION	<input type="checkbox"/> BALANCE OF ORDER WILL FOLLOW. <input type="checkbox"/> THIS SHIPMENT COMPLETES YOUR ORDER
----------------------------	---

HOW SHIPPED AND ROUTE	DATE SHIPPED	F. O. B.
-----------------------	--------------	----------

JOB ORDER NO.	QUANTITY		PART NUMBER - DESCRIPTION			UNIT LIST PRICE	AMOUNT	TOTAL
	ORDERED	SHIPPED	(INDEX)	RATED	(CLASS DIV.)			
					Use of AMF Welder on Columbia Gas System Pipe-line for period of 23 October 1964 thru 10 December 1964. (Reference your P. O. #35252) Charge: Installing Research Pipe-Line WB-5 Acct. No. 186-1-879.			\$12,970.70

"We hereby certify that these goods were produced in compliance with all applicable requirements of sections 6, 7, and 12 of the Fair Labor Standards Act, as amended, and of regulations and orders of the Administration issued under section 14 thereof. We also warrant that the articles ordered were produced in compliance with any and all applicable provisions of the Walsh-Healy Public Contracts Act, the Eight Hour Law and the Davis-Bacon Act." "It is the Seller's policy to conform with all applicable ceiling price regulations."
 TERMS: NET CASH 30 DAYS, UNLESS OTHERWISE SPECIFIED ABOVE - NO CASH DISCOUNT - PAYABLE IN U.S.A. DOLLARS
 ALL GOODS F. O. B. OUR FACTORIES. MAKE NO DEDUCTIONS FROM THIS INVOICE: IF INCORRECT RETURN AT ONCE.



AMERICAN MACHINE & FOUNDRY COMPANY
ADVANCED PRODUCTS GROUP, Greenwich, Conn.

REMIT TO: **261 Madison Avenue, New York 16, N.Y.**

CUSTOMER'S ORDER NO. & DATE P. O. 35252	REQUISITION OR CONTRACT NO.	CUSTOMER CODE	REFER TO JOB ORDER NO.
INVOICE NO. 1437	TERMS Net 30 Days	INVOICE DATE Dec 7, 1964	

TO [Atlantic Seaboard Corporation
 1700 Mac Corkle Ave., S. E.
 Charleston 25, West Virginia]

SHIPPED TO AND DESTINATION

- BALANCE OF ORDER WILL FOLLOW.
 THIS SHIPMENT COMPLETES YOUR ORDER

HOW SHIPPED AND ROUTE

DATE SHIPPED F. O. B.

JOB ORDER NO.	QUANTITY		PART NUMBER - DESCRIPTION		UNIT LIST PRICE	AMOUNT	TOTAL
	ORDERED	SHIPPED	(INDEX)	RATED (CLASS DIV.)			
				Use of AMF Welder on Columbia Gas System Pipe-line for period of 23 October 1964 thru 10 December 1964. (Reference your P. O. #35252) Charge: Installing Research Pipe-Line WB-5 Acct. No. 186-1-879.			\$12,970.70

"We hereby certify that these goods were produced in compliance with all applicable requirements of sections 6, 7, and 12 of the Fair Labor Standards Act, as amended, and of regulations and orders of the Administration issued under section 14 thereof. We also warrant that the articles ordered were produced in compliance with any and all applicable provisions of the Walsh-Healy Public Contracts Act, the Eight Hour Law and the Davis-Bacon Act." "It is the Seller's policy to conform with all applicable ceiling price regulations."

TERMS: NET CASH 30 DAYS, UNLESS OTHERWISE SPECIFIED ABOVE - NO CASH DISCOUNT - PAYABLE IN U.S. A. DOLLARS
 ALL GOODS F. O. B. OUR FACTORIES. MAKE NO DEDUCTIONS FROM THIS INVOICE: IF INCORRECT RETURN AT ONCE.

ORIGINAL COPIES (CUST.) ADDITIONAL COPIES 1 PINK 1 POSTING 1 COLLECTION 1 SHIPPING

TO Monarch Mills, Inc.
ADDRESS P. O. Box 126 - Petersburg, West Virginia

\$ **147.59**

ISSUED FOR Supplies	147	59

TO BE USED FOR **Research Line Pipe WB-5 - Account 186-0-2-81**

PREPARED BY <i>Thomas F. Gude</i>	RECEIVED OF Atlantic Seaboard Corp. CO.	CLASSIFICATION									
APPROVED BY	One hundred forty-seven and 59/100 - - - - DOLLARS	ST.	CO. BLD.	GEN. LED.	AUX.	INT.	SUB.	OTHER	CODE	AMOUNT	
APPROVED BY	SIGNED										
STATEMENT NUMBER 6	SUB NO. 9	Paid by Ck. No. 10126									

Monarch Mills, Inc.

BUILDING MATERIALS · FARMERS' SUPPLIES

REMODELING · NEW CONSTRUCTION

TELEPHONE CIRCLE 3-4611 · 3-2881

P. O. BOX 126 · PETERSBURG, W. VA. 26747

ATLANTIC SEASOARD CORP.
PETERSBURG, W. VA.

TERMS 30 DAYS

INTEREST CHARGED ON PAST DUE ACCOUNTS

DATE	DESCRIPTION	CHARGES	CREDITS	BALANCE
OCT 31 64	60 FT 1/2" ROPE R	3.00 .00		2.46 5.54
NOV 7 64	1 PAINT BRUSH 1 PAINT BRUSH TAX ✓ 4 RLS 939-12-12 1/2 WIRE ✓ 40 7' STEEL POSTS ✓ 1 RL. BARBED WIRE 5 1/2 STAPLES 6 STEEL BRUSHES TAX LINE WB-5 ACCT NO. 186-0-2-01 W.P.DIEHL JR ✓ 100 FT LATTICE EX LINE WB-5 ACCT 186-0-2-01 W. P. DIEHL JR	1.99 .79 .00 70.60 50.00 9.00 .90 3.34 4.03 3.50 .10		130.67
NOV 12 64	✓ 24. 1/2X4X8 AD PLYWOOD LABOR EX BY 1 RL 939-12-12 1/2 WIRE BY TAX 10 PIPE FITTINGS TAX	5.89 .79 .20 17.65 .53 .97 .02		139.68
NOV 17 64	BY CHECK		2.46	137.22
NOV 17 64	✓ 1 1/4X4X8 PLYWOOD MILLING RX	3.20 .50 .11		141.93

PLEASE KEEP THIS INVOICE -- WE POSITIVELY DO NOT ITEMIZE AGAIN

Monarch Mills, Inc.

BUILDING MATERIALS PATTERNS & SUPPLIES
 REMEDIATION NEW CONSTRUCTION
 TELEPHONE ORDERS 800-441-1441
 P.O. BOX 118 PETERSBURG, W. VA. 23104

ATLANTIC SEABOARD CORP.
 PETERSBURG, W. VA.

TERMS 30 DAYS

INTEREST CHARGED ON PAST DUE ACCOUNTS

DATE	DESCRIPTION	CHARGES	CREDITS	BALANCE
NOV 19 64				141.05
NOV 19 64	1 8x3/4 GALV. NIPPLE	.25		
	1 1/2" GALV. PLUG	.14		
	1 1/2" GALV. COUPLING	.23		
	TAX	.02		141.67
NOV 27 64	1# 20D NAILS	.14		
	1# 16D NAILS	.12		
	EX	.01		141.94

PLEASE KEEP THIS INVOICE -- WE POSITIVELY DO NOT ITEMIZE AGAIN

Monarch Mills, Inc.

BUILDING MATERIALS - FARMER SUPPLIES
 REMODELING - NEW CONSTRUCTION
 TELEPHONE CIRCLE 1-4511 - 1-6231
 P. O. BOX 190 PETERSBURG, W. VA. 20167

ATLANTIC SEABOARD CORP.
 PETERSBURG, W. VA.

TERMS 30 DAYS

INTEREST CHARGED ON FAST DUE ACCOUNTS

DATE	DESCRIPTION	AMOUNT	SECURITY	BALANCE
DEC 16 68	1 SOFT STEEL TAPE TAX	2.49 .16		112.94 117.59

PLEASE KEEP THIS INVOICE -- WE POSITIVELY DO NOT ISSUE AGAIN

MONARCH MILLS, INC.

R. H. ALT

BOX 126

PETERSBURG, WEST VIRGINIA 26747

ROSWELL H. ALT.

CIRCLE 3-4511

CIRCLE 3-5561

BUILDING MATERIALS

FARM & GARDEN SUPPLIES

BUILDING CONTRACTING

WHOLESALE and RETAIL

SALESMAN	CUSTOMER ORDER NO.	WHEN TO SHIP	PICK UP	DATE <i>11/4/64</i>
----------	--------------------	--------------	---------	------------------------

NOTE-THIS IS A JOINT ACCOUNT

TERMS: 30 DAYS NET

Mr. & Mrs.

Atlantic Seaboard

S
T
O
C
K

S
H
I
P
T
O

JOB

CASH	CONTRACT	CHARGE <input checked="" type="checkbox"/>	ON ACCT.	MDSE. RETD.	INTEREST CHARGED ON PAST DUE ACCOUNTS
------	----------	--	----------	-------------	---------------------------------------

QUANTITY ORDERED	DESCRIPTION	QUANTITY SHIPPED	PRICE	AMOUNT
4	<i>rl 939-12-12 1/2 Wire</i>	4	<i>17.65</i>	<i>3</i>
40	<i>Steel Posts 7'</i>	40	<i>1.25</i>	
1	<i>rl Barbed Wire</i>	1	<i>9.00</i>	
5	<i>lb Staples</i>	5	<i>.18</i>	
6	<i>Steel Brushes</i>	6	<i>.59</i>	
<i>Line WB-5</i>				
<i>acct. No. 186-0-2-81</i>				
<i>W.P. Dill Jr.</i>				
			TAX	
			TOTAL	

RECEIVED BY

No. 25191

MONARCH MILLS, INC.

R. H. ALT

BOX 126
PETERSBURG, WEST VIRGINIA 26747
CIRCLE 3-4511

PETERSBURG, WEST VIRGINIA 26747

CIRCLE 3-5561

ROSWELL H. ALT.

BUILDING MATERIALS FARM & GARDEN SUPPLIES BUILDING CONTRACTING
WHOLESALE and RETAIL

SALESMAN	CUSTOMER ORDER NO.	WHEN TO SHIP	PICK UP	DATE <i>11-6-64</i>
----------	--------------------	--------------	---------	------------------------

NOTE-THIS IS A JOINT ACCOUNT

TERMS: 30 DAYS NET

Mr. & Mrs. *Att. Seaboard*

S
T
O

S
H
I
P
T
O

JOB

CASH	CONTRACT	CHARGE	ON ACCT. <input checked="" type="checkbox"/>	MDSE. RETD.	INTEREST CHARGED ON PAST DUE ACCOUNTS
------	----------	--------	--	-------------	---------------------------------------

QUANTITY ORDERED	DESCRIPTION	QUANTITY SHIPPED	PRICE	AMOUNT
	<i>Order</i>			
<i>134</i>	<i>1 Bl. 939-12-12 1/2</i>			
	<i>Cr. ac. chgd</i>			
			TAX	
			TOTAL	

RECEIVED BY

No. 25221

MONARCH MILLS, INC.

R. H. ALT

BOX 126

PETERSBURG, WEST VIRGINIA 26747

ROSWELL H. ALT.

CIRCLE 3-4511

CIRCLE 3-5561

BUILDING MATERIALS

FARM & GARDEN SUPPLIES

BUILDING CONTRACTING

WHOLESALE and RETAIL

SALESMAN	CUSTOMER ORDER NO.	WHEN TO SHIP	PICK UP	DATE <i>11-12-64</i>
----------	--------------------	--------------	---------	-------------------------

NOTE-THIS IS A JOINT ACCOUNT

TERMS: 30 DAYS NET

Mr. & Mrs. *Atte. Seaboard*

S
H
I
P
T
O

JOB

CASH	CONTRACT	CHARGE <input checked="" type="checkbox"/>	ON ACCT.	MDSE. RETD.	INTEREST CHARGED ON PAST DUE ACCOUNTS
------	----------	--	----------	-------------	---------------------------------------

QUANTITY ORDERED	DESCRIPTION	QUANTITY SHIPPED	PRICE	AMOUNT
	<i>AD</i>			
	<i>SR. 1/2" 4X8 Plywood</i>	<i>1</i>		
	<i>Sabon - 1/4 Hr.</i>			
	<i>Line WB-5</i>			
	<i>Acct. No. 186-0-2-81</i>			
	<i>W.P. Hill, Jr.</i>			
			TAX	
			TOTAL	

RECEIVED BY *James L. Carr*

No. 25120

MONARCH MILLS, INC.

R. H. ALT

BOX 126

PETERSBURG, WEST VIRGINIA 26747

ROSWELL H. ALT.

CIRCLE 3-4511

CIRCLE 3-5561

BUILDING MATERIALS

FARM & GARDEN SUPPLIES

BUILDING CONTRACTING

WHOLESALE and RETAIL

SALESMAN	CUSTOMER ORDER NO.	WHEN TO SHIP	PICK UP	DATE <i>11/13/64</i>
----------	--------------------	--------------	---------	-------------------------

NOTE-THIS IS A JOINT ACCOUNT

TERMS: 30 DAYS NET

Mr. & Mrs. *Atlantic Sealwood*

S
O
L
D
T
O

Jimmy Can

S
H
I
P
T
O

JOB

CASH	CONTRACT	CHARGE <input checked="" type="checkbox"/>	ON ACCT.	MDSE. RETD.	INTEREST CHARGED ON PAST DUE ACCOUNTS
------	----------	--	----------	-------------	---------------------------------------

QUANTITY ORDERED	DESCRIPTION	QUANTITY SHIPPED	PRICE	AMOUNT
	<i>Plywood 4x4x8</i>	<i>1</i>		
	<i>Milling</i>			
	<i>Line WB-5</i>			
	<i>Acct. No. 186-02-81</i>			
	<i>W.P. Stahl, Jr.</i>			
			TAX	
			TOTAL	

RECEIVED BY

No. 25406

MONARCH MILLS, INC.

R. H. ALT

BOX 126

PETERSBURG, WEST VIRGINIA 26747

ROSWELL H. ALT.

CIRCLE 3-4511

CIRCLE 3-5561

BUILDING MATERIALS

FARM & GARDEN SUPPLIES

BUILDING CONTRACTING

WHOLESALE and RETAIL

SALESMAN	CUSTOMER ORDER NO.	WHEN TO SHIP	PICK UP	DATE <i>11-2-64</i>
----------	--------------------	--------------	---------	------------------------

NOTE-THIS IS A JOINT ACCOUNT

TERMS: 30 DAYS NET

Mr. & Mrs.

Att. Seaboard

S
T
O
T

S
H
I
P
T
O

JOB

CASH	CONTRACT	CHARGE <input checked="" type="checkbox"/>	ON ACCT.	MDSE. RETD.	INTEREST CHARGED ON PAST DUE ACCOUNTS
------	----------	--	----------	-------------	---------------------------------------

QUANTITY ORDERED	DESCRIPTION	QUANTITY SHIPPED	PRICE	AMOUNT
	<i>Paint Brush</i>	<i>1</i>		<i>1.99</i>
	<i>" "</i>	<i>1</i>		<i>79</i>
			TAX	
			TOTAL	

Spent 11/3/64

RECEIVED BY

No. 24992

TRANSMITTAL SLIP

<input type="checkbox"/> Immediate action desired	Date 9-9-64
TO Ray Lynn	
FROM Jack Brown	
With reference to the attached:	
<input type="checkbox"/> Take charge <input type="checkbox"/> Approval required <input type="checkbox"/> Return to me <input type="checkbox"/> Signature required <input type="checkbox"/> Return to me <input type="checkbox"/> Prepare reply for my signature <input type="checkbox"/> Reply. Send me copy <input type="checkbox"/> Advise status <input type="checkbox"/> Review and contact me this _____ A.M. _____ P.M. <input type="checkbox"/> Comments desired <input type="checkbox"/> Recommendations desired <input type="checkbox"/> Note and return <input type="checkbox"/> Note and file <input checked="" type="checkbox"/> For your information	
RECEIVED	
Remarks:	
<div style="display: flex; justify-content: space-between;"> <div style="width: 40%;"> <p><i>Project 4-1</i> <i>St. Luke</i></p> </div> <div style="width: 50%; text-align: center;"> <p>SEP 10 1964</p> <p>A.S.C. Trans.</p> </div> </div>	



United States Steel Corporation

PLEASE REMIT TO
TREASURY DEPARTMENT
P O BOX 286
PITTSBURGH, PA 15201

INVOICE NUMBER
NR 31272

MILL
S. 21233 6/25/A
11-0438650-030 036
060
30 NET 24 10 DAYS SEMI MONTHLY
00 0000 1 0

ATLANTIC SEABOARD CORPORATION
120 EAST 41ST STREET
NEW YORK 17 NEW YORK

MC KEESPORT
8/27/64
NY 64520
2 074 4 97
1
2.6 3

THE PLE NYC WAB
SHIP
REOST

SHIP AUTH SYMBOL
TLP

TRUCK LICENSE OR CAR NUMBERS

WEIGHT RATE FREIGHT AMOUNT FREIGHT TERMS
163801# AS .515 1236.00 PREPAID
240000#

SHIPMENT CODE
1 - COMPLETE
2 - PARTIAL
3 - FINAL

NET AMOUNT
R 100 FEET
ST PRICE
ST PRICE

DESCRIPTION

COMPLETE
USS MATL EXP ELEC WELD STEEL LINE PIPE BE REV 30 DEG AP 5
NOT OILED 36" OD 95.45 LB/FT .250 W GR X 100 SF 495328

ITEM	DESCRIPTION	WEIGHT	RATE	FREIGHT AMOUNT	FREIGHT TERMS
16P	PRR 363946	28524#	AS 40000#	2921 10"	
16P	PLE 11445	27362#	AS 40000#	2861 8"	
16P	PRR 613814	26440#	AS 40000#	2771 0"	
16P	B&O 559071	26678#	AS 40000#	2791 6"	
16P	PLE 11197	27323#	AS 40000#	2861 3"	
15F	BLE 17115	27474#	AS 40000#	2871 10"	

3003

R & O 59356.003

ULT DEST MELYNDALE MICHIGAN

The (ORIGINAL) of this invoice is on GREY paper. COPIES are on WHITE paper.

PAID IN OR BEFORE 9/10/64 \$

TOTAL AMOUNT \$

THE ABOVE TERMS HAVE BEEN PROVIDED IN ACCORDANCE WITH THE FAIR AND STANDARDS ACT OF 1938, AS AMENDED. IN CASE OF LOSS OR DAMAGE TO THIS INVOICE, THE BUYER SHALL BE RESPONSIBLE FOR THE DELIVERY OF THE ORIGINAL COPY OF THIS INVOICE TO THE UNITED STATES STEEL CORPORATION AT THE ABOVE ADDRESS. MATERIAL RETURNED WITHOUT PERMISSION WILL NOT BE ACCEPTED FOR REBATE.

Property - W.O.
W.O. 359-21
Bud 3505 - Line WB-5

X-Ref
Engineering + Planning
Co. - Cath Prot
(Inspection + Testing)
February 15, 1966

Mr. Leo J. Payne

Mr. J. Frank Dickerson

Gas Test Line WB-5

Attached are the Pipelines and Mains Test Data Sheet with recording charts for the gas test of 36" Line WB-5 from Moorefield to Route 220.

This section of line was gas tested due to impending delivery requirements and the possibility of sub-freezing weather interfering with a standard hydrostatic test. The contractor spotted a portable gas compressor at Moorefield to boost test gas from the 26" System to a final test pressure of 884 Psi.

A hydrostatic test to yield will be put on this section during 1966 by the contractor, Carl E. Smith.

Until further test, this section of 36" Line is available for operation at 804 Psi.

J. Frank Dickerson
J. Frank Dickerson

cc: Mr. R. E. Lynn ✓

WB-5 Test File

PIPELINES AND MAINS TEST DATA

COMPANY ATLANTIC SEABOARD CORPORATION		DATE February 16, 1966	
STATE West Virginia	DIVISION Elkins	DISTRICT	
LINE NUMBER WB-5		ACCOUNT OR WORK ORDER NUMBER Budget 3505 W. O. 359-21	
PIPE DATA			
1	PIPE SIZE, NOM. O. D. 36"	LENGTH, FT. 51,958 *	MILES 9.72
2	WALL THICKNESS - INS. .438	GRADE X-60	MINIMUM SPECIFIED YIELD STRENGTH 60,000
3	MANUFACTURER U. S. Steel	PURCHASE ORDER NO. 593	DATE Jan. 26, 1965
4	TYPE OF LONGITUDINAL SEAM, IF ANY Double Submerged Arc		
5	COLD EXPANDED Yes	MILL INSPECTED BY Pittsburgh Testing Co. P. O. 4381 March 19, 1965	
DESIGN DATA			
6	CONSTRUCTION TYPE "F" 0.72 (Type A Construction)		
7	LONGITUDINAL JOINT FACTOR "E" 1.0		
8	TEMPERATURE DERATING FACTOR "T" 1.0		
9	DESIGN PRESSURE ** 1 000 PSIG	(See Approved Procedure No. 95, System Standard Policy for Piping Design Pressure)	
PROOF TEST DATA			DATE OF PROOF TEST November 30, 1965
10	LOCATION CLASS 1	TEST MEDIUM Gas	
11	TEST PRESSURE 884 PSIG	DURATION OF TEST 24 HOURS	
WITNESSED BY:	CONTRACTOR Carl E. Smith	COMPANY Lloyd Ulrich	
TEST ACCEPTED BY:			
LEAKAGE TEST DATA (See Form No. G - 10412)			DATE OF LEAKAGE TEST
12	TEST MEDIUM	TEST PRESSURE PSIG	
13	LENGTH OF TEST	PRESSURE LOSS PSIG	
14	CALCULATED LEAKAGE, CUBIC FEET LOSS PER MILE OF EQUIVALENT 3" AT 100 PSIG		CU. FT.
WITNESSED BY:	CONTRACTOR	COMPANY	
TEST ACCEPTED BY:			

NOTE: If the line falls into more than one Construction Type (excepting road, railroad crossings, fabricated assemblies, spans, . . .) complete separate sheet for each type.

* 1185 of 36", X-100 Experimental pipe laid in 1964 was also tested.

** Line designed for 1000 Psi, this test qualifies it for temporary operation at 804 Psi until retest during 1966.

TEMPERATURE CHART

GAS TEST OF LINE WB-5-36" - 1965 CONSTRUCTION

A.S.C. BUD 3505, W.O. 359-21

TEST TIME: 2:00pm (11-29-65) TO 2:00pm (11-30-65) (24 HRS.)

Avg. Dead Wt. Pressure = 884 psig.

Form ARC 408

REMARKS:

CHART PLACED BY: S.T. Callano

CHART REMOVED BY: S.T. Callano

CHART PERIOD	
1965	MO. DATE HOUR
11	30 2:00 PM
29	11 2:00 PM

STATION NUMBER

Average Value

FORM CSA-119




STATION NAME

Woolerfield Corte Settiva



RECEIVED
FEB 18 1966
ELKINS, W. VA.



FOXBORO BACK PRINTING NO. 1781




TO BE FILLED OUT WHEN CHART IS PLACED	STATION NUMBER <u>MOORE FIELD GATE</u>
	STATION NAME _____
	CHART ON <u>11-29</u> 19 <u>65</u> AT <u>2:00</u> A.M. P.M. SIGNED <u>S.T. Collins</u>
TO BE FILLED OUT WHEN CHART IS REMOVED	CHART OFF <u>11-30</u> - 19 <u>65</u> AT <u>2:00</u> A.M. P.M.
	REMARKS _____
	SIGNED <u>S.T. Collins</u>
OFFICE _____	AVERAGE _____ FACTOR _____







GAS TEST OF 53.167' OF LINE WB-5-36"
 1965 CONSTRUCTION
 A.S.C. BUD. 3505, W.O. 359-21
 TEST TIME: 2:00pm - 2:00pm (24 HR.)
 DATE OF TEST: NOV. 29-30, 1965
 AVE. DEAD WT. TEST PRESSURE = 884 psig.
 DESIGN PRESSURE: 1000 psig. (800 psig. FOR WINTER, 1965-66)

Appendix B. Pipe Section Details




Pipe Name: P1



Pipe Name: P2



Pipe Name: P3





Appendix C. Mechanical Test Specimen Cut Plans

Specimens with welds must be aligned axially and centrally with the weld center line.

Specimens without welds are aligned parallel with the pipe axis (reference lines provided on pipe) or perpendicular to the pipe axis.

Kerf dimension is unimportant. Sprues must be at the ends of the specimens.

Reference via centerlines marked on plate.



PROJECT:
Vintage X100

MATERIAL: X100 Steel

QTY REQUIRED: 1

DEFAULT UNITS: Inches
DEFAULT TOLERANCE: $\pm 0.005'' - \pm 1'$
DEFAULT FINISH: < 63 microinch

PART/VIEW:
P1S1

SCALE: In View SHEET: 1 of 1 CREATION DATE: 8/11/2021 REVISION:

Contact: Dash Weeks - timdash@nist.gov - 303-968-8822

The information contained on this drawing shall be considered intellectual property owned by NIST. Authorized receipt and review of this information implies consent to non-disclosure of trade secrets. Disclosure to third parties is unauthorized without prior written permission from NIST.



NIST

Specimens with welds must be aligned axially and centrally with the weld center line.

Specimens without welds are aligned parallel with the pipe axis (reference lines provided on pipe) or perpendicular to the pipe axis.

Kerf dimension is unimportant. Sprues must be at the ends of the specimens.

Reference via centerlines marked on plate.



PROJECT:
Vintage X100

MATERIAL: X100 Steel

QTY REQUIRED: 1

DEFAULT UNITS: Inches
DEFAULT TOLERANCE: $\pm 0.005'' - \pm 1'$
DEFAULT FINISH: < 63 microinch

PART/VIEW:
P1S1-90



SCALE: In View SHEET: 1 of 1 CREATION DATE: 8/11/2021 REVISION:

Contact: Dash Weeks - timdash@nist.gov - 303-968-8822


The information contained on this drawing shall be considered intellectual property owned by NIST. Authorized receipt and review of this information implies consent to non-disclosure of trade secrets. Disclosure to third parties is unauthorized without prior written permission from NIST.

Specimens with welds must be aligned axially and centrally with the weld center line.


Specimens without welds are aligned parallel with the pipe axis (reference lines provided on pipe) or perpendicular to the pipe axis.

Kerf dimension is unimportant. Sprues must be at the ends of the specimens.

Reference via centerlines marked on plate.



Flat Side



PROJECT:

Vintage X100

MATERIAL: X100 Steel

QTY REQUIRED: 1

DEFAULT UNITS: Inches
 DEFAULT TOLERANCE: $\pm 0.005"$ - $\pm 1'$
 DEFAULT FINISH: < 63 microinch


PART/VIEW:

P1S1-180

SCALE: In View SHEET: 1 of 1 CREATION DATE: 8/11/2021 REVISION:

Contact: Dash Weeks - timdash@nist.gov - 303-968-8822

The information contained on this drawing shall be considered intellectual property owned by NIST. Authorized receipt and review of this information implies consent to non-disclosure of trade secrets. Disclosure to third parties is unauthorized without prior written permission from NIST.





Specimens with welds must be aligned axially and centrally with the weld center line.

Specimens without welds are aligned parallel with the pipe axis (reference lines provided on pipe) or perpendicular to the pipe axis.

Kerf dimension is unimportant. Sprues must be at the ends of the specimens.

Reference via centerline marked on plate.



PROJECT:
Vintage X100

MATERIAL: X100 Steel

QTY REQUIRED: 1

DEFAULT UNITS: Inches
DEFAULT TOLERANCE: $\pm 0.005'' - \pm 1'$
DEFAULT FINISH: < 63 microinch


PART/VIEW:
P1S2

SCALE: In View SHEET: 1 of 1 CREATION DATE: 8/11/2021 REVISION:

Contact: Dash Weeks - timdash@nist.gov - 303-968-8822

The information contained on this drawing shall be considered intellectual property owned by NIST. Authorized receipt and review of this information implies consent to non-disclosure of trade secrets. Disclosure to third parties is unauthorized without prior written permission from NIST.






Specimens with welds must be aligned axially and centrally with the weld center line.

Specimens without welds are aligned parallel with the pipe axis (reference lines provided on pipe) or perpendicular to the pipe axis.

Kerf dimension is unimportant. Sprues must be at the ends of the specimens.

Reference via centerlines marked on plate.



It is very possible that there isn't enough material at this end to actually cut. The important setup requirement is that the weld center line is in the middle of the specimens.



PART/VIEW:
P1S2-90

PROJECT:
Vintage X100



SCALE: In View	SHEET: 1 of 1	CREATION DATE: 8/11/2021	REVISION:
CONTACT: Dash Weeks - timdash@nist.gov - 303-968-8822			
<p>NOTES:</p> <p>MATERIAL: X100 Steel</p> <p>QTY REQUIRED: 1</p> <p>DEFAULT UNITS: Inches DEFAULT TOLERANCE: ± 0.005" - ± 1' DEFAULT FINISH: < 63 microminch</p>			
<p>The information contained on this drawing shall be considered intellectual property owned by NIST. Authorized receipt and review of this information implies consent to non-disclosure of trade secrets. Disclosure to third parties is unauthorized without prior written permission from NIST.</p>			

Specimens with welds must be aligned axially and centrally with the weld center line.

Specimens without welds are aligned parallel with the pipe axis (reference lines provided on pipe) or perpendicular to the pipe axis.

Kerf dimension is unimportant. Sprues must be at the ends of the specimens.

Reference via centerlines marked on plate.



PROJECT:
Vintage X100
MATERIAL: X100 Steel
QTY REQUIRED: 1

PART/VIEW:
P1S2-180

NIST

SCALE: In View SHEET: 1 of 1 CREATION DATE: 8/11/2021 REVISION:

Contact: Dash Weeks - timdash@nist.gov - 303-968-8822

DEFAULT UNITS: Inches
DEFAULT TOLERANCE: $\pm 0.005'' - \pm 1'$
DEFAULT FINISH: < 63 microinch



The information contained on this drawing shall be considered intellectual property owned by NIST. Authorized receipt and review of this information implies consent to non-disclosure of trade secrets. Disclosure to third parties is unauthorized without prior written permission from NIST.

Specimens with welds must be aligned axially and centrally with the weld center line.

Specimens without welds are aligned parallel with the pipe axis (reference lines provided on pipe) or perpendicular to the pipe axis.

Kerf dimension is unimportant. Sprues must be at the ends of the specimens.

Reference via centerlines marked on plate.



PROJECT:
Vintage X100

MATERIAL: X100 Steel

QTY REQUIRED: 1

NOTES:
DEFAULT UNITS: Inches
DEFAULT TOLERANCE: $\pm 0.005'' - \pm 1'$
DEFAULT FINISH: < 63 microinch

PART/VIEW:
P2S1-90

SCALE: In View SHEET: 1 of 1 CREATION DATE: 8/11/2021 REVISION:

Contact: Dash Weeks - timdash@nist.gov - 303-968-8822

The information contained on this drawing shall be considered intellectual property owned by NIST. Authorized receipt and review of this information implies consent to non-disclosure of trade secrets. Disclosure to third parties is unauthorized without prior written permission from NIST.

NIST



Specimens with welds must be aligned axially and centrally with the weld center line.

Specimens without welds are aligned parallel with the pipe axis (reference lines provided on pipe) or perpendicular to the pipe axis.

Kerf dimension is unimportant. Sprues must be at the ends of the specimens.

Reference via centerlines marked on plate.

Unsure which side is flat.
There is no weld, so plate can be turned either way.



PROJECT:

Vintage X100

MATERIAL: X100 Steel

QTY REQUIRED: 1

DEFAULT UNITS: Inches
DEFAULT TOLERANCE: $\pm 0.005"$ - $\pm 1'$
DEFAULT FINISH: < 63 microinch

PART/VIEW:

P2S1-180

SCALE: In View SHEET: 1 of 1 CREATION DATE: 8/11/2021 REVISION:

Contact: Dash Weeks - timdash@nist.gov - 303-968-8822

The information contained on this drawing shall be considered intellectual property owned by NIST. Authorized receipt and review of this information implies consent to non-disclosure of trade secrets. Disclosure to third parties is unauthorized without prior written permission from NIST.



NIST

Specimens with welds must be aligned axially and centrally with the weld center line.

Specimens without welds are aligned parallel with the pipe axis (reference lines provided on pipe) or perpendicular to the pipe axis.

Kerf dimension is unimportant. Sprues must be at the ends of the specimens.

Reference via centerlines marked on plate.



PROJECT:

Vintage X100

MATERIAL: X100 Steel

QTY REQUIRED: 1

DEFAULT UNITS: Inches
 DEFAULT TOLERANCE: $\pm 0.005'' - \pm 1'$
 DEFAULT FINISH: < 63 microinch

PART/VIEW:

P2S2

SCALE: In View SHEET: 1 of 1 CREATION DATE: 8/11/2021 REVISION:

Contact: Dash Weeks - timdash@nist.gov - 303-968-8822

The information contained on this drawing shall be considered intellectual property owned by NIST. Authorized receipt and review of this information implies consent to non-disclosure of trade secrets. Disclosure to third parties is unauthorized without prior written permission from NIST.





Specimens with welds must be aligned axially and centrally with the weld center line.

Specimens without welds are aligned parallel with the pipe axis (reference lines provided on pipe) or perpendicular to the pipe axis.

Kerf dimension is unimportant. Sprues must be at the ends of the specimens.

Reference via centerlines marked on plate.



PROJECT:
Vintage X100

MATERIAL: X100 Steel

QTY REQUIRED: 1

NOTES:
DEFAULT UNITS: Inches
DEFAULT TOLERANCE: $\pm 0.005'' - \pm 1'$
DEFAULT FINISH: < 63 microinch

PART/VIEW:
P2S2-90

SCALE: In View SHEET: 1 of 1 CREATION DATE: 8/11/2021 REVISION:

Contact: Dash Weeks - timdash@nist.gov - 303-968-8822

The information contained on this drawing shall be considered intellectual property owned by NIST. Authorized receipt and review of this information implies consent to non-disclosure of trade secrets. Disclosure to third parties is unauthorized without prior written permission from NIST.



NIST

Specimens with welds must be aligned axially and centrally with the weld center line.

Specimens without welds are aligned parallel with the pipe axis (reference lines provided on pipe) or perpendicular to the pipe axis.

Kerf dimension is unimportant. Sprues must be at the ends of the specimens.

Reference via centerlines marked on plate.



PROJECT:

Vintage X100

MATERIAL: X100 Steel

QTY REQUIRED: 1

DEFAULT UNITS: Inches
 DEFAULT TOLERANCE: $\pm 0.005"$ - $\pm 1'$
 DEFAULT FINISH: < 63 microinch

PART/VIEW:

P2S2-180

SCALE: In View SHEET: 1 of 1 CREATION DATE: 8/11/2021 REVISION:

Contact: Dash Weeks - timdash@nist.gov - 303-968-8822

The information contained on this drawing shall be considered intellectual property owned by NIST. Authorized receipt and review of this information implies consent to non-disclosure of trade secrets. Disclosure to third parties is unauthorized without prior written permission from NIST.





Specimens with welds must be aligned axially and centrally with the weld center line.

Specimens without welds are aligned parallel with the pipe axis (reference lines provided on pipe) or perpendicular to the pipe axis.

Kerf dimension is unimportant. Sprues must be at the ends of the specimens.

Reference via centerlines marked on plate.



PROJECT:
Vintage X100

MATERIAL: X100 Steel

PART/VIEW:
P3S1



SCALE: In View SHEET: 1 of 1 CREATION DATE: 8/11/2021 REVISION:

Contact: Dash Weeks - timdash@nist.gov - 303-968-8822

NOTES:

QTY REQUIRED: 1

DEFAULT UNITS: Inches
DEFAULT TOLERANCE: $\pm 0.005'' \pm 1'$
DEFAULT FINISH: < 63 microinch

The information contained on this drawing shall be considered intellectual property owned by NIST. Authorized receipt and review of this information implies consent to non-disclosure of trade secrets. Disclosure to third parties is unauthorized without prior written permission from NIST.

Cutout is on the wrong side of the plate.
(This shows right, actual left)


I'll work on getting it fixed.

Specimens with welds must be aligned axially and centrally with the weld center line.


Specimens without welds are aligned parallel with the pipe axis (reference lines provided on pipe) or perpendicular to the pipe axis.

Kerf dimension is unimportant. Sprues must be at the ends of the specimens.

Reference via centerlines marked on plate.



Flat Side



PROJECT:
Vintage X100
MATERIAL: X100 Steel

PART/VIEW:
P3S1-90



NOTES:

QTY REQUIRED: 1

DEFAULT UNITS: Inches
DEFAULT TOLERANCE: $\pm 0.005'' - \pm 1'$
DEFAULT FINISH: < 63 microminch

SCALE: In View SHEET: 1 of 1 CREATION DATE: 8/11/2021 REVISION:

Contact: Dash Weeks - timdash@nist.gov - 303-968-8822



The information contained on this drawing shall be considered intellectual property owned by NIST. Authorized receipt and review of this information implies consent to non-disclosure of trade secrets. Disclosure to third parties is unauthorized without prior written permission from NIST.

Specimens with welds must be aligned axially and centrally with the weld center line.

Specimens without welds are aligned parallel with the pipe axis (reference lines provided on pipe) or perpendicular to the pipe axis.

Kerf dimension is unimportant. Sprues must be at the ends of the specimens.

Reference via centerlines marked on plate.



Flat Side

PROJECT:
Vintage X100

MATERIAL: X100 Steel

QTY REQUIRED: 1

DEFAULT UNITS: Inches
DEFAULT TOLERANCE: $\pm 0.005'' - \pm 1'$
DEFAULT FINISH: < 63 microminch

PART/VIEW:
P3S1-180



SCALE: In View SHEET: 1 of 1 CREATION DATE: 8/11/2021 REVISION:

Contact: Dash Weeks - timdash@nist.gov - 303-968-8822



The information contained on this drawing shall be considered intellectual property owned by NIST. Authorized receipt and review of this information implies consent to non-disclosure of trade secrets. Disclosure to third parties is unauthorized without prior written permission from NIST.

Specimens with welds must be aligned axially and centrally with the weld center line.

Specimens without welds are aligned parallel with the pipe axis (reference lines provided on pipe) or perpendicular to the pipe axis.

Kerf dimension is unimportant. Sprues must be at the ends of the specimens.

Reference via centerlines marked on plate.





PROJECT: Vintage X100		PART/VIEW: P3S2		NIST	
MATERIAL: X100 Steel		SCALE: In View		SHEET: 1 of 1	
QTY REQUIRED: 1		CREATION DATE: 8/11/2021		REVISION:	
NOTES: DEFAULT UNITS: Inches DEFAULT TOLERANCE: ± 0.005" - ± 1' DEFAULT FINISH: < 63 microinch		Contact: Dash Weeks - timdash@nist.gov - 303-968-8822			
The information contained on this drawing shall be considered intellectual property owned by NIST. Authorized receipt and review of this information implies consent to non-disclosure of trade secrets. Disclosure to third parties is unauthorized without prior written permission from NIST.					

Specimens with welds must be aligned axially and centrally with the weld center line.

Specimens without welds are aligned parallel with the pipe axis (reference lines provided on pipe) or perpendicular to the pipe axis.

Kerf dimension is unimportant. Sprues must be at the ends of the specimens.



PROJECT:
Vintage X100

MATERIAL: X100 Steel

QTY REQUIRED: 1

DEFAULT UNITS: Inches
DEFAULT TOLERANCE: $\pm 0.005'' \pm 1'$
DEFAULT FINISH: < 63 microinch

PART/VIEW:
P3S3

SCALE: In View SHEET: 1 of 1 CREATION DATE: 8/11/2021 REVISION:

Contact: Dash Weeks - timdash@nist.gov - 303-968-8822

The information contained on this drawing shall be considered intellectual property owned by NIST. Authorized receipt and review of this information implies consent to non-disclosure of trade secrets. Disclosure to third parties is unauthorized without prior written permission from NIST.





Specimens with welds must be aligned axially and centrally with the weld center line.

Specimens without welds are aligned parallel with the pipe axis (reference lines provided on pipe) or perpendicular to the pipe axis.

Kerf dimension is unimportant. Sprues must be at the ends of the specimens.

Reference via centerlines parked on plate.



PROJECT:
Vintage X100

MATERIAL: X100 Steel

QTY REQUIRED: 1

NOTES:
DEFAULT UNITS: Inches
DEFAULT TOLERANCE: ± 0.005" - ± 1'
DEFAULT FINISH: < 63 microinch

PART/VIEW:
P3S3-90

SCALE: In View SHEET: 1 of 1 CREATION DATE: 8/11/2021 REVISION:

Contact: Dash Weeks - timdash@nist.gov - 303-968-8822





The information contained on this drawing shall be considered intellectual property owned by NIST. Authorized receipt and review of this information implies consent to non-disclosure of trade secrets. Disclosure to third parties is unauthorized without prior written permission from NIST.

Specimens with welds must be aligned axially and centrally with the weld center line.

Specimens without welds are aligned parallel with the pipe axis (reference lines provided on pipe) or perpendicular to the pipe axis.

Kerf dimension is unimportant. Sprues must be at the ends of the specimens.

Reference via centerlines marked on plate.





PROJECT: Vintage X100		PART/VIEW: P3S3-180		NIST	
MATERIAL: X100 Steel		SCALE: In View		SHEET: 1 of 1	
QTY REQUIRED: 1		CREATION DATE: 8/11/2021		REVISION:	
NOTES:		Contact: Dash Weeks - timdash@nist.gov - 303-968-8822			
DEFAULT UNITS: Inches		The information contained on this drawing shall be considered intellectual property owned by NIST. Authorized receipt and review of this information implies consent to non-disclosure of trade secrets. Disclosure to third parties is unauthorized without prior written permission from NIST.			
DEFAULT TOLERANCE: ± 0.005" - ± 1'					
DEFAULT FINISH: < 63 microinch					

Appendix D. Metallurgy Specimen Locations

Specimens with welds must be aligned axially and centrally with the weld center line.

Specimens without welds are aligned parallel with the pipe axis (reference lines provided on pipe) or perpendicular to the pipe axis.

Kerf dimension is unimportant. Sprues must be at the ends of the specimens.



PROJECT:
Vintage X100

MATERIAL: X100 Steel

QTY REQUIRED: 1

DEFAULT UNITS: Inches
DEFAULT TOLERANCE: $\pm 0.005'' - \pm 1'$
DEFAULT FINISH: < 63 microinch

PART/VIEW:
P1S1-90



SCALE: In View SHEET: 1 of 1 CREATION DATE: 8/11/2021 REVISION:



Contact: Dash Weeks - timdash@nist.gov - 303-968-8822

The information contained on this drawing shall be considered intellectual property owned by NIST. Authorized receipt and review of this information implies consent to non-disclosure of trade secrets. Disclosure to third parties is unauthorized without prior written permission from NIST.

Specimens with welds must be aligned axially and centrally with the weld center line.

Specimens without welds are aligned parallel with the pipe axis (reference lines provided on pipe) or perpendicular to the pipe axis.

CM1 Kerf dimension is unimportant. Sprues must be at the ends of the specimens.



PROJECT:
Vintage X100

MATERIAL: X100 Steel

QTY REQUIRED: 1

DEFAULT UNITS: Inches
DEFAULT TOLERANCE: $\pm 0.005"$ - $\pm 1'$
DEFAULT FINISH: < 63 microinch

PART/VIEW:
P1S1-180

SCALE: In View SHEET: 1 of 1 CREATION DATE: 8/11/2021 REVISION:

Contact: Dash Weeks - timdash@nist.gov - 303-968-8822



The information contained on this drawing shall be considered intellectual property owned by NIST. Authorized receipt and review of this information implies consent to non-disclosure of trade secrets. Disclosure to third parties is unauthorized without prior written permission from NIST.

NIST

Specimens with welds must be aligned axially and centrally with the weld center line.

Specimens without welds are aligned parallel with the pipe axis (reference lines provided on pipe) or perpendicular to the pipe axis.

Kerf dimension is unimportant. Sprues must be at the ends of the specimens.



PROJECT:

Vintage X100

MATERIAL: X100 Steel

QTY REQUIRED: 1

DEFAULT UNITS: Inches
 DEFAULT TOLERANCE: $\pm 0.005'' - \pm 1'$
 DEFAULT FINISH: < 63 microinch

PART/VIEW:


P1S2

SCALE: In View SHEET: 1 of 1 CREATION DATE: 8/11/2021 REVISION:

Contact: Dash Weeks - timdash@nist.gov - 303-968-8822

The information contained on this drawing shall be considered intellectual property owned by NIST. Authorized receipt and review of this information implies consent to non-disclosure of trade secrets. Disclosure to third parties is unauthorized without prior written permission from NIST.


NIST



Specimens with welds must be aligned axially and centrally with the weld center line.

Specimens without welds are aligned parallel with the pipe axis (reference lines provided on pipe) or perpendicular to the pipe axis.

Kerf dimension is unimportant. Sprues must be at the ends of the specimens.



It is very possible that there isn't enough material at this end to actually cut. The important setup requirement is that the weld center line is in the middle of the specimens.



PART/VIEW:
P1S2-90

PROJECT:
Vintage X100

SCALE: In View SHEET: 1 of 1 CREATION DATE: 8/11/2021 REVISION:

MATERIAL: X100 Steel
QTY REQUIRED: 1

Contact: Dash Weeks - timdash@nist.gov - 303-968-8822



The information contained on this drawing shall be considered intellectual property owned by NIST. Authorized receipt and review of this information implies consent to non-disclosure of trade secrets. Disclosure to third parties is unauthorized without prior written permission from NIST.

DEFAULT UNITS: Inches
DEFAULT TOLERANCE: $\pm 0.005'' - \pm 1'$
DEFAULT FINISH: < 63 microminch

Specimens with welds must be aligned axially and centrally with the weld center line.

Specimens without welds are aligned parallel with the pipe axis (reference lines provided on pipe) or perpendicular to the pipe axis.

Kerf dimension is unimportant. Sprues must be at the ends of the specimens.



PROJECT:
Vintage X100
MATERIAL: X100 Steel
QTY REQUIRED: 1

PART/VIEW:
P1S2-180



SCALE: In View SHEET: 1 of 1 CREATION DATE: 8/11/2021 REVISION:

Contact: Dash Weeks - timdash@nist.gov - 303-968-8822

The information contained on this drawing shall be considered intellectual property owned by NIST. Authorized receipt and review of this information implies consent to non-disclosure of trade secrets. Disclosure to third parties is unauthorized without prior written permission from NIST.



NOTES:

DEFAULT UNITS: Inches
DEFAULT TOLERANCE: $\pm 0.005'' - \pm 1'$
DEFAULT FINISH: < 63 microinch

Specimens with welds must be aligned axially and centrally with the weld center line.

Specimens without welds are aligned parallel with the pipe axis (reference lines provided on pipe) or perpendicular to the pipe axis.

Kerf dimension is unimportant. Sprues must be at the ends of the specimens.



PROJECT:
Vintage X100

MATERIAL: X100 Steel

QTY REQUIRED: 1

DEFAULT UNITS: Inches
DEFAULT TOLERANCE: $\pm 0.005'' - \pm 1'$
DEFAULT FINISH: < 63 microinch

PART/VIEW:
P2S1

NIST

SCALE: In View SHEET: 1 of 1 CREATION DATE: 8/11/2021 REVISION:



Contact: Dash Weeks - timdash@nist.gov - 303-968-8822

The information contained on this drawing shall be considered intellectual property owned by NIST. Authorized receipt and review of this information implies consent to non-disclosure of trade secrets. Disclosure to third parties is unauthorized without prior written permission from NIST.

Specimens with welds must be aligned axially and centrally with the weld center line.

Specimens without welds are aligned parallel with the pipe axis (reference lines provided on pipe) or perpendicular to the pipe axis.

Kerf dimension is unimportant. Sprues must be at the ends of the specimens.



PROJECT:

Vintage X100

MATERIAL: X100 Steel

QTY REQUIRED: 1

DEFAULT UNITS: Inches
 DEFAULT TOLERANCE: $\pm 0.005"$ - $\pm 1'$
 DEFAULT FINISH: < 63 microinch

PART/VIEW:

P2S1-90

SCALE: In View SHEET: 1 of 1 CREATION DATE: 8/11/2021 REVISION:

Contact: Dash Weeks - timdash@nist.gov - 303-968-8822



The information contained on this drawing shall be considered intellectual property owned by NIST. Authorized receipt and review of this information implies consent to non-disclosure of trade secrets. Disclosure to third parties is unauthorized without prior written permission from NIST.



Specimens with welds must be aligned axially and centrally with the weld center line.

Specimens without welds are aligned parallel with the pipe axis (reference lines provided on pipe) or perpendicular to the pipe axis.

Kerf dimension is unimportant. Sprues must be at the ends of the specimens.



PROJECT:
Vintage X100

MATERIAL: X100 Steel

QTY REQUIRED: 1

DEFAULT UNITS: Inches
DEFAULT TOLERANCE: $\pm 0.005"$ - $\pm 1'$
DEFAULT FINISH: < 63 microinch

PART/VIEW:
P2S1-180

SCALE: In View SHEET: 1 of 1 CREATION DATE: 8/11/2021

REVISION:

Contact: Dash Weeks - timdash@nist.gov - 303-968-8822



The information contained on this drawing shall be considered intellectual property owned by NIST. Authorized receipt and review of this information implies consent to non-disclosure of trade secrets. Disclosure to third parties is unauthorized without prior written permission from NIST.

NIST

Specimens with welds must be aligned axially and centrally with the weld center line.

Specimens without welds are aligned parallel with the pipe axis (reference lines provided on pipe) or perpendicular to the pipe axis.

Kerf dimension is unimportant. Sprues must be at the ends of the specimens.



PROJECT:

Vintage X100

MATERIAL: X100 Steel

QTY REQUIRED: 1

DEFAULT UNITS: Inches
 DEFAULT TOLERANCE: ± 0.005" - ± 1'
 DEFAULT FINISH: < 63 microinch

PART/VIEW:

P2S2

SCALE: In View SHEET: 1 of 1 CREATION DATE: 8/11/2021 REVISION:

Contact: Dash Weeks - timdash@nist.gov - 303-968-8822



The information contained on this drawing shall be considered intellectual property owned by NIST. Authorized receipt and review of this information implies consent to non-disclosure of trade secrets. Disclosure to third parties is unauthorized without prior written permission from NIST.



Specimens with welds must be aligned axially and centrally with the weld center line.

Specimens without welds are aligned parallel with the pipe axis (reference lines provided on pipe) or perpendicular to the pipe axis.

Kerf dimension is unimportant. Sprues must be at the ends of the specimens.



PROJECT:
Vintage X100

MATERIAL: X100 Steel

QTY REQUIRED: 1

DEFAULT UNITS: Inches
DEFAULT TOLERANCE: $\pm 0.005'' - \pm 1'$
DEFAULT FINISH: < 63 microinch

PART/VIEW:
P2S2-90



SCALE: In View SHEET: 1 of 1 CREATION DATE: 8/11/2021 REVISION:



Contact: Dash Weeks - timdash@nist.gov - 303-968-8822

The information contained on this drawing shall be considered intellectual property owned by NIST. Authorized receipt and review of this information implies consent to non-disclosure of trade secrets. Disclosure to third parties is unauthorized without prior written permission from NIST.

Specimens with welds must be aligned axially and centrally with the weld center line.

Specimens without welds are aligned parallel with the pipe axis (reference lines provided on pipe) or perpendicular to the pipe axis.

Kerf dimension is unimportant. Sprues must be at the ends of the specimens.



PROJECT:

Vintage X100

MATERIAL: X100 Steel

QTY REQUIRED: 1

DEFAULT UNITS: Inches
 DEFAULT TOLERANCE: $\pm 0.005'' - \pm 1'$
 DEFAULT FINISH: < 63 microinch

PART/VIEW:

P2S2-180

SCALE: In View SHEET: 1 of 1 CREATION DATE: 8/11/2021 REVISION:

Contact: Dash Weeks - timdash@nist.gov - 303-968-8822



The information contained on this drawing shall be considered intellectual property owned by NIST. Authorized receipt and review of this information implies consent to non-disclosure of trade secrets. Disclosure to third parties is unauthorized without prior written permission from NIST.



Specimens with welds must be aligned axially and centrally with the weld center line.

Specimens without welds are aligned parallel with the pipe axis (reference lines provided on pipe) or perpendicular to the pipe axis.

Kerf dimension is unimportant. Sprues must be at the ends of the specimens.



PROJECT:
Vintage X100
MATERIAL: X100 Steel

PART/VIEW:
P3S1-90



SCALE: In View SHEET: 1 of 1 CREATION DATE: 8/11/2021 REVISION:

Contact: Dash Weeks - timdash@nist.gov - 303-968-8822

QTY REQUIRED: 1
 NOTES:
 DEFAULT UNITS: Inches
 DEFAULT TOLERANCE: ± 0.005" - ± 1'
 DEFAULT FINISH: < 63 microminch

The information contained on this drawing shall be considered intellectual property owned by NIST. Authorized receipt and review of this information implies consent to non-disclosure of trade secrets. Disclosure to third parties is unauthorized without prior written permission from NIST.

OM1



OM2
OM3

OM4

Specimens with welds must be aligned axially and centrally with the weld center line.

Specimens without welds are aligned parallel with the pipe axis (reference lines provided on pipe) or perpendicular to the pipe axis.

Kerf dimension is unimportant. Sprues must be at the ends of the specimens.



PROJECT:
Vintage X100

MATERIAL: X100 Steel

QTY REQUIRED: 1

DEFAULT UNITS: Inches
DEFAULT TOLERANCE: ± 0.005" - ± 1'
DEFAULT FINISH: < 63 microinch


PART/VIEW:
P3S1-180



SCALE: In View SHEET: 1 of 1 CREATION DATE: 8/11/2021 REVISION:

Contact: Dash Weeks - timdash@nist.gov - 303-968-8822


The information contained on this drawing shall be considered intellectual property owned by NIST. Authorized receipt and review of this information implies consent to non-disclosure of trade secrets. Disclosure to third parties is unauthorized without prior written permission from NIST.



Specimens with welds must be aligned axially and centrally with the weld center line.

Specimens without welds are aligned parallel with the pipe axis (reference lines provided on pipe) or perpendicular to the pipe axis.

Kerf dimension is unimportant. Sprues must be at the ends of the specimens.



PROJECT:
Vintage X100
MATERIAL: X100 Steel
QTY REQUIRED: 1

PART/VIEW:
P3S2



SCALE: In View SHEET: 1 of 1 CREATION DATE: 8/11/2021 REVISION:

Contact: Dash Weeks - timdash@nist.gov - 303-968-8822

The information contained on this drawing shall be considered intellectual property owned by NIST. Authorized receipt and review of this information implies consent to non-disclosure of trade secrets. Disclosure to third parties is unauthorized without prior written permission from NIST.



DEFAULT UNITS: Inches
DEFAULT TOLERANCE: $\pm 0.005"$ - $\pm 1'$
DEFAULT FINISH: < 63 microinch

NOTES:

Specimens with welds must be aligned axially and centrally with the weld center line.

Specimens without welds are aligned parallel with the pipe axis (reference lines provided on pipe) or perpendicular to the pipe axis.

Kerf dimension is unimportant. Sprues must be at the ends of the specimens.



PROJECT:
Vintage X100

MATERIAL: X100 Steel

QTY REQUIRED: 1

DEFAULT UNITS: Inches
DEFAULT TOLERANCE: $\pm 0.005'' \pm 1'$
DEFAULT FINISH: < 63 microinch

PART/VIEW:
P3S3

SCALE: In View SHEET: 1 of 1 CREATION DATE: 8/11/2021 REVISION:

Contact: Dash Weeks - timdash@nist.gov - 303-968-8822

The information contained on this drawing shall be considered intellectual property owned by NIST. Authorized receipt and review of this information implies consent to non-disclosure of trade secrets. Disclosure to third parties is unauthorized without prior written permission from NIST.



SM1



SM2

SM3

Specimens with welds must be aligned axially and centrally with the weld center line.

Specimens without welds are aligned parallel with the pipe axis (reference lines provided on pipe) or perpendicular to the pipe axis.

Kerf dimension is unimportant. Sprues must be at the ends of the specimens.



PROJECT:
Vintage X100

MATERIAL: X100 Steel

QTY REQUIRED: 1

NOTES:
DEFAULT UNITS: Inches
DEFAULT TOLERANCE: $\pm 0.005"$ - $\pm 1'$
DEFAULT FINISH: < 63 microminch

PART/VIEW:
P3S3-180



SCALE: In View SHEET: 1 of 1 CREATION DATE: 8/11/2021 REVISION:

Contact: Dash Weeks - timdash@nist.gov - 303-968-8822

The information contained on this drawing shall be considered intellectual property owned by NIST. Authorized receipt and review of this information implies consent to non-disclosure of trade secrets. Disclosure to third parties is unauthorized without prior written permission from NIST.